



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555-0001

May 19, 1994

Docket Nos. 50-213, 50-245,
50-336, 50-423,
and 50-443

LICENSEE: Northeast Utilities (NU)
FACILITIES: Haddam Neck, Millstone Units 1, 2, and 3, and Seabrook
SUBJECT: SUMMARY OF APRIL 21, 1994, NRC/NORTHEAST UTILITIES COUNTERPARTS
MEETING

On April 21, 1994, representatives of Northeast Utilities (NU) and the NRC staff met at the NU Corporate Headquarters in Berlin, Connecticut. Enclosure 1 contains the list of attendees. The meeting represented the eighth in a series of "counterpart meetings" during which the NRC and NU discussed various programs and issues at Haddam Neck, Millstone Units 1, 2, and 3, and Seabrook. Enclosure 2 contains summary material relating to NU's presentations.

Following opening remarks by NRC and NU, R. E. Busch addressed the group and spoke about the importance of safety as the first priority. Mr. Busch described safety as the "permissive gate" to discussion of economic issues and emphasized the importance of demonstrating the understanding of safety to the public, the regulators, and to NU. Mr. Busch went on to say that the NU reengineering effort is expected to begin (e.g., mobilizing appropriate personnel) later this year in the nuclear organization. Reengineering is a method for evaluating the process for delivering a service to NU customers.

There was an exchange of ideas and acknowledgement by the NRC of the importance being placed on cost beneficial licensing actions (CBLAs). NRC commented that the NRC has had a team interviewing utilities for the past year, soliciting input on issues that are considered to provide no significant safety benefit.

NU provided an overview of the initiative undertaken to return Millstone Station to the status of excellence. The key to reestablishing Millstone Station's former state of excellence is developing employee trust. Once employee trust is regained, an atmosphere that allows cultural change can develop which will promote teamwork. This increased sense of employees working as a team will result in improved initial performance ("more things being done right the first time"), improved employee morale, and lessened employee frustration. The resultant outcome will be improved safety and increased electric production.

With regard to the concerned employee issue, NU noted that once employee trust is regained, employees will feel more comfortable addressing their concerns through the management chain. The NRC noted that it has been NRC's experience that the majority of employee concerns deal with processes (i.e., procedures), and improvements in this area seem to be slow. NU responded by stating that one way to achieve improvement in this area is by implementing more common procedures across the three Millstone units.

200057

9405250111 940519
PDR ADOCK 05000213
P PDR

NRC FILE CENTER COPY

DFU

With regard to the schedule for submittal of 24-month refueling license amendment requests, the NRC requested additional clarification. NU pointed out that the license amendment requests would be for extension of surveillance intervals (from 18-month to 24-month intervals), and the dates designated in the handout material were target dates for submittal of the last license amendment requests to the NRC. NU also noted that they intend to organize the license amendment requests by system in order to help minimize the number of reviews required to be performed by the Staff.

The NRC asked why Seabrook is not planning on going to 24-month fuel cycles. NU replied that Seabrook does not have sufficient operating experience at this time to make the transition from 18- to 24-month cycles, although it may be considered at some point in the future.

The NRC questioned whether the spent fuel pool storage capacity noted in the current monthly operating report corresponds to the schedules represented in the 24-month fuel cycle project. NU replied that the schedules do match; however, they do not take into consideration any contemplated future reracking.

With regard to CBLAs, NU provided an overview of the efforts ongoing at NU to identify potential items for inclusion in the nuclear group's reduction of regulatory burden program. NU stated that the nuclear group has generated approximately 90 ideas for possible CBLAs. NU noted that they have recently docketed the first official CBLA, i.e., a submittal specifically identified as such. Notwithstanding this, approximately 23.5 to 29.5 million dollars of avoided costs have been achieved through CBLA activities during 1993.

The NRC noted that it is important for licensees to understand how the NRC plans on handling CBLAs. Currently, items of low safety significance are assigned a low priority. The technical reviewers process them as time is available. CBLAs will get a slightly higher priority than they would otherwise get as low safety significant issues. The NRC considers it important that licensees are aware of this process so that issues of higher safety significance aren't labeled as CBLA and, therefore, lowered in priority by the NRC ranking process.

More information on the topic of CBLAs is expected to be available at the regulatory information conference.

With regard to responding to employee concerns, the NRC asked if individuals received monetary incentives for bringing forth nuclear safety concerns. NU responded that there have been a few instances where money has been awarded to employees who bring forth safety concerns (through the Spot Recognition Program), but that the NU management team needed to exercise case-specific judgment given that nuclear safety is considered to be a fundamental responsibility of every employee.

The NRC noted that the tabulation of employee concerns for Millstone Station that was presented in the handout appeared somewhat misleading. The NRC

stated that the actual number of nuclear safety concerns is more like 75 to 80 rather than the 38 identified by NU. With regard to the identification of nuclear safety concerns, the NRC pointed out that the initial conflict occurs at the first-line supervisor level and that NU needs to do a better job of supporting those supervisors.

On the subject of a long-term solution for the Millstone Unit No. 3 supplementary leak collection and release system (SLCRS), NU provided the system description, recent activities, and an action plan to resolve the design deficiencies. The NRC inquired as to whether NU had revisited the possibility of having two trains operating simultaneously rather than having one train shut down before the next one starts. NU reported that NU is considering many alternatives that will simplify the SLCRS. With regard to NU's schedule for submittal of any license amendment requests (i.e., restored containment leakage rate, revised drawdown time), the NRC was informed that NU expects to submit requests in the August/September timeframe.

With regard to long term improvements, NU spoke on the impact of existing source term assumptions, specifically the magnitude and timing of a release, and the relative urgency placed on the NRC issuing the revised source term (NUREG-1465) and its application to existing plants.

On the subject of human engineering discrepancies (HEDs), the NRC stated their willingness to support resolution of the remaining items by having their human factors branch personnel come to NU and assist in dispositioning the remaining HEDs. The schedule for dispositioning the remaining HEDs at Millstone Unit No. 1 is late summer/early fall 1994.

On the subject of 10 CFR Part 50, Appendix J modifications, NU reported that a submittal was recently docketed for Millstone Unit No. 1. This submittal contained Appendix J exemption requests for several penetrations. In addition to the exemption requests, NU discussed why certain valves were considered to be outside the scope of Appendix J. The basis for not performing modifications to certain valves was previously discussed in the ISAP update reports. Modifications to make these valves testable would cost millions of dollars and would provide no commensurate safety benefit. The NRC asked what the difference was between this current Appendix J submittal and the one that NRC had previously rejected. NU stated that the current submittal provides an improved basis for the exemptions requested as well as a discussion concerning why certain valves do not belong in the Appendix J program.

With regard to the Performance Enhancement Program status, a concern was raised about the number of failures during the validation process. NU stated that some questions arose during the Verification/Validation (V&V) process and the decision was made to keep those action plans open and reassess them. The NRC suggested that action plans that have failed validation, or action plans that are completed but not yet validated, be reflected in the 1995 business plan. The NRC went on to emphasize the importance of demonstrating that the intended effects of the action plan are complete and reiterated that the NRC feels obligated to assure that all 42 action plans are complete. The NRC does not view an item as complete until the validation is closed out.

On the subject of integration of the corporate EOC into the site organizations, NU provided an overview of the plan to eliminate the corporate EOC by incorporation of the functions into the site organization, with a long-range plan of designating the State Armory as the alternate location. The State of Connecticut is aware of these plans which are expected to improve communications between the State and the sites. The overall plan is intended to strengthen the technical support centers at the sites. NRC approval is required to change the alternate location from the corporate EOC to the Armory.

Original signed by:

David H. Jaffe, Sr. Project Manager
 Project Directorate I-4
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. NU's Presentation

DISTRIBUTION: w/enclosures 1 & 2
 Docket File
 NRC & Local PDRs
 PDI-4 Memo
 LDoerflein, RGI
 DJaffe

DISTRIBUTION: w/enclosure 1
 WRussell/FMiraglia ADe Agazio PHabighorst
 LReyes VRooney PSwetland
 SVarga GVissing ACRS (10)
 JCalvo JAndersen
 SNorris OGC
 AWang EJordan

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME	SNorris	DJaffe:bp	JStolz		
DATE	5/17/94	5/18/94	5/18/94	1/94	1/1

OFFICIAL RECORD COPY
 Document Name: G:\JAFFE\COUNTSUM

May 19, 1994

On the subject of integration of the corporate EOC into the site organizations, NU provided an overview of the plan to eliminate the corporate EOC by incorporation of the functions into the site organization, with a long-range plan of designating the State Armory as the alternate location. The State of Connecticut is aware of these plans which are expected to improve communications between the State and the sites. The overall plan is intended to strengthen the technical support centers at the sites. NRC approval is required to change the alternate location from the corporate EOC to the Armory.



David H. Jaffe, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. NU's Presentation

Mr. John F. Opeka
Northeast Nuclear Energy Company

Haddam Neck Plant & Millstone Power
Station, Unit Nos. 1, 2 & 3

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Resident Inspector
Haddam Neck Plant
c/o U.S. Nuclear Regulatory Commission
361 Injun Hollow Road
East Hampton, Connecticut 06424-3099

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, Connecticut 06106-5127

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

F. R. Dacimo, Nuclear Unit Director
Millstone Unit No. 3
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

Burlington Electric Department
c/o Robert E. Fletcher, Esq.
271 South Union Street
Burlington, Vermont 05402

David W. Graham
Fuel Supply Planning Manager
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Mr. John F. Opeka
Nuclear Northeast Nuclear Energy Company

Haddam Neck Plant & Millstone
Power Station, Unit Nos. 1, 2 & 3

cc:

H. F. Haynes, Nuclear Unit Director
Millstone Unit No. 1
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

G. H. Bouchard, Nuclear Unit Director
Millstone Unit No. 2
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Charles Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Pkwy., Suite 330
Rockville, Maryland 20852

Board of Selectmen
Town Office Building
Haddam, Connecticut 06438

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

J. J. LaPlatney
Haddam Neck Unit Director
Connecticut Yankee Atomic Power Company
36? Injun Hollow Road
East Hampton, Connecticut 06424-3099

J. M. Solymossy, Director
Nuclear Quality and Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Mr. Ted C. Feigenbaum

cc:

Thomas Dignan, Esq.
John A. Ritsher, Esq.
Ropes and Gray
One International Place
Boston, Massachusetts 02110-2624

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
Post Office Box 1149
Seabrook, New Hampshire 03874

Jane Spector
Federal Energy Regulatory Commission
825 North Capital Street, N.E.
Room 8105
Washington, DC 20426

Mr. T. L. Harpster
North Atlantic Energy Service
Corporation
Post Office Box 300
Seabrook, New Hampshire 03874

Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Gerald Garfield, Esq.
Day, Berry and Howard
City Place
Hartford, Connecticut 06103-3499

Mr. R. M. Kacich
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Seabrook Station

Mr. George L. Iverson, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, New Hampshire 03301

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, Massachusetts 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts 01913

Mr. Jack Dolan
Federal Emergency Management Agency
Region I
J.W. McCormack Post Office &
Courthouse Building, Room 442
Boston, Massachusetts 02109

Mr. David Rodham, Director
Massachusetts Civil Defense Agency
400 Worcester Road
Post Office Box 1496
Framingham, Massachusetts 01701-0317
ATTN: James Muckerheide

Jeffrey Howard, Attorney General
G. Dana Bisbee, Deputy Attorney
General
Attorney General's Office
25 Capitol Street
Concord, New Hampshire 03301

Mr. Robert Sweeney
Bethesda Licensing Office
Suite 610
3 Metro Center
Bethesda, Maryland 20814

ENCLOSURE 1

ATTENDEES AT APRIL 21, 1994

NCR/NU COUNTERPARTS MEETING

NRC

J. Stolz
D. Jaffe
P. Habighorst
P. Swetland
A. Wang
G. Vissing
A. De Agazio
V. Rooney
J. Andersen

NU

R. Kacich
B. Solomon
E. Perkins, Jr.
D. Miller, Jr.
H. Risley
L. Chatfield
L. Cuoco
M. Wilson
M. Bonaca
S. Scace
F. Dacimo
J. Solymossy
R. Necci
R. Young
C. Ashton
F. Van Noordennen
M. Kupinski
C. Ondash
P. Miner
K. Hannon
T. Silko
E. Bennett
P. Patton
J. Peschel
A. Callendrello
A. Castagno
W. Temple
J. Stetz
R. Schmidt
W. Hutchins
E. Marks
G. Pitman
J. DeVeau
P. Pastuszak
D. Dube

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Location: Room 0-3F, NU-East
Time: 9 a.m. to 4 p.m.

Agenda

I. INTRODUCTION

II. SELECTED NU INITIATIVES

- A. Initiatives for the 90's
- B. Nuclear Group Reorganization and Relocation to the Sites
- C. 24-Month Fuel Cycles
- D. Cost-Beneficial Licensing Actions
- E. NRB Restructuring
- F. Current Licensing Basis (CLB) Status
- G. Integration of the Corporate EOC Into the Site Organization
- H. PEP Status
- I. Responding to Employee Concerns

III. MAJOR LICENSING ISSUES

- A. SLCRS Long-Term Solution
- B. Status of SEP Topics (CY & Millstone 1)
- C. Control Room Design Review - HED Status - Millstone 1 & CY
- D. Appendix J Modifications/Changes - Millstone 1
- E. Spent Fuel Storage Capacity and Future Spent Fuel Storage Plans at Millstone Units and CY

IV. REGULATORY INTERFACE ISSUES

- A. NRC/NU Communication – General Discussion
- B. NRC Inspection Schedule
- C. ISAP License Conditions

V. GENERAL LICENSING TOPICS

- A. Implementation of Line-item Technical Specification Improvements
- B. Plant-Specific Issues
- C. Status of USI, TMI Items, SEP Items, GSIs

VI. SUMMARY AND CONCLUSIONS


I. INTRODUCTION

II. SELECTED NU INITIATIVES

II.A INITIATIVES FOR THE 90'S

INITIATIVES TO RETURN MILLSTONE STATION TO STATUS OF EXCELLENCE


- DEVELOP CONSISTENCY IN WORK PROGRAMS BETWEEN UNITS
- ESTABLISH TEAMWORK BETWEEN UNITS
- DEVELOP OPENNESS TO COMMENTS
- DEVELOP OWNERSHIP BY FRONT LINE SUPERVISORS
- DEVELOP/ENHANCE LEADERSHIP SKILLS
- FOCUS WORKERS ON THEIR JOBS



II.A INITIATIVES FOR THE 90'S (CONT'D.)

DEFINITION OF MY JOB

- PROTECT HEALTH AND SAFETY OF THE EMPLOYEES
- PROTECT HEALTH AND SAFETY OF THE NEIGHBORS
- CONTRIBUTE TO A SUCCESSFUL NU ORGANIZATION
- COMMUNICATE MY VALUES:
 - Safety
 - Integrity
 - People
 - Teamwork
- MONITOR EFFECTIVENESS OF INITIATIVES



II.A INITIATIVES FOR THE 90'S (CONT'D.)

SELF-ASSESSMENT

- "MILLSTONE STATION SELF-ASSESSMENT PROCESS MANUAL" ISSUED MARCH 1994
- ONGOING SELF-ASSESSMENT PROVIDES FOR STATION IMPROVEMENT BY:
 - Candid and Objective Evaluation of Our Own Performance
 - Timely and Effective Corrective Action
 - Fostering a No-Fault Attitude to Problem Discovery and Reporting
- MAJOR FOCUS FOR 1994 IS HORIZONTAL (INPO-STYLE) AND VERTICAL ASSESSMENTS


PLANT INFORMATION REPORT

- REDESIGN OF PIR PROCESS
- ANYONE CAN INITIATE A REPORT
- PROMOTE A LOW INITIATION THRESHOLD
- PROCESS COORDINATED BY A SINGLE GROUP
- IMPLEMENTATION IN THIRD QUARTER 1994

ENHANCE COMMUNICATIONS WITH EMPLOYEES

- COMMUNICATION IS VERY IMPORTANT TO WORKERS
- DEVELOPED DAILY PAPER: "TO THE POINT"
- INCREASE MANAGEMENT PRESENCE IN FIELD
- ESTABLISH A COMMUNICATIONS COUNCIL

APPROACH TO THE CONCERNED EMPLOYEE ISSUE AT MILLSTONE



II.A INITIATIVES FOR THE 90'S (CONT'D.)

EXPECTATIONS OF EMPLOYEE BEHAVIOR

- TREAT EVERYONE WITH RESPECT
- WORK TOGETHER AS A TEAM
- DO EVERY TASK RIGHT THE FIRST TIME
- IMMEDIATELY REPORT SAFETY ISSUES
- TAKE RESPONSIBILITY FOR OWN ACTIONS

II.B NUCLEAR GROUP REORGANIZATION AND
RELOCATION TO THE SITES

II.B NUCLEAR GROUP REORGANIZATION AND
RELOCATION TO THE SITES

ENGINEERING INTEGRATION -- BACKGROUND

- INTEGRATION OF ACTIVITIES
- OPERATIONAL FOCUS

OBJECTIVE: IMPROVE QUALITY OF ENGINEERING SUPPORT TO PLANTS

- CLARIFY ENGINEERING ROLES AND RESPONSIBILITIES
- ELIMINATE DUPLICATION OF WORK

APPROACH: WHO, HOW

- WHO:
 - NU Team of Engineering Managers
 - Full Time
 - Consultant - Towers Perrin
- HOW:
 - Issue Definition
 - Detailed Analysis and Recommendations Development
 - Finalization and Implementation

II.B NUCLEAR GROUP REORGANIZATION AND
RELOCATION TO THE SITES (CONT'D)

RESULTS OF ENGINEERING INTEGRATION

- MORE EFFECTIVE ORGANIZATION
- CLEAR ROLES AND RESPONSIBILITIES
- FOCUS ON PLANT OPERATIONS
- RECOGNIZES ENGINEERING'S ROLE
- DIRECTOR LEVEL ENGINEERING DEPARTMENT
- FULLY IMPLEMENTS SYSTEM ENGINEERING

II.B NUCLEAR GROUP REORGANIZATION AND
RELOCATION TO THE SITES (CONT'D)

MAINTENANCE INTEGRATION

- SIMILAR TO ENGINEERING
- EQUIPMENT ANALYSIS
- NDE
- PROGRAMMATIC MAINTENANCE
- MAINTENANCE SUPPORT

RESULTS OF MAINTENANCE INTEGRATION

- UNIT MAINTENANCE
- ALL MAINTENANCE SUPPORT UNDER SENIOR VICE PRESIDENT OF MILLSTONE
- IMPROVE EFFECTIVENESS
- FUTURE RECOMMENDATIONS

II.B NUCLEAR GROUP REORGANIZATION AND
RELOCATION TO THE SITES (CONT'D)

RELOCATION TO SITE

- FACILITIES (TECHNICAL SUPPORT BUILDING)
- PERSONNEL
- INFORMATION TECHNOLOGY
- STATUS
 - Technical Support Building, Completion - July 1994
 - Millstone 1 Personnel Relocated
 - Millstone 2 and 3 Personnel
 - Connecticut Yankee Personnel
 - Quality and Assessment Services
 - Nuclear Planning, Licensing and Budgeting
 - Nuclear Operations Support Service
 - Nuclear Emergency Preparedness

II.C 24-MONTH FUEL CYCLES

II.C 24-MONTH FUEL CYCLES

BACKGROUND

- VARIOUS FACTORS HAVE ENCOURAGED NU TO PURSUE 24-MONTH CYCLES AT MILLSTONE 2, MILLSTONE 3, AND CONNECTICUT YANKEE
 - Successful 24-month operation at Millstone 1
 - Successful 24-month operation at other plants
 - Historically, NU has operated its units on the longest achievable fuel cycle without a mid-cycle shutdown
 - Potential cost and radiation dose savings due to fewer outages
- EFFECTIVELY SUPPORTED BY THE IMPLEMENTATION OF THE MAINTENANCE RULE
- FUEL DESIGNS AND FUEL MANAGEMENT SCHEMES WILL ALLOW 24-MONTH OPERATION AT MILLSTONE 2, MILLSTONE 3, AND CONNECTICUT YANKEE

OBJECTIVES

DEVELOP AND IMPLEMENT INTEGRATED TECHNICAL AND LICENSING PROGRAM TO ADDRESS REGULATORY REQUIREMENTS FOR A 24-MONTH FUEL CYCLE FOR MILLSTONE 2, MILLSTONE 3, AND CONNECTICUT YANKEE


II.C 24-MONTH FUEL CYCLES (CONT'D.)

SCOPE

WILL ADDRESS FUEL AND NONFUEL-RELATED ISSUES

- FUEL ISSUES
 - Cycle design and length reload analysis
 - Spent Fuel/New Fuel Storage Requirements
- NONFUEL-RELATED ISSUES
 - Instrumentation Drifts and Setpoint Impacts
 - Steam Generator Tube Inspections
 - Containment Leak Rate
 - Safety Goal Compatibility
 - Plant Maintenance/Reliability
 - Outage Integrations
- NRC GUIDANCE - GL 91-04 WILL BE USED TO EVALUATE AND TO PREPARE NECESSARY SUBMITTALS

ORGANIZATION STRUCTURE FOR THE 24-MONTH FUEL CYCLE PROJECT FOR MILLSTONE 2, MILLSTONE 3, AND CONNECTICUT YANKEE



II.C 24-MONTH FUEL CYCLES (CONT'D.)

SCHEDULES AND MILESTONES

FUEL CYCLE PLANS

PLANT	MONTHS/CURRENT CYCLE	NEXT	FOLLOWING
Connecticut Yankee	18 Months (Cycle 18)	20 Months (Cycle 19)	24 Months (Cycle 20) September 1996
Millstone 2	20 Months (Cycle 12)	23 Months (Cycle 13)	24 Months (Cycle 14) July 1996
Millstone 3	21 Months (Cycle 5)	24 Months (Cycle 6) (July 1995)	24 Months (Cycle 7)

MAJOR MILESTONES

PLANT	LICENSE AMENDMENT REQUESTS SUBMITTALS TO THE NRC	REQUESTED NRC APPROVAL
Connecticut Yankee	November 1995	September 1996
Millstone 2	September 1995	July 1996
Millstone 3	July 1995	September 1996

II.D COST-BENEFICIAL LICENSING ACTIONS

II.E NRB RESTRUCTURING

II.E NRB RESTRUCTURING

BACKGROUND

- REFOCUS THE OVERSIGHT REVIEW FUNCTION FROM A STRONGLY TECHNICAL TO AN ASSESSMENT ROLE
- CLOSE ALIGNMENT OF THE OVERSIGHT REVIEW FUNCTION WITH FUNCTIONAL MANAGEMENT
- STRENGTHEN THE COMMUNICATION LINK WITH THE EVP-NUCLEAR
- ENHANCE THE ABILITY TO IDENTIFY GLOBAL ISSUES ACROSS THE ORGANIZATION
- FOSTER A HEALTHY SELF-ASSESSMENT ATTITUDE IN THE NUCLEAR ORGANIZATION

RESTRUCTURE PROCESS

- INVESTIGATE OTHER OVERSIGHT REVIEW BOARDS FOR MULTIPLE UNIT, MULTIPLE SITE UTILITIES
- ESTABLISH OBJECTIVES FOR THE NU OVERSIGHT REVIEW BOARD
- DEVELOP A CHARTER DESCRIBING THE BROAD PHILOSOPHICAL ASPECTS FOR THE BOARD
- DEVELOP THE IMPLEMENTING PROCEDURE DESCRIBING THE STRUCTURE AND PROCESSES OF THE OVERSIGHT REVIEW BOARD
- EVALUATE THE STRUCTURE AND PROCESS AGAINST INDUSTRY EXPERIENCE

II.E NRB RESTRUCTURING (CONT'D.)

CONCEPTUAL ORGANIZATION STRUCTURE

- ONE UNIFIED BOARD WOULD REPLACE THE FOUR UNIT NRBs AND THE MILLSTONE SNRB
- NSAB - NUCLEAR SAFETY ASSESSMENT BOARD
- CHAIRMAN IS THE VICE PRESIDENT OF NUCLEAR OPERATION SERVICES
- OUTSIDE MEMBERS (CONSULTANTS AND EXCHANGE MEMBERS) PROVIDE DIVERSITY
- ORGANIZATIONAL INFRASTRUCTURE TO PROVIDE SUPPORT TO THE CHAIRMAN AND THE BOARD

II.E NRB RESTRUCTURING (CONT'D.)

KEY POINTS

• MEMBERS

- Senior management is the backbone of the membership; Vice Presidents, selected directors, and members-at-large comprise the NU committee members
- Consultants and exchange members from other utilities add an independent perspective that encompasses industry and regulatory issues
- Minimize the need for in-depth technical experts as members; technical expertise can be brought in on an as-needed basis
- Members have the authority to act on most issues that come before the NSAB; only major issues will require direct involvement by the EVP-Nuclear

• SUBCOMMITTEES

- Used to ensure effective use of member's time
- Subcommittees for Safety Evaluation, Technical Support, Operations, and Quality Assurance are being considered
- Ad hoc subcommittees can be commissioned by the chairman when appropriate

II.E NRB RESTRUCTURING (CONT'D.)

- COMMUNICATIONS WITH THE EVP-NUCLEAR
 - Chairman provides a one-on-one briefing soon after each meeting
 - A memo to the EVP-Nuclear communicates significant issues or recommendations
 - Minutes of each meeting are forwarded to the EVP-Nuclear
 - EVP-Nuclear may attend meetings on a periodic basis to get a "flavor" of the issues
- PROCEDURES
 - Charter for the Nuclear Safety Assessment Board (NEO 2.02) is the implementing procedure for the Technical Specification requirements
 - NSAB Principles (NEO 2.02 attachment) provides the safety and assessment philosophy for the NSAB
 - Administrative procedures provide the detailed "how to" instructions; these procedures will be controlled and approved by the Chairperson

II.E NRB RESTRUCTURING (CONT'D.)

• MILESTONES AND DELIVERABLES

NSAB Principles (draft)	March	1994
Enabling Procedures (draft)	March	1994
Site Visits to Evaluate the Process	April	1994
Technical Specification Change Review	March & April	1994
Presentation to the NRC	Today	
NRC Review and Approval	May - October	1994
Administrative Procedures	May	1994
Develop the Transition Plan	June	1994

• MEMBERS OF THE NRB RESTRUCTURE TASK GROUP

John Blaisdell	Nuclear Safety Engineering
Paul Callaghan	Vice Chairman, MP3 NRB
Carl Clement	Vice Chairman, MP1 NRB
Reggie Rodgers	Vice Chairman, CY NRB
Richard Schmidt	Vice Chairman, MP2 NRB
Gerry van Noordennen	Nuclear Licensing

II.F CURRENT LICENSING BASIS (CLB) STATUS

II.F CURRENT LICENSING BASIS (CLB) STATUS

- CLB BACKGROUND
- CLB PRODUCTS
- NUCLEAR GROUP APPLICATIONS
- CLB APPLICATIONS TO LICENSING ISSUES
- LONG-TERM MAINTENANCE
- HARDWARE CONFIGURATION
- SUMMARY
- DEMONSTRATION

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

CLB BACKGROUND

• NRC ACTIVITIES RELATING TO CLB

- November 7, 1991
 - Generic Letter 91-18 (Operability/Degraded Equipment)
- January 13, 1992
 - CLB Definition 10CFR54.3
- March 19, 1992
 - Generic Letter 92-03 (CLB Pilot Program)
- June 1992
 - NRC/Utility Workshop on CLB Development
- November 1992
 - Office of Policy Planning Document (OPP-92-02) Current Licensing Basis for Operating Plants
- 1993
 - NRC Audits of How Licensees Control Changes to Their CLB
 - Spontaneous Demonstrations to NRC During Visits/ Inspections at NU

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

- NU'S ACTIVITIES RELATED TO CLB
- HISTORICALLY, CLB ISSUES HANDLED AS EMERGING CIRCUMSTANCES REQUIRED
- MID 1980s CONFIGURATION MANAGEMENT/DBR DISCUSSIONS
- CLB INITIATIVE PROPOSED IN 1990
- PEP ACTION PLAN 2.3.7 INITIATED TO ADDRESS CLB DEVELOPMENT
 - Overall Schedule Consists of Goals and Milestones Defined in PEP Action Plan 2.3.7
 - Activities Began in 1992 and Continue Through 1995
 - Major 1992 Accomplishments
 - Defined CLB Documents
 - Hardware, Software, and Data Conversion, Vendors Selected
 - Major 1993 Accomplishments
 - Data Conversion Pilot Program Analysis and Revisions
 - Full Scale Data Conversion Activities
 - Long-Range Planning Document (Issued 4/2/93)
 - Declaration of CLB Retrieval System Fully Functional (8/27/93)
 - CLB Pilot Program Benchmarking and Benchmarking Report (Issued 12/31/93)

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

- Major 1994 and 1995 Activities
 - Application Review (Completed 3/31/94)
 - Use of Tool in Existing Work Flow
 - Use of Tool in New Work Flow
 - Recommended Changes to Work Flow Procedures
 - Implementation of Work Flow Procedure Changes
 - Application to Licensing Issues (Underway)

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

CLB PRODUCTS

- WIDE VARIETY OF INFORMATION IS AVAILABLE ELECTRONICALLY
- CLB DATA BASE CONTAINS APPROXIMATELY 300,000 PAGES OF SEARCHABLE TEXT WITH APPROXIMATELY 230,000 IMAGES AVAILABLE
 - Licensing Basis (10CFR54.3 and NE&O 4.01)
 - Operating Licenses
 - NRC SERs
 - Technical Specifications
 - 10CFR
 - NRC/NU Correspondence
 - ASCII Text
 - Raster Images
 - Licensee Event Reports
 - Generic Correspondence
 - Bulletins
 - Generic Letters
 - Information Notices
 - Circulars

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

CLB PRODUCTS (CONT'D.)

- Supporting Information Examples
 - Regulatory Guides
 - NUREG Abstracts
 - NUREG-0737 (TMI)
 - NUREG-0800 (Standard Review Plan)
 - NRC Inspection Manual
 - NRC Enforcement Manual
- SEARCH CAPABILITIES
 - Enhanced Engineering Support (50.59, 50.72 and 50.73)
 - Program Integration Benefits (EQ, DBD, HELB, MOV)
- LICENSING PRODUCTIVITY INCREASED
 - Response to Emergent Situations Enhanced
 - General Support to Nuclear Units Improved
 - Licensing Information Readily Retrievable; Less Time Researching Files

NUCLEAR GROUP APPLICATIONS

- CLB DETERMINATIONS AND OTHER LICENSING INTERPRETATIONS REMAIN THE RESPONSIBILITY OF NL
- SAFETY EVALUATIONS PER 10CFR50.59
- REPORTABILITY AND OPERABILITY DETERMINATIONS
- JUSTIFICATION FOR CONTINUED OPERATIONS

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

NUCLEAR GROUP APPLICATIONS (CONT'D.)

- BACKFIT DETERMINATIONS
- INTEGRATION WITH DESIGN BASIS RECONSTRUCTION AND OTHER ESTABLISHED ENGINEERING PROGRAMS
- ENHANCED MEANS OF ACCESS TO PREVIOUS COMMITMENTS
- ENHANCED MEANS OF ACCESS TO PREVIOUS SIMILAR NU LERs

CLB APPLICATIONS TO LICENSING ISSUES


- PRELIMINARY LIST OF LICENSING ISSUES
 - Solicited Issues From Nuclear Group
 - Identified Licensing Issues Likely to Meet One of the Objectives of CLB
- PRIORITIZED LICENSING ISSUES
- END PRODUCT DEVELOPMENT
 - Defined CLB End Products Not Previously Captured
 - End Product Definition Based on Analysis and Results of the CLB Benchmarking Activities
- ADDRESS LICENSING ISSUES
 - Systematically Address the Identified and Prioritized Licensing Basis Issues
 - Subject to Resources, Staffing, and Priorities
- SCHEDULE
 - PEP 2.3.7 Targeted for Completion December 31, 1995
 - Issue Development to Continue Until Proactively Resolved

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

LONG-TERM MAINTENANCE

- DATABASE MAINTENANCE
 - Frequent Database Updates to Keep It Current
 - Periodic Database Backups
- USER PRODUCT MAINTENANCE
 - First Choice
 - Find Cost-Effective Homes for User Products, E.G., FSAR, T.S., T.S. Bases, Technical Requirements Manuals, Engineering Program Manuals, DBDPS, etc.
 - Alternate Choice
 - Create Selected CLB Summary Documents and Keep Them Current

Hardware Configuration



Page 36

II.F CURRENT LICENSING BASIS (CLB) STATUS (CONT'D.)

SUMMARY

- A Number of New and Enhanced Licensing Products
- Enhanced Means of Access to All Licensing Basis Documents
- Enhanced Means of Access to Previous NU Commitments to NRC
- In Harmony with Current NRC Thinking
- Close Communication with Seabrook
- Potential Asset in Facilitating Regulatory Interface
- Promote Cost-Effective Operation
- Demonstration

II.G INTEGRATION OF THE CORPORATE EOC INTO THE
SITE ORGANIZATION

II.G INTEGRATION OF THE CORPORATE EOC INTO THE SITE ORGANIZATION

• INTEGRATION DRIVEN BY:

- Engineering Support Relocating to the Sites
- Need to Strengthen the TSCs at Both Sites Based on Internal and NRC Feedback
- Need to Strengthen the EOFs by Integrating the Organization Into One Entity
- Need to Expedite Communications to the State
- Resource Savings

II.E INTEGRATION OF THE CORPORATE EOC INTO THE
SITE ORGANIZATION (CONT'D.)

SCHEDULE

- MARCH 29 EXECUTIVE VICE PRESIDENT - NUCLEAR APPROVAL
- APRIL-OCTOBER - REVISE AND DEVELOP PROCEDURES; SUBMIT TO PORC/SORC AS DEVELOPED FOR 3-1-95 IMPLEMENTATION
- JUNE-OCTOBER - TABLE TOP SESSIONS WITH THE ERO MEMBERS TO V & V DRAFT PROCEDURES
- JULY-DECEMBER - NUCLEAR TRAINING DEVELOPS TRAINING MATERIALS BASED ON APPROVED PROCEDURES
- NOVEMBER 1 - ALL PROCEDURES MUST BE READY FOR PORC/SORC APPROVAL IN ORDER FOR TRAINING TO DEVELOP TRAINING MATERIALS
- JANUARY-FEBRUARY - INTEGRATED TRAINING PRIOR TO IMPLEMENTATION
- MARCH 1, 1995 - IMPLEMENTATION OF THE NEW ORGANIZATION


II.H PEP STATUS

II.H PEP STATUS


PERFORMANCE ENHANCEMENT PROGRAM STATUS

- PEP Deliverables Remain On-Schedule
 - 1994 PEP Deliverable Status Chart
 - Action Series 1 through 4 Status


Action Plan Status



Action Plan is still active



Action Plan has been completed



Action Plan has been completed and validated

ROOT CAUSE

Management Practices

Contributor Level

Management Style

Leadership

Policy

Cultural/ Professional

Action Plans

[Blacked out box]

1.1.2 Objectivity (4/94)

[Blacked out box]

[Blacked out box]

1.2.2 Empowerment (Validated)

[Blacked out box]

[Blacked out box]

[Blacked out box]

[Blacked out box]

1.4.1 Cultural Analysis (12/97)

Status: 1 Action Plan Completed and Validated
7 Action Plans Completed
2 Action Plan Active

ROOT CAUSE

Programs & Processes

Contributor Level

Strategic Planning

Operational Planning & Budgeting

Work Programs & Processes

Action Plans

2.1.1 Strategic Planning (Validated)

2.2.1 Business Plan (Validated)

2.3.1 Configuration Management (2/95)

2.3.2 Design Control Processes (12/94)

[Redacted]

[Redacted]

2.3.4 Plant System Engineering (12/95)

2.3.5 Procedures (6/96)

2.3.6 Maintenance Rule & Reliability Centered Maintenance (5/97)

2.3.7 Licensing Basis (12/95)

[Redacted]

2.3.9 Engineering Backlog Reduction (Validated)

[Redacted]

Status: 3 Action Plans Completed & Validated
 4 Action Plans Completed
 6 Action Plans Active

ROOT CAUSE

Performance Assessment

Contributor Level

People/
Organizational

Assessment
Implementation

Management
Policies

Data
Analysis

Action
Plans

3.1.1 Reporting Relationships (Validated)

3.2.1 Communications (Validated)

3.3.1 Nuclear Fuel Cycle Management (11/94)

3.4.1 Nuclear Tracking & Trending System (11/94)

3.1.2 Reporting Relationships (Validated)

3.2.2 Communications (Validated)

3.3.2 Nuclear Fuel Cycle Management (11/94)

3.4.2 Nuclear Tracking & Trending System (11/94)

3.4.3 Nuclear Tracking & Trending System (11/94)

Page 46

Status: 2 Action Plans Completed & Validated
6 Action Plans Complete
2 Action Plans Active

These Action Plans have been developed to address other issues not identified by Root Cause Analysis

Functional Programs

Contributor Level

Nuclear Operation Services

Millstone Point

Connecticut Yankee

Corporate

Action Plans

4.1.1 MEPL / BOM (12/95)

[Redacted]

4.1.3 Nuclear Training Enhancement (1/95)

[Redacted]

[Redacted]

4.2.2 Chemical / Hazardous Material Control (1/95)

[Redacted]

[Redacted]

[Redacted]

4.4.3 Employee Concerns Program (Validated)

Status: 1 Action Plan Completed & Validated
6 Action Plan Completed
3 Action Plans Active

PEP Action Plans are Being Completed

Action Plans Completed & Validated.....	7
Action Plans Completed.....	23
Action Plans Active.....	12
Action Plans in Validation.....	9

Page 48

Remaining Validation Schedule

	Q1	Q2	Q3	Q4	Total
1994	--	6	4	3	13
1995	--	4	2	--	6
1996	--	3	--	1	4
1997	1	--	1	--	2
1998	1	--	--	--	1


PEP Deliverable / Milestone Status

1994 PEP DELIVERABLES / MILESTONES PERFORMANCE CHART

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

DELIVERABLES / MILESTONES
Page 50



II.H PEP STATUS (CONT'D.)

- VALIDATION IS UNDERWAY, 1994 IS AN ACTIVE YEAR
 - Twelve Validation reports prepared to date
 - 7 Recommended for Closure
 - 5 Remain Open, Issues Being Actively Pursued
 - Eighteen Additional Validations Planned for Remainder of this Year
 - Six Scheduled for 1995
 - Six to be Completed for Remainder of Program (1996-1998)

II.H PEP STATUS (CONT'D.)

- VALIDATION PROCESS REFLECTS HIGH STANDARDS
 - Assess If Intended Effect Achieved
 - Validation Team is Independent of Action Plan Manager
 - Action Plan Sponsor Concurs with Validation Plan
 - Action Plan is Closed only After Intended Effect Achieved

II.H PEP STATUS (CONT'D.)

- PEP WILL TRANSITION INTO BUSINESS PLAN
 - 1994 Business Plan
 - Partial Integration (PEP Deliverables specified, PEP Action Plan Remains a Unique Document)
 - 1995 Business Plan
 - Full Integration of Open PEP Deliverables into Business Plan
 - Validation Process Continues

II.H PEP STATUS (CONT'D.)

- THE PERFORMANCE ENHANCEMENT PROGRAM IS MAKING A POSITIVE CHANGE
 - Management Development Program is Being Implemented
 - Cultural Analysis Re-Survey Results Show Improvement
 - Engineering Backlog Reduction is Complete on Two Units
 - Technical Procedures Upgrades Are Being Accomplished
 - Engineering and Maintenance Integration is Complete
 - Root Cause Evaluations Are Becoming Part of NU Culture
 - Self-assessment Manual Has Been Issued at Millstone Station
 - Measures of Performance are Complete and Part of Management Process

II.I RESPONDING TO EMPLOYEE CONCERNS

II.I RESPONDING TO EMPLOYEE CONCERNS

EMPLOYEE CONCERNS ACTIVITY IS HIGH

1993	NRC MILLSTONE	NRC HADDAM NECK	NSCP
1st Qtr.	4	1	7
2nd Qtr.	8	3(1*)	5
3rd Qtr.	15	2	8
4th Qtr.	11	2(2*)	4
Total 1993	38	11	24
1994			
1st Qtr.	9	2	4
* Millstone & Haddam Neck, Jointly			

II.I RESPONDING TO EMPLOYEE CONCERNS (CONT'D.)

2.206 PETITIONS ARE ANOTHER INDICATOR OF EMPLOYEE CONCERN
ACTIVITY

- FOUR PETITIONS FILED BY CURRENT NU EMPLOYEES PENDING AT THIS TIME
- TWO PETITIONS FILED BY FORMER NU EMPLOYEES RECENTLY RESOLVED BY THE NRC STAFF

II.I RESPONDING TO EMPLOYEE CONCERNS (CONT'D.)

EMPLOYEE CONCERNS ACTIVITY HAS BOTH QUANTITATIVE AND QUALITATIVE INPUTS

- WE ARE KEENLY AWARE OF THE CONCERNS RAISED EXTERNAL TO LINE MANAGEMENT — THAT ACTIVITY IS QUANTITATIVE AND MONITORED
- WE ARE QUALITATIVELY AWARE OF SAFETY ISSUES BROUGHT TO AND RESOLVED BY LINE MANAGEMENT

II.I RESPONDING TO EMPLOYEE CONCERNS (CONT'D.)

EMPLOYEE CONCERNS ISSUES REMAIN A KEY AREA OF MANAGEMENT FOCUS

- AGGRESSIVE, COMPREHENSIVE ACTIONS HAVE BEEN AND ARE BEING TAKEN TO:
 - Resolve Current Issues
 - Develop a Climate, Culture, and Management Responsiveness and Attentiveness Conducive to Raising and Resolving all Concerns through Line Management

II.I RESPONDING TO EMPLOYEE CONCERNS (CONT'D.)

EMPLOYEE CONCERNS INVOLVEMENT BY MANAGEMENT IS HIGH

- NEEDS TO BE HIGH
 - Involves Matters Affecting Nuclear Safety
 - Management Involvement is Necessary to Learn Lessons and Achieve Desired Results
 - Can Lead to Very Significant Problems/Resource Burden if Not Well Handled at the Outset
 - Additional Resources Have Been and Will Be Made Available to Managers Who Need Them

II.I RESPONDING TO EMPLOYEE CONCERNS (CONT'D.)

WE CONTINUE TO TAKE ACTIONS TO IMPROVE OUR RESPONSIVENESS TO CONCERNS

- BUSINESS PLAN INITIATIVES
- ENHANCED COMMUNICATIONS
 - NSCP Director - Facilitated Case Studies: VP/Director Meetings and Peer Representatives
 - NSCP Director Involvement in Engineering Ethics Training
 - Communicating Appreciation for Those Who Raise Safety Concerns
 - Frequent Management Dialogue With Those Who Have Raised Safety Issues
- INDEPENDENT EVALUATION OF TECHNICAL ISSUES
 - Yankee Atomic
 - Jim Partlow
- SUPPORT MECHANISMS ARE BEING EXPLORED FOR SUPERVISORS
 - Enhanced Training
 - Supervisor's Handbook
 - Support Team

III. MAJOR LICENSING ISSUES

III.A SLCRS LONG-TERM SOLUTION

III.A SLCRS LONG-TERM SOLUTION

SLCRS/ABVS DESCRIPTION

- SLCRS
 - The operability of SLCRS ensures that radioactive material that leaks from the primary containment into the secondary containment boundary following a DBA is filtered and absorbed prior to any release to the environment
 - SLCRS is a redundant two train system with a common inlet and discharge duct system
 - Prior to recently approved Technical Specifications, SLCRS was required to achieve a negative pressure of 0.25 w/g in the secondary containment boundary within one minutes of DBA

- ABVS/ABFS
 - The system design basis role is twofold:
 - ABVS (which includes ABFS) provides cooling to vital equipment housed in the auxiliary building under normal and post-accident conditions
 - Augments the SLCRS in completing its enclosure and ancillary building vacuum drawdown design requirement
 - The ABVS is redundant in terms of active components, but lacks independence since failure of one train of equipment must be positively detected prior to startup of the standby train
 - System timing under worst case failure and postulated accident and loss-of-power conditions, suffers while a determination of operational status of each of the ABVS trains is automatically made.

III.A SLCRS LONG-TERM SOLUTION (CONT'D.)

- ABVS/ABFS (Cont'd.)
 - This is quite unlike conventional redundant equipment trains wherein both auto-start on accident and both run oblivious to the other's operational status
 - The net result is that the ABVS is complex and slow in response, in a role for which Technical Specifications require relatively rapid response
 - Additionally, the system becomes complex to analyze, introducing the requirement to go beyond normal means to thoroughly coordinate design features and devices
 - Positive means for one ABVS train to detect operation of the other, and vice versa, become cumbersome and introduces undesired time delays

III.A SLCRS LONG-TERM SOLUTION (CONT'D.)

• RECENT ACTIVITIES

- October/November 1993, NNECO implemented several design changes to resolve the design deficiencies and technical specification to increase drawdown time to allow greater system tolerances for design complexity
- Yankee Atomic Electric Company Independent Assessment and NU's own Task Force provided several recommendations to further enhance the system reliability

III.A SLCRS LONG-TERM SOLUTION (CONT'D.)

• SLCRS/ABVS ACTION PLAN

- Yankee Atomic and SLCRS Task Force recommendations include issues of both a hardware (system design) and software (preventive maintenance, surveillance testing, FMEA, training, etc.) nature
- Action Plan has been developed to resolve outstanding issues/recommendations using cost-effective and time-efficient approach
 - Due to high cost and low safety significance, major modifications are not planned and are not warranted
- Hardware Issues
 - Implementation of modifications identified in five engineering work requests (EWR) by the fifth refueling outage
 - Consolidation of four EWRs into a PA and implementation in the sixth refueling outage
 - ABVS FMEA to include additional factors
 - Develop ABVS/SLCRS detailed design description and walkdown
 - Restore containment leak rate allowance and increase SLCRS/ABFS drawdown time
- Software Issues
 - Ventilation air flow surveillance testing
 - Evaluate the adequacy of preventive maintenance for SLCRS/ABFS components
 - Training module will be developed to address test plan and test procedure development and test conduct and review of test results for design changes. This training module will be utilized for training design and system engineering personnel

III.A SLCRS LONG-TERM SOLUTION (CONT'D.)

- Regulatory and Analysis Options
 - Relax T.S. Action for Inoperable SLCRS/ABFS Based on PRA Justification
 - Pursue Exceptions to Standard Review Plan Using Radiological DBA LOCA Assumptions
 - Increase drawdown time before exfiltration must be assumed
 - No exfiltration for first minute
 - Less than 100% exfiltration
 - Reduced source-term for first few minutes
 - Reduced Technical Support Center occupancy for first 15 minutes
 - More effective containment sprayed/nonsprayed area mixing rate
 - Reanalyze DBA LOCA Using SRP Allowed Assumptions
 - Regain margin in containment leakage rate and maintain 2 minute drawdown
 - Longer Term Improvements
 - Staff approval of revised source term (NUREG-1465) and application to existing plants
 - Industry groups (NEI) working with NRC to reduce requirements marginal to safety

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1)

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1)

MILLSTONE UNIT NO. 1

SEP Topic VIII-1.A Potential Equipment Failures Associated with Degraded Grid Voltage

SEP Topic VIII-3.B DC Power System Bus Voltage Monitoring and Annunciation
(ISAP Topic 1.25)

Status • The NRC Staff by letter dated December 23, 1993, accepted the proposed modifications for the split-logic, loss of normal power detection scheme.

Action • NU - Submit proposed technical specification changes for degraded voltage settings in 1995.

• NU - Complete modifications during the Cycle 15 refueling outage in 1996.

• NRC- Provide closeout letter for these SEP topics.

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1) (CONT'D.)

MILLSTONE UNIT NO. 1

SEP Topic III-6 Seismic Design Considerations
(ISAP Topic
1.06)

- Status
- Safety-Related Piping Systems need to be upgraded for a Safe Shutdown Earthquake. The current approach would require substantial additional piping supports.
 - A new approach to demonstrate seismic adequacy using the IPEEE seismic margins methodology will be proposed.
 - Millstone Unit No. 1 will follow the same approach proposed for the Haddam Neck Plant and approved by the NRC Staff for Dresden 2 and 3.
 - NRC acceptance would greatly reduce the scope of the remaining modifications.
- Action
- NU - Submit letter requesting use of IPEEE seismic margins methodology to resolve this topic in 1994.
 - NU - Implement remaining pipe support modifications during the Cycle 15 refueling outage in 1996 assuming revised approach.
 - NRC-- Provide response accepting revised approach.

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1) (CONT'D.)

CONNECTICUT YANKEE

SEP Topic III-1
(ISAP Topic 1.09) Classification of Structural Components and Systems

Status • A submittal was provided on January 27, 1993. The NRC Staff has requested a comprehensive, detailed analysis of the information provided. This additional information was submitted on April 11, 1994

Action • NRC - Provide closeout letter for this SEP Topic.

SEP Topics III-2
and III-4.A
(ISAP Topic 1.06) Wind and Tornado Loadings Tornado Missiles

Status • The NRC SER was received on September 29, 1993.

• An air-cooled diesel has been purchased and will be installed during the Cycle 19 refueling outage in 1996.

• Also, MCC-5 modifications will be completed during the Cycle 18 refueling outage in 1995.

Action • NU - Complete modifications during the Cycle 19 refueling outage in 1996.

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1) (CONT'D.)

CONNECTICUT YANKEE

SEP: Topic III-6 Seismic Design Considerations
(ISAP Topics
1.04, 1.05)

- Status
- The remaining piping systems to be upgraded are service water, main steam and main feedwater, all outside of containment.
 - A new approach to demonstrating seismic adequacy using seismic margin methodology was submitted on July 9, 1993 and discussed in a meeting with the Staff on March 8, 1994.
 - A revised approach using IPEEE seismic margins methodology will be proposed as a result of recent discussion with the Staff.
 - The revised approach was approved by the NRC Staff for Dresden 2 and 3.
 - NRC acceptance would greatly reduce the scope of the remaining modifications.
- Action
- NU- Submit letter requesting use of IPEEE seismic margins methodology to resolve this topic in April 1994.
 - NU- Implement pipe support modifications during the Cycle 19 refueling outage in 1996 assuming revised approach.
 - NRC- Provide response accepting revised approach.

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1) (CONT'D.)

CONNECTICUT YANKEE

SEP Topic III-7.B Design Codes, Design Criteria, Load
(ISAP Topic 1.09) Combinations, and Reactor Cavity Design
Criteria

Status • A final submittal was provided to the NRC
Staff on January 19, 1993.

Action • NRC- Provide closeout letter for this SEP
topic.

SEP Topic V-11.A Requirements for Isolation of HPSI and LPSI
(ISAP Topic 1.02)

Status • Interlocks on the LPSI/Core Deluge Isolation
valves will be installed to prevent opening
of the valves until the RCS pressure is
reduced below a certain value.

Action • NU - The modifications will be implemented
during the Cycle 18 refueling outage in 1995.

III.B STATUS OF SEP TOPICS (CY & MILLSTONE 1) (CONT'D.)

CONNECTICUT YANKEE

SEP Topic VI-4 Containment Isolation System
(ISAP Topic 1.03)

- Status
- In a letter dated July 26, 1993, the NRC Staff concluded that all penetrations either meet the provisions of or the intent of the GDCs 54 through 57, except for P-39 and P-40 (containment purge and exhaust lines).
 - On November 29, 1993, CYAPCO transmitted to the Staff information on how penetration P-39 and P-40 would be protected via a second barrier.
 - Changes to the CY technical specifications have been developed to support the proposed modifications.
- Action
- NU -- The proposed technical specification changes for the containment purge and exhaust line are scheduled to be submitted in May 1994.
 - NU -- The modifications are scheduled to be implemented during the Cycle 18 refueling outage in 1995.
 - NRC -- Approve proposed technical specification changes to close this topic.

III.C CONTROL ROOM DESIGN REVIEW - HED STATUS -
MILLSTONE 1 & CY

III.C CONTROL ROOM DESIGN REVIEW

STATUS OF HUMAN ENGINEERING DISCREPANCIES (HEDs) FOR MILLSTONE
UNIT NO. 1

•	TOTAL NUMBER OF HEDs:	361
•	NUMBER OF HEDs DISPOSITIONED OR WILL BE DISPOSITIONED BY \geq 80% START OF CYCLE 15	248
•	REMAINING NUMBER OF HEDs TO BE DISPOSITIONED OR IMPLEMENTED BY END OF CYCLE 15	113

III.C CONTROL ROOM DESIGN REVIEW (CONT'D.)

STATUS OF PRIORITY 1 HUMAN ENGINEERING DISCREPANCIES (HEDs) FOR THE HADDAM NECK PLANT

- REMAINING HEDS TO BE RESOLVED DURING THE UPCOMING CYCLE 18 REFUELING OUTAGE:
 - Group 2 (Main Control Board) 25 HEDs
 - Group 13 (Control Board Relabeling) 72 HEDs
- ALL OTHER PRIORITY 1 HEDS (TOTAL = 351) HAVE BEEN DISPOSITIONED/RESOLVE DURING PREVIOUS REFUELING OUTAGES

III.D APPENDIX J MODIFICATIONS/CHANGES — MILLSTONE 1

III.E SPENT FUEL STORAGE CAPACITY AND FUTURE SPENT
FUEL STORAGE PLANS AT MILLSTONE UNITS AND CY

III.E SPENT FUEL STORAGE CAPACITY AND FUTURE SPENT
FUEL STORAGE PLANS AT MILLSTONE UNITS AND CY

OBJECTIVES

- PROVIDE FULL-CORE-DISCHARGE (FCD) CAPABILITY FOR EACH UNIT UNTIL THE END OF THE OPERATING LICENSES
- PROVIDE COST EFFECTIVE ON-SITE STORAGE UNTIL DOE REMOVES SPENT FUEL

STRATEGY

- PURSUE SOLUTIONS THAT MINIMIZE UP-FRONT INVESTMENT
- PURSUE SOLUTIONS THAT MINIMIZE REGULATORY APPROVALS
- MAINTAIN OPTIONS OPEN

III.E SPENT FUEL STORAGE CAPACITY AND FUTURE SPENT FUEL STORAGE PLANS AT MILLSTONE UNITS AND CY (CONT'D.)

SPENT FUEL POOL STORAGE REQUIREMENTS

UNIT	CURRENT* NO. OF ASSEMBLIES	CURRENT CAPACITY	PLANNED CELL ADDITIONS	CAPACITY SHORTFALL TO MEET EOL
MP1	2116	3229	227	-860**
MP2	784	1306	0	-549**
MP3	322	756	>1105	0
CY	816	1172	308	0

* AS OF DECEMBER 1993

** SHORTFALL CAN BE MET THROUGH MULTIPLE OPTIONS

III.E SPENT FUEL STORAGE CAPACITY AND FUTURE SPENT
FUEL STORAGE PLANS AT MILLSTONE UNITS AND CY (CONT'D.)

FUEL STORAGE REQUIREMENTS

	Loss of FCD Capability	DOE Removal Schedule Year of Allocation	Licensed Life to
MP1	2002	Year 1	2010
MP2	2002	Year 5	2015
MP3	1999*	Year 15 (est.)	2025
CY	2000*	Year 1	2007

* Full utilization of pool by installing additional racks will provide storage to end of life.

At the present time, the units are expected to lose FCD capability as indicated above. Also displayed is the first year DOE currently plans to remove fuel from each unit.

NU has evaluated multiple options to address fuel storage requirements, such as consolidation, on-site transfers, and dry cask storage.

III.E SPENT FUEL STORAGE CAPACITY AND FUTURE SPENT
FUEL STORAGE PLANS AT MILLSTONE UNITS AND CY (CONT'D.)

SUMMARY

- UTILIZE WET (IN POOL) STORAGE AT MP AND CY
- PARTIAL RERACK OF HADDAM NECK PLANT IN 1995-1996
- EVALUATE REMOVAL OF MP2, REGION B CELL BLOCKERS IN 1995
- ADD RACK MODULES TO MP1 IN 1997
- RERACK MP3 IN 1998
- EVALUATE ECONOMICS OF ALTERNATIVES FOR MP1 AND MP2
TRANSFERS/CONSOLIDATION/DRY STORAGE/NEW TECHNOLOGIES
- ASSESS DOE ABILITY TO PERFORM
- IMPLEMENT THE MOST ECONOMIC ALTERNATIVE
- NRC APPROVAL REQUIRED FOR IMPLEMENTATION

IV. REGULATORY INTERFACE ISSUES

IV.A NRC/NU COMMUNICATION - GENERAL DISCUSSION

IV.B NRC INSPECTION SCHEDULE

IV.C ISAP LICENSE CONDITIONS

IV.C ISAP LICENSE CONDITIONS

- ISAP BEGAN AT HADDAM NECK AND MILLSTONE 1 IN 1985
- LICENSE CONDITIONS INITIALLY PREPARED IN 1988
- SUPPLEMENTAL INFORMATION PROVIDED IN DECEMBER 1991
- LICENSE CONDITIONS ISSUED FEBRUARY 1992 FOR THE HADDAM NECK PLANT AND MILLSTONE 1 - EFFECTIVE FOR THREE YEARS (EXPIRE FEBRUARY 1995)
- NU CURRENTLY PROVIDING APPROXIMATELY SEMIANNUAL UPDATE REPORTS
- ISAP CONTINUES TO BE BENEFICIAL TOOL
 - Several ISAP success stories - Examples:
 - Millstone 1 Hydrogen Monitoring
 - Haddam Neck Plant Tornado Missile Protection Modifications
 - Haddam Neck Plant Containment Isolation Valves
- PLANS ARE TO REQUEST HADDAM NECK PLANT AND MILLSTONE 1 LICENSE CONDITIONS REMAIN IN EFFECT
 - License Amendment Requests Would Be Submitted in mid-1994
- CURRENT EXPECTATIONS CONTINUE TO BE THAT ISAP WILL BE IMPLEMENTED ON MILLSTONE 2 AND 3
- ISAP BEING REVIEWED AS PART OF ONGOING PROJECT PRIORITIZATION RE-ENGINEERING EFFORT

V. GENERAL LICENSING TOPICS

V.A IMPLEMENTATION OF LINE-ITEM
TECHNICAL SPECIFICATION IMPROVEMENTS

Status of Generic Letters That Recommend
Specific Technical Specification Changes

Generic Letter (GL) Number/Date	Description	Millstone 1	Millstone 2	Millstone 3	Haddam Neck Plant
GL 93-08 12/29/93	Relocation of Technical Specifications Tables of Instrument Response Time Limits.	Under Review	Under Review	Under Review	Under Review
GL 93-07 12/28/93	Modification of the Technical Specifications Administrative Control Requirements for Emergency and Security Plans.	Under Review	Under Review	Under Review	Under Review
GL 93-05 9/27/93	Line Item Technical Specifications Improvements to Reduce SR for Testing During Power Operation.	Under Review	Under Review	Under Review	Under Review
GL 91-13 9/19/91	Request for Information Related to the Resolution of Generic Issue 130, "Essential Service Water System Failures at Multi-unit sites," pursuant to IOCFR50.54(f).	Not Applicable	Not Applicable	Not Applicable	Not Applicable
GL 91-09 6/27/91	Modification of Surveillance Interval for the Electrical Protective Assemblies in Power Suppliers for the Reactor Protection System.	Under Review	Not Applicable	Not Applicable	Not Applicable
GL 91-08	Removal of Component Lists from Technical Specifications.	Under Review	Under Review	Implemented	Partially Implemented

Page 92

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Generic Letter (GL) Number/Date	Description	Millstone 1	Millstone 2	Millstone 3	Haddam Neck Plant
GL 91-04 4/2/91	Changes in Technical Specification Surveillance Intervals to Accommodate a 24-month fuel cycle.	No Plans to Implement ⁽¹⁾	Under Review	Under Review	Under Review
GL 91-01 3/3/91	Reactor Vessel Surveillance Capsule.	No Plans to Implement	Under Review	Under Review	Implemented
GL 90-09 12/11/90	Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions.	Implemented	Implemented	Implemented	Implemented
GL 90-06	Resolution of Generic Issue 70, "Power-Operated Relief Valves Reliability," and Generic Letter 94, "Additional Low-Temperature Overpressure Protection for Light Water Reactors," pursuant to 10CFR50.54(f).	Not Applicable	Under review	Implemented	Implemented
GL 90-02 02/01/90	Alternative Requirements for Fuel Assemblies in the Design Features Section of Technical Specifications.	No Plans to Implement	Under Review	Implemented	Partially Implemented

(1) For Millstone Unit 1 NNECO has implemented the 24 month fuel cycle prior to the issuance of Generic Letter 91-04. However, the surveillance extension for snubbers has been implemented.

Generic Letter (GL) Number/Date	Description	Millstone 1	Millstone 2	Millstone 3	Haddam Neck Plant
GL 89-14 8/21/89	Line Item Improvements in Technical Specifications—removal of the 3.25 Limit on Extending Surveillance Intervals.	Implemented	Implemented	Implemented	Implemented
GL 89-01 01/31/89	Implementation of Programmatic Controls for Radiological Effluent Technical Specifications in the Administrative Control Section of the Technical Specification and the Relocation of Procedural Details of RETs to the Offsite Dose Calculations Manual or to the Process of Control Program.	Partially Implemented	Partially Implemented	Partially Implemented	Partially Implemented
GL 88-16 10/04/88	Removal of Cycle-Specific Parameter Limits from Technical Specification.	Implemented	Implemented	Implemented	Implemented
GL 88-06 03/22/88	Removal of Organization Charts from Technical Specification Administrative Control Requirements.	Implemented	Implemented	Implemented	Implemented
GL 87-09 06/04/87	Sections 3.0 and 4.0 of the Standard Technical Specification on the applicability of LCO and Surveillance Requirements.	No Plans to Implement	Implemented	Implemented	Implemented

Generic Letter (GL) Number/Date	Description	Millstone 1	Millstone 2	Millstone 3	Haddam Neck Plant
GL 86-10 4/24/86 and GL 88-12 8/2/88	Implementation of Fire Protection Requirements.	Implemented	Under Review	Implemented	Under Review with NRC
GL 85-09 05/23/85	Technical Specification for GL 83-28, Item 4.3, for Westinghouse Plants.	Not Applicable	Not Applicable	Implemented in the Original Technical Specifications	Implemented
GL 84-15 07/02/84	Proposed Staff Action to Improve and Maintain Diesel Generator Reliability.	Resolved via 2/4/85 Letter to NRC	Resolved via 2/4/85 Letter to NRC	Implemented in the Original Technical Specification and Further Modified via Amendment 64 (3/9/92)	Implemented
GL84-13 5/3/84	Technical Specification for Snubbers	Implemented	Implemented	Implemented in the Original Technical Specifications	Implemented in the Reformatted Technical Specifications
GL 83-36 11/01/83 or GL 83-37 11/1/83	NUREG-0737 Technical Specifications.	Implemented	Implemented	Implemented in the Original Technical Specifications	Implemented
GL 83-28 Supp. 1 10/7/92	Required Actions Based on Generic Implications of Salem ATWS Events.	Not Applicable	Not Applicable	Resolved	Not Applicable

V.B PLANT SPECIFIC ISSUES

V.B PLANT SPECIFIC ISSUES

MILLSTONE UNIT NO. 1

INITIATIVES RECENTLY SUBMITTED

- APPENDIX J – PROPOSED RESOLUTION OF LLRTs
- RESPONSE TO BULLETIN 93-02, SUPPLEMENT 1
- ISAP UPDATE REPORT

UPCOMING INITIATIVES

- ISI REPORT (OUTAGE)
- ILRT REPORT (OUTAGE)
- ISAP UPDATE REPORT (ITEMS COMPLETED DURING OUTAGE)
- SHIFT CREW COMPOSITION – 3RD RO LICENSE AMENDMENT REQUEST
- VERIFICATION OF COMPLETION OF COMBUSTIBLE GAS CONTROL MODIFICATIONS
- LPCI/ESW ΔP ISSUE

LONG-TERM INITIATIVES

- PROPOSED LICENSE AMENDMENT – SINGLE LOOP OPERATION
- REMOVAL OF COMPONENT LISTS FROM TECHNICAL SPECIFICATIONS
GL 91-08

AWAITING NRC ACTION

- ASME SECTION XI RELIEF REQUEST

V.B PLANT SPECIFIC ISSUES (CONT'D.)

MILLSTONE UNIT NO. 2

INITIATIVES RECENTLY SUBMITTED

- PROPOSED LICENSE AMENDMENTS
 - 18-Month Surveillances, One-Time Extension
 - Charcoal Filter Testing

UPCOMING INITIATIVES

- PROPOSED LICENSE AMENDMENT ESAS
- PROPOSED LICENSE AMENDMENT BATTERY CHARGER REPLACEMENT
- PROPOSED LICENSE AMENDMENT GL 90-06, BORON DILUTION, SD RISK
- PROPOSED LICENSE AMENDMENT FEEDWATER ISOLATION COMPONENTS
- PROPOSED LICENSE AMENDMENT REMOTE SHUTDOWN PANEL METER
- PROPOSED LICENSE AMENDMENT FOR METEOROLOGICAL DATA COLLECTION/SWPP COLLECTION
- PROPOSED LICENSE AMENDMENT FOR SFP AREA ACCESS
- 24-MONTH FUEL CYCLE

LONG-TERM INITIATIVES

- ISAP IMPLEMENTATION/IPE IMPLEMENTATION
- REMOVAL OF CONTAINMENT ISOLATION VALVES FROM TECHNICAL SPECIFICATION

AWAITING NRC ACTION

- CHARCOAL FILTER TESTING LICENSE AMENDMENT

V.B PLANT SPECIFIC ISSUES (CONT'D.)

MILLSTONE UNIT NO. 3

INITIATIVES RECENTLY SUBMITTED

- PROPOSED LICENSE AMENDMENTS
 - AC/DC Onsite Power Distribution System - Shutdown
 - EDG Fuel Oil Capacity
 - Reactor Coolant System - Flow Rate
 - Main Steam Safety and Pressurizer Safety Valves - Lift Settings
 - MSV Building Area Temperature

UPCOMING INITIATIVES

- Relaxation of the SLCRS Vacuum Drawdown Requirement and Regain the Margin Related to Containment Leak Rate
- Relocate Response Time for RPS and ESFAS from Technical Specification to Technical Requirements Manual - GL 93-08
- Technical Specification Improvement per GL 93-05
- 24 - Month Fuel Cycle

LONG-TERM INITIATIVES

- ISAP Submittal and License Condition
- Line Item Improvements Consistent with NUREG-1431

AWAITING NRC ACTION

NONE

V.B PLANT SPECIFIC ISSUES (CONT'D.)

HADDAM NECK PLANT

INITIATIVES RECENTLY SUBMITTED

- PROPOSED LICENSE AMENDMENTS
 - Pressure/Temperature Limits
 - RCP Pump Flywheel
 - Spent Fuel Pool and New Fuel Storage Modifications
 - Physics Methodology for PWR Reload Design
- UPDATE ON THE PROPOSED MODIFICATIONS TO THE AFW SYSTEM
- ISAP UPDATE
- PROPOSED RESOLUTION OF SEPT TOPIC III-1, "CLASSIFICATION OF STRUCTURAL COMPONENTS AND SYSTEMS"
- PROPOSED RESOLUTION OF SEP II-6, "SEISMIC DESIGN CONSIDERATIONS"

V.B PLANT SPECIFIC ISSUES (CONT'D.)

HADDAM NECK (Cont'd.)

UPCOMING INITIATIVES

- RESOLUTION OF CONTROL ROOM DESIGN REVIEW; PRIORITY 1 HUMAN ENGINEERING DISCREPANCIES
- PROPOSED LICENSE AMENDMENT - CYCLE 18 RELATED REFUELING OUTAGE
- PROPOSED LICENSE AMENDMENT - 24-MONTH FUEL CYCLE

LONG-TERM INITIATIVES

- AFW SYSTEM UPGRADINGS - ELECTRIC-DRIVEN PUMP
- CORE-MELT FREQUENCY REDUCTION EFFORTS EVALUATION
- CLOSEOUT OF LONG-STANDING SEP AND TMI TOPICS
- IPE EFFORTS

AWAITING NRC ACTION

- RESOLUTION OF PENDING SEP TOPIC FOR WHICH CLOSURE HAS BEEN PROPOSED

V.C STATUS OF USI, TMI ITEMS, SEP ITEMS, GSIs

V.C STATUS OF USI, TMI ITEMS, SEP ITEMS GSIs

USIs--Open ItemsHaddam Neck Plant

USI	Title	Action By	Remarks
A-31	RHR Shutdown Requirement	NU	Issue addressed under ISAP Topic 1.02
A-40	Seismic Design Criteria	-	Issue addressed under ISAP Topic 1.04
A-44	Station Blackout	NU	NRC issued supplemental SER on June 17, 1992. Station Blackout Program has been implemented.
A-46	Seismic Qualification of Equipment in Operating Plants	NU	Final walkdowns performed during the 1993 refueling outage. A report has been submitted to the NRC Staff.

Millstone 1

USI	Title	Action By	Remarks
A-1	Water Hammer	NRC	Topic addressed under ISAP Topic 1.43. Topic closed. Awaiting NRC Staff response.
A-40	Seismic Design Criteria	NU	Being addressed as part of ISAP Topic 1.06

V.C STATUS OF USI, TMI ITEMS, SEP ITEMS GSIs (CONT'D.)

USI	Title	Action By	Remarks
A-44	Station Blackout	NU	NRC-issued SER; implementation during the current refueling outage. Discussed as part of ISAP Topic 1.106
A-46	Seismic Qualification of Equipment in Operating Plants	NU	Being pursued via SQUG methodology; work currently scheduled to commence 5/93
A-47	Safety Implications of Control Systems	NRC	Licensee response under staff review
A-48	Hydrogen Control	NU	NRC issued SER in August 1993. Implementation being completed during current refueling outage.

Millstone 2

USI	Title	Action By	Remarks
A-44	Station Blackout	-	NRC-issued SER; implemented by 1994 refueling outage
A-46	Seismic Qualification of Equipment in Operating Plants	NU	Being pursued via SQUG methodology; work currently scheduled to commence 7/93
A-47	Safety Implication of Control Systems	NRC	Licensee position under staff review

V.C STATUS OF USI, TMI ITEMS, SEP ITEMS GSIS (CONT'D.)

Millstone 3

USI	Title	Action By	Remarks
A-44	Station Blackout	-	NRC-issued SER; implemented during the fourth refueling outage
A-47	Safety Implication of Control Systems	NRC	Licensee position under staff review

TMI Action Items--Open Items

		Action By	Status
HADDAM NECK			
I.D.1	Control Room Design Review	NU	Open
MILLSTONE 1			
I.D.1.2	Detailed CRDR	NU	Open
MILLSTONE 2			
I.D.1.2	Detailed CRDR	-	Closed
MILLSTONE 3			
None			

STATUS OF CY SEP OPEN ITEMS

February 1994

SEP TOPIC	TITLE	PLANS	IMPLEMENTATION SCHEDULE	TECHNICAL LEADS
III-2 & III-4.A	Wind and Tornado Loadings Tornado Missiles (PRA Significant) ISAP Topic 1.08	An air-cooled diesel will be installed during the Cycle 19 refueling outage. Also, MCC-5 separation modifications will be completed during the Cycle 18 refueling outage. A submittal discussing the proposed modifications and schedule was provided on June 30, 1993. Additional information was provided on August 23, and September 14, 1993. The NRC SER was received on September 29, 1993.	1998 (Cycle 19 Outage)	R. J. Palmieri, C. J. Gladding
VI-4	Containment Isolation System (Not PRA Significant) ISAP Topic 1.03	In a letter dated July 26, 1993, the NRC Staff concluded that all penetrations either meet the provisions of or the intent of the GDCs 54 through 57, except for P-39 and P-40 (containment purge and exhaust line). On November 29, 1993, CYAPCO transmitted to the Staff information on how penetration P-39 and P-40 would be protected via a second barrier. The modifications to these barriers will be implemented during the Cycle 18 refueling outage. Changes to the CY technical specifications will be developed to support the proposed modifications. Currently, a letter to the Staff is scheduled to be submitted in February 1994 which will address the two remaining confirmatory items from the NRC SER of July 26, 1993. The two issues to be addressed are (1) verify that all automatic isolation valves take the position of greatest safety upon the loss of power; and (2) for those valves that do not receive an automatic closure signal, describe the administrative controls that assure the valves are locked closed, or procedurally controlled during use.	Cycle 18 outage, late 1994.	C. J. Gladding, R. M. Kacich R. J. Palmieri
III-1	Classification of Structural Components and Systems (Not PRA Significant) ISAP Topic 1.009	A submittal was provided on January 27, 1993. The NRC Staff has informally requested a comprehensive, detailed analysis of the information provided in January 1993. This additional information is scheduled to be submitted in February 1994.	1994 Pending NRC action.	M. Kupinski, R. M. Kacich

STATUS OF CY SEP OPEN ITEMS (cont'd.)

February 1994

SEP TOPIC	TITLE	PLANS	IMPLEMENTATION SCHEDULE	TECHNICAL LEADS
III-8	Seismic Design Considerations (Small PRA Benefit) ISAP Topics 1.04, 1.05	The remaining piping systems to be upgraded are service water, main steam and main feedwater, all outside of containment. A new approach to demonstrating seismic adequacy using seismic margin methodology was submitted on July 9, 1993. NRC acceptance would dramatically reduce the scope of the remaining modifications. A meeting with the NRC Staff is planned for March 1994. A supplemental safety evaluation from the NRC Staff was received on January 6, 1994. Via this letter, the Staff concluded that the analysis and design of the new switchgear building is adequate and that the open issues related to the pipe gallery structure, auxiliary feedwater pumphouse and the PAB have been resolved.	1996 (Cycle 19 Outage) for Pipe Supports	M. Kupinski, G. J. Gladding, R. M. Kacich
V-11.A	Requirements for isolation of HPSI and LPSI (PRA Significant) ISAP Topic 1.02	Interlocks on the LPSI/Core Deluge Isolation valves will be installed during the Cycle 18 refueling outage. The interlocks will prevent opening of the valves until the RCS pressure is reduced below a certain value.	Cycle 18 Outage, late 1994.	G. J. Gladding
III-7.B	Design Codes, Design Criteria, Load Combinations, and Reactor Cavity Design Criteria ISAP Topic 1.09	Final submittal provided on January 19, 1993. No action needed by NU at this time. An NRC SER expected in July 1994.	1994 Pending NRC approval.	M. Kupinski, R. M. Kacich

Page 107

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

MILLSTONE UNIT NO. 1
SEP STATUS

NRC/NU COUNTERPARTS MEETING

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
II-3.B, II-3.B.1, II-3.C (1.19)	Flooding Elevation; Intake Structure; Local Flooding; Gas Turbine Building; Diesel Fuel Oil; Emergency Procedures	Closed		SER from NRC dated from January 4, 1990.
II.4.F (1.19)	Turbine Building; Gas Turbine Generator Building; Buried Pipelines	Closed		M. L. Boyle letter to E. J. Mroczka, January 4, 1990.
III-1 (1.15)	Radiography Requirements Fracture Toughness; Valves; Pumps; Storage Tanks	Closed		Submittal of UFSAR on March 27, 1987. Draft NUREG-1184, dated April 2, 1987.
III-2 (1.19)	Wind and Tornado Loadings	Closed		SER from NRC dated November 11, 1985.
III-3.A (1.19)	Flood Elevation; Groundwater	Closed		SER from NRC dated January 4, 1990.
III-3.C (1.15)	Structures and Components Requiring Inspection and Inspection Program	Closed		Submittal of UFSAR in March of 1987. ISAP submittal dated November 9, 1988. Draft NUREG-1184, dated April 2, 1987.

APRIL 21, 1994

MILLSTONE UNIT NO. 1
SEP STATUS

NRC/NU COUNTERPARTS MEETING

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
III-4.A (1.02)	Tornado Missiles	Closed		SER from NRC dated December 19, 1991.
III-4.B	Turbine Missiles	Closed		SER from NRC dated December 23, 1991.
III-4.C	Internally Generated Missiles	Closed		IPSAR, Section 3.1.
III-5.A	Cascading Pipe Breaks; Jet Impingement, and Pipe Whip	Closed		IPSAR Supplement Section 2.7.
III-5.B	Moderate-Energy Piping, Jet Impingement, and Unisolable Breaks	Closed		SER from NRC on June 29, 1983 and IPSAR Section 2.8.
III-6 (1.19 and 1.06)	Seismic Design Considerations review of submitted information	Closed		SER from NRC on September 4, 1991.
III-7.B (1.19)	Design Codes, Design Criteria, Load Combinations and Reactor Cavity Design Criteria	Closed		M. L. Boyle letter to E. J. Mroczka, dated January 4, 1990.
III-8.A	Loose-Parts Monitoring and Core Barrel Vibration Monitoring	Closed		Issue deleted March 3, 1982.

Page 109

APRIL 21, 1994

MILLSTONE UNIT NO. 1
SEP STATUS

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
III-10.A	Thermal-Overload Protection for Motors of Motor-Operated Valves	Closed		SER from NRC September 16, 1985. IPSAR Supplement Section 2.11.
IV-2	Reactivity Control Systems	Closed		Amendment #97 to License
V-5	Reactor Coolant Pressure Boundary Leakage Detection	Closed		Amendment #97 to License
V-6	Reactor Vessel Integrity	Closed		D. M. Crutchfield letter to W. G. Council, August 28, 1982.
V.10.A	Residual Heat Removal System Heat Exchanger Tube Failure	Closed		IPSAR, Section 3.1.
V-10.B	Residual Heat Removal System Reliability	Closed		IPSAR Supplement Section 4.
V-11.A (1.04)	Requirements for Isolation of High- and Low-Pressure Systems	Closed		Draft NUREG-1184, dated April 2, 1987.
V-11.B	RHR System Interlock Requirements	Closed		IPSAR, Section 3.1
V-12.A	Water Chemistry Limits	Closed		Amendment #99 to License

MILLSTONE UNIT NO. 1
SEP STATUS

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
VI-1	Organic Materials and Post Accident Chemistry	Closed		J. Shea to W. G. Council February 26, 1982.
VI-4 (1.03)	Containment Isolation	Closed		SER from the Staff on July 7, 1983.
VI-7.A.3	ECCS Actuation System	Closed		SER from the Staff dated July 5, 1983.
VI-7.A.4	Core Spray Nozzle Effectiveness	Closed		IPSAR Section 4.22.
VI-7.C.1 (1.21)	Redundant Onsite Power Systems	Closed		ISAP submittal dated November 9, 1988. NRC SER dated September 3, 1991.
VI-10.A (1.22)	Testing of RTS and ESF	Closed		IPSAR Supplement, Section 4.
VII-1.A	Isolation Devices Between Reactor Protection System (RPS) and Monitoring Systems	Closed		NRC SER dated September 3, 1991.
VII-3	Systems Required for Safe Shutdown	Closed		IPSAR Section 4.2.6.

Page III

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

MILLSTONE UNIT NO. 1
SEP STATUS

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
VIII-1.A (1.25)	Potential Equipment Failures Associated with Degraded Grid Voltage	Open	Work was completed during 1989 Refueling Outage (TAC #50207). By letter dated 7/20/90, NNECO responded to Staff's 5/31/89 letter which identified new concerns with the Loss of Normal Power (LNP) logic. Independent of Staff's new concern, NNECO considers this specific issue resolved. NRC closeout required. NNECO provided additional information relating to the Millstone Unit No. 1 LNP logic in a letter dated 10/30/90. By letter dated, 11/27/91, NNECO responded to Staff's SER regarding compliance with GDC 17. Additional information submitted in letters dated 12/20/91, 4/27/92 and 11/30/92. NRC letter dated 12/28/93 accepted NNECO's proposed resolution. ISAP Topic 1.122 initiated. Mod scheduled for Cycle 15 RFO.	
VIII-2 (1.22)	Onsite Emergency Power Systems	Closed		SER from NRC, dated August 16, 1984. ISAP submittal dated September 29, 1989. NRC SER dated July 17, 1991.
VIII-3.A	Station Battery Test Requirements	Closed		Amendment #99 to License.

MILLSTONE UNIT NO. 1
SEP STATUS

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
VIII-3.B (1.25)	D. C. Power System Bus Voltage Monitoring and Annuciation; Battery Status Alarms and Indications	Closed	NRC letter dated April 14, 1993 closing ISAP Topic 1.25.	
IX-3	Station Service and Cooling Water Systems	Closed		IPSAR Section 4.31.
IX-5 (1.05)	Ventilation Systems	Closed		SER from the Staff on September 14, 1982.
XV-1	Decrease in Feedwater Temperature, Increase in Flow, Increase in Steam Flow, and Inadvertent Opening of a Steam Generator Relief or Safety Valve.	Closed		SER from NRC dated December 31, 1981.
XV-3	Loss of External Load Turbine Trip, Loss of Condenser Vacuum, Closure of Main Steam Isolation Valve (BWR), and Steam Pressure Regulator Failures (Closed)	Closed		IPSAR, Section 4.34.

MILLSTONE UNIT NO. 1
SEP STATUS

NRC/NU COUNTERPARTS MEETING

SEP Topic No. (ISAP No.)	Title	Status	Comments	Closure Document
XV-7	Reactor Coolant Pump Rotor Seizure and Shaft Break	Closed		D. M. Crutchfield to W. G. Council, December 4, 1981. IPSAR, Section 3.1.
XV-16	Radiological Consequences of Failure of Small Lines Carrying Primary Coolant Outside Containment.	Closed		Amendment #99 to license and NRC SER June 21 1984.
XV-18	Radiological Consequences of a Main Steam Line Failure Outside Containment	Closed		Amendment #99 to license and NRC SER June 21, 1984.
XV-19	LOCAs Resulting From Spectrum of Postulated Pipe Breaks Within RCPB	Closed		IPSAR, Section 3.1

SUMMARY:

Total Open SEP Topics: 2
Awaiting NRC closure: 2

Page 114

APRIL 21, 1994

FACILITY NAME: Haddam Neck Plant
 DOCKET NO.: 50-213
 LICENSEE: Connecticut Yankee Atomic Power Company

STATUS OF LICENSEE IMPLEMENTATION OF GENERIC SAFETY ISSUES
 RESOLVED WITH IMPOSITION OF REQUIREMENTS OR CORRECTIVE ACTIONS

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
40 (B065)	Safety Concerns Associated With Pipe Breaks in the BWR Scram System	All BWRs	N/A	--
41 (B058)	BWR Scram Discharge Volume Systems	All BWRs	N/A	--
43 (B107)	Reliability of Air Systems	All Plants	C	AFW modifications in Cycle 16 refueling outage completed.
51 (L913)	Improving the Reliability of Open-Cycle Service Water Systems	All Plants	C	ISAP Topic 1.120, see CYAPCO submittal dated 8/4/92.
67.3.3 (A017)	Improved Accident Monitoring	All Plants	C	ISAP Topic 1.21, see CYAPCO submittal dated 3/30/94
75 (B076)	Item 1.1--Post-Trip Review (Program Description and Procedure)	All Plants	C	Closed by NRC SER dated 3/20/85.
75 (B085)	Item 1.2--Post-Trip Review--Data and Information Capability	All Plants	C	Closed by NRC SER dated 7/3/85.
75 (B077)	Item 2.1--Equipment Classification and Vendor Interface (Reactor Trip System Components)	All Plants	C	Closed by NRC SERs dated 8/15/86 and 4/22/87.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B086)	Item 2.2.1--Equipment Classification for Safety-Related Components	All Plants	C	Closed by ISAP Topic 1.36, submittal dated 4/30/90.
75 (L003)	Items 2.2.2--Vendor Interface for Safety-Related Components	All Plants	C	ISAP Topic 1.36 and NRC SER dated 5/27/87. NNECO addressed open issues in response to GL 90-03, dated 4/19/91. Closed by NRC letter dated May 3, 1991.
75 (B078)	Items 3.1.1 & 3.1.2--Post-Maintenance Testing (Reactor Trip System Components)	All Plants	C	Closed by NRC SER dated 2/21/86.
75 (B079)	Item 3.1.3--Post-Maintenance Testing--Changes to Test Requirements (Reactor Trip System Components)	All Plants	C	Closed by NRC SER dated 10/16/85.
75 (B087)	Items 3.2.1 & 3.2.2--Post-Maintenance Testing (All Other Safety-Related Components)	All Plants	C	Closed by NRC SER dated 2/21/86.
75 (B088)	Item 3.2.3--Post-Maintenance Testing--Changes to Test Requirements (All Other Safety-Related Components)	All Plants	C	Closed by NRC SER dated 10/16/85.
75 (B080)	Item 4.1--Reactor Trip System Reliability (Vendor-Related Modifications)	All Plants	C	Closed by NRC SER dated 2/21/86.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B081)	Items 4.2.1 & 4.2.2--Reactor Trip System Reliability--Maintenance and Testing (Preventative Maintenance and Surveillance Program for Reactor Trip Breakers)	All PWRs	C	Closed by NRC SER dated 7/1/85.
75 (B082)	Item 4.3--Reactor Trip System Reliability--Design Modifications (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All W and B&W Plants	C	Closed by NRC SER dated 4/26/90.
75 (B090)	Item 4.3--Reactor Trip System Reliability--Tech Spec Changes (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All W and B&W Plants	C	Closed by NRC SER dated 4/26/90.
75 (B091)	Item 4.4--Reactor Trip System Reliability (Improvements in Maintenance and Test Procedures for B&W Plants)	All B&W Plants	N/A	--
75 (B092)	Item 4.5.1--Reactor Trip System Reliability--Diverse Trip Features (System Functional Testing)	All Plants	C	Closed by NRC SER dated 2/21/86.
75 (B093)	Items 4.5.2 & 4.5.3--Reactor Trip System Reliability--Test Alternatives and Intervals (System Functional Testing)	All Plants	C	Closed by NRC letter dated 6/20/89.
86 (B084)	Long Range Plan for Dealing With Stress Corrosion Cracking in BWR Piping	All BWRs	N/A	--

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Page 117

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
93 (B098)	Steam Binding of Auxiliary Feed-water Pumps	All PWRs	C	Closed by ISAP Topic 1.58 submittal dated 3/2/89.
99 (L817)	RCS/RHR Suction Line Valve Interlock on PWRs	All PWRs	I (1994)	Plant modification planned for Cycle 18 refueling outage.
124	Auxiliary Feedwater System Reliability	ANO-1&2, Rancho Seco, Prairie Island 1&2, Crystal River-3 Ft. Calhoun	N/A	--
A-13 (B017)	Snubber Operability Assurance-- Hydraulic Snubbers	All Plants	C	Closed by ISAP Topic 1.24, NRC letter dated 8/18/87.
A-13 (B022)	Snubber Operability Assurance-- Mechanical Snubbers	All Plants	C	Closed by ISAP Topic 1.25, NRC letter dated 8/18/87.
A-16 (D012)	Steam Effects on BWR Core Spray Distribution	Oyster Creek & NMP-1	N/A	--
A-35 (B023)	Adequacy of Offsite Power Systems	All Plants	C	Closed by NRC SER dated 4/26/90.
B-10	Behavior of BWR Mark III Contain- ments	All BWR Mark III Plants	N/A	--

Page 118

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
B-36	Develop Design, Testing and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Features Systems and for Normal Ventilation Systems	All Plants With OL Applications After 04/01/80	N/A	--
B-63 (B045)	Isolation of Low Pressure Systems Connected to the Reactor Coolant System Pressure Boundary	All Plants	I (1994)	Plant modification planned for Cycle 18 refueling outage.

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Page 119

FACILITY NAME: Millstone Nuclear Power Station, Unit No. 1
 DOCKET NO.: 50-245
 LICENSEE: Northeast Nuclear Energy Company

STATUS OF LICENSEE IMPLEMENTATION OF GENERIC SAFETY ISSUES
 RESOLVED WITH IMPOSITION OF REQUIREMENTS OR CORRECTIVE ACTIONS

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
40 (B065)	Safety Concerns Associated With Pipe Breaks in the BWR Scram System	All BWRs	C	Addressed under ISAP Topic 1.29. Closed by NRC in NUREG-1184.
41 (B058)	BWR Scram Discharge Volume Systems	All BWRs	C	License Amendment #86, dated 11/12/82.
43 (B107)	Reliability of Air Systems	All Plants	C	NNECO submittals dated 5/4/90, 6/11/90, and NRC letter dated 10/15/91.
51 (L913)	Improving the Reliability of Open-Cycle Service Water Systems	All Plants	I (5/94)	Addressed Under ISAP Topic 1.112. NNECO submittals dated 1/25/90, 6/1/90, 4/3/92 and 3/23/94.
67.3.3 (A017)	Improved Accident Monitoring	All Plants	C	NRC issued SER in December which concluded that NNECO is in compliance with RG 1.97. Remaining Items to be addressed under ISAP Topic 1.09.

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Page 120

75 (B076)	Item 1.1--Post-Trip Review (Program Description and Procedure)	All Plants	C	Closed by NRC SER dated 4/5/85.
75 (B085)	Item 1.2--Post-Trip Review--Data and Information Capability	All Plants	C	Addressed under ISAP Topic 1.30. Closed by NRC SER dated 6/24/86.
75 (B077)	Item 2.1--Equipment Classification and Vendor Interface (Reactor Trip System Components)	All Plants	C	Addressed Under ISAP Topic 1.26. Closed by NRC SERs dated 11/24/86 and 8/4/87.
75 (B086)	Item 2.2.1--Equipment Classification for Safety-Related Components	All Plants	C	Addressed Under ISAP Topic 1.31. Closed by NRC SER dated 10/31/88.
75 (L003)	Items 2.2.2--Vendor Interface for Safety-Related Components	All Plants	C	Addressed under ISAP Topic 1.31. NRC SER dated 6/2/87. NNECO addressed open issues in response to GL 90-03, dated 4/19/91. Closed by NRC letter dated May 3, 1991.
75 (B078)	Items 3.1.1 & 3.1.2--Post-Maintenance Testing (Reactor Trip System Components)	All Plants	C	Addressed under ISAP Topic 1.27. Closed by NRC SER dated 2/21/86.
75 (B079)	Item 3.1.3--Post-Maintenance Testing--Changes to Test Requirements (Reactor Trip System Components)	All Plants	C	Addressed under ISAP Topic 1.28. Closed by NRC SER dated 9/3/85.
75 (B087)	Items 3.2.1 & 3.2.2--Post-Maintenance Testing (All Other Safety-Related Components)	All Plants	C	Addressed Under ISAP Topic 1.32. Closed by NRC SER dated 2/21/86.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B088)	Item 3.2.3--Post-Maintenance Testing--Changes to Test Requirements (All Other Safety-Related Components)	All Plants	C	Addressed Under ISAP Topic 1.33. Closed by NRC SER dated 9/3/85.
75 (B080)	Item 4.1--Reactor Trip System Reliability (Vendor-Related Modifications)	All Plants	C	Closed by NRC SER dated 2/21/86.
75 (B081)	Items 4.2.1 & 4.2.2--Reactor Trip System Reliability--Maintenance and Testing (Preventative Maintenance and Surveillance Program for Reactor Trip Breakers)	All PWRs	N/A	--
75 (B082)	Item 4.3--Reactor Trip System Reliability--Design Modifications (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All W and B&W Plants	N/A	--
75 (B090)	Item 4.3--Reactor Trip System Reliability--Tech Spec Changes (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All W and B&W Plants	N/A	--
75 (B091)	Item 4.4--Reactor Trip System Reliability (Improvements in Maintenance and Test Procedures for B&W Plants)	All B&W Plants	N/A	--
75 (B092)	Item 4.5.1--Reactor Trip System Reliability--Diverse Trip Features (System Functional Testing)	All Plants	C	Addressed under ISAP Topic 1.35. Closed by NRC SER dated 2/21/86.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B093)	Items 4.5.2 & 4.5.3--Reactor Trip System Reliability--Test Alternatives and Intervals (System Functional Testing)	All Plants	C	Addressed Under ISAP Topic 1.34. Closed by NRC SER dated 5/31/89.
86 (B084)	Long Range Plan for Dealing With Stress Corrosion Cracking in BWR Piping	All BWRs	C	Closed by NRC SER dated 12/1/89; License Amendment #49, dated 3/25/91 and License Amendment #59, dated 9/24/92.
93 (B098)	Steam Binding of Auxiliary Feedwater Pumps	All PWRs	N/A	--
99 (L817)	RCS/RHR Suction Line Valve Interlock on PWRs	All PWRs	N/A	--
124	Auxiliary Feedwater System Reliability	ANO-1&2, Rancho Seco, Prairie Island 1&2, Crystal River-3 Ft. Calhoun	N/A	--
A-13 (B017)	Snubber Operability Assurance--Hydraulic Snubbers	All Plants	C	License Amendment #15, dated 3/17/88.
A-13 (B022)	Snubber Operability Assurance--Mechanical Snubbers	All Plants	C	License Amendment #15, 3/17/88.
A-16 (D012)	Steam Effects on BWR Core Spray Distribution	Oyster Creek & NMP-1	N/A	--

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
A-35 (B023)	Adequacy of Offsite Power Systems	All Plants	I	(1)
B-10	Behavior of BWR Mark III Containments	All BWR Mark III Plants	N/A	--
B-36	Develop Design, Testing and Maintenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Features Systems and for Normal Ventilation Systems	All Plants With OL Applications After 04/01/80	N/A	--
B-63 (B045)	Isolation of Low Pressure Systems Connected to the Reactor Coolant System Pressure Boundary	All Plants	C	NNECO submittal dated 3/18/80. Addressed under SEP Topic V-11.A ISAP Topic 1.04. Closed by NRC in NUREG-1184.

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

(1) By letter dated December 28, 1993, the NRC Staff accepted NNECO's proposed resolution of this issue. Modifications to be implemented during the Cycle 15 Refueling Outage. Issue is addressed under ISAP Topic 1.122.

FACILITY NAME: Millstone Nuclear Power Station, Unit No. 2
 DOCKET NO.: 50-336
 LICENSEE: Northeast Nuclear Energy Company

STATUS OF LICENSEE IMPLEMENTATION OF GENERIC SAFETY ISSUES
 RESOLVED WITH IMPOSITION OF REQUIREMENTS OR CORRECTIVE ACTIONS

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
40 (B065)	Safety Concerns Associated With Pipe Breaks in the BWR Scram System	All BWRs	N/A	--
41 (B058)	BWR Scram Discharge Volume Systems	All BWRs	N/A	--
43 (B107)	Reliability of Air Systems	All Plants	C	Closed by NNECO submittal dated 5/4/90. Closed by NRC letter dated 6/28/90.
51 (L913)	Improving the Reliability of Open-Cycle Service Water Systems	All Plants	C	NNECO submittal dated 6/18/93.
67.3.3 (A017)	Improved Accident Monitoring	All Plants	C	Closed by NNECO submittal dated 5/13/91.
75 (B076)	Item 1.1--Post-Trip Review (Program Description and Procedure)	All Plants	C	Closed by NRC SER dated 7/10/85.
75 (B085)	Item 1.2--Post-Trip Review--Data and Information Capability	All Plants	C	Closed by NRC SER dated 6/12/86.
75 (B077)	Item 2.1--Equipment Classification and Vendor Interface (Reactor Trip System Components)	All Plants	C	Closed by NRC SER dated 7/27/87.
75 (B086)	Item 2.2.1--Equipment Classification for Safety-Related Components	All Plants	C	Closed by NRC SER dated 10/31/88.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (L003)	Items 2.2.2--Vendor Interface for Safety-Related Components	All Plants	C	NNECO addressed open issues in response to GL 90-03, dated 4/19/91. Closed by NRC letter dated May 3, 1991.
75 (B078)	Items 3.1.1 & 3.1.2--Post-Maintenance Testing (Reactor Trip System Components)	All Plants	C	Closed by NRC SER dated 3/18/86.
75 (B079)	Item 3.1.3--Post-Maintenance Testing--Changes to Test Requirements (Reactor Trip System Components)	All Plants	C	Closed by NRC SER dated 10/24/85.
75 (B087)	Items 3.2.1 & 3.2.2--Post-Maintenance Testing (All Other Safety-Related Components)	All Plants	C	Closed by NRC SER dated 3/18/86.
75 (B088)	Item 3.2.3--Post-Maintenance Testing--Changes to Test Requirements (All Other Safety-Related Components)	All Plants	C	Closed by NRC SER dated 10/24/85.
75 (B080)	Item 4.1--Reactor Trip System Reliability (Vendor-Related Modifications)	All Plants	C	Closed by NRC SER dated 3/18/86.
75 (B081)	Items 4.2.1 & 4.2.2--Reactor Trip System Reliability--Maintenance and Testing (Preventative Maintenance and Surveillance Program for Reactor Trip Breakers)	All PWRs	C	Closed by NRC SER dated 4/10/86.

Page 126

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B082)	Item 4.3--Reactor Trip System Reliability--Design Modifications (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All <u>W</u> and B&W Plants	N/A	--
75 (B090)	Item 4.3--Reactor Trip System Reliability--Tech Spec Changes (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All <u>W</u> and B&W Plants	N/A	--
75 (B091)	Item 4.4--Reactor Trip System Reliability (Improvements in Maintenance and Test Procedures for B&W Plants)	All B&W Plants	N/A	--
75 (B092)	Item 4.5.1--Reactor Trip System Reliability--Diverse Trip Features (System Functional Testing)	All Plants	C	Closed by NRC SER dated 3/18/86.
75 (B093)	Items 4.5.2 & 4.5.3--Reactor Trip System Reliability--Test Alternatives and Intervals (System Functional Testing)	All Plants	C	Closed by NRC SERs dated 4/26/89 and 6/21/89.
86 (B084)	Long Range Plan for Dealing With Stress Corrosion Cracking in BWR Piping	All BWRs	N/A	--
93 (B098)	Steam Binding of Auxiliary Feed-water Pumps	All PWRs	C	Closed by NNECO response to IEB 85-01, dated 2/28/86.
99 (L817)	RCS/RHR Suction Line Valve Interlock on PWRs	All PWRs	C	Work was completed during Cycle 11 refueling outage.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
124	Auxiliary Feedwater System Reliability	ANO-1&2, Rancho Seco, Prairie Island 1&2, Crystal River-3 Ft. Calhoun	N/A	--
A-13 (B017)	Snubber Operability Assurance-- Hydraulic Snubbers	All Plants	C	License Amendment #118, dated 9/1/87.
A-13 (B022)	Snubber Operability Assurance-- Mechanical Snubbers	All Plants	C	License Amendment #118, dated 9/1/87.
A-16 (D012)	Steam Effects on BWR Core Spray Distribution	Oyster Creek & NMP-1	N/A	--
A-35 (B023)	Adequacy of Offsite Power Systems	All Plants	C	License Amendment #16, dated 7/30/76.
B-10	Behavior of BWR Mark III Contain- ments	All BWR Mark III Plants	N/A	--
B-36	Develop Design, Testing and Main- tenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Features Systems and for Normal Ventilation Systems	All Plants With OL Applications After 04/01/80	N/A	--
B-63 (B045)	Isolation of Low Pressure Systems Connected to the Reactor Coolant System Pressure Boundary	All Plants	C	Closed by NNECO response (dated 3/18/80 to NRC request for information (dated 2/23/80).

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Page 128

FACILITY NAME: Millstone Nuclear Power Station, Unit No. 3
 DOCKET NO.: 50-423
 LICENSEE: Northeast Nuclear Energy Company

STATUS OF LICENSEE IMPLEMENTATION OF GENERIC SAFETY ISSUES
 RESOLVED WITH IMPOSITION OF REQUIREMENTS OR CORRECTIVE ACTIONS

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
40 (B065)	Safety Concerns Associated With Pipe Breaks in the BWR Scram System	All BWRs	N/A	--
41 (B058)	BWR Scram Discharge Volume Systems	All BWRs	N/A	--
43 (B107)	Reliability of Air Systems	All Plants	C	Closed by NRC letter dated 5/5/89.
51 (L913)	Improving the Reliability of Open-Cycle Service Water Systems	All Plants	C	NNECO letters of 1/25/90, 5/31/91, and 11/5/93
67.3.3 (A017)	Improved Accident Monitoring	All Plants	C	Closed by NUREG 1031, Supplement #4 and NRC letter dated 10/21/87.
75 (B076)	Item 1.1--Post-Trip Review (Program Description and Procedure)	All Plants	C	Closed by NUREG 1031, Supplement #4.
75 (B085)	Item 1.2--Post-Trip Review--Data and Information Capability	All Plants	C	Closed by NRC letter dated 11/24/86.
75 (B077)	Item 2.1--Equipment Classification and Vendor Interface (Reactor Trip System Components)	All Plants	C	Closed by NRC letters dated 11/24/86 and 8/4/87.
75 (B086)	Item 2.2.1--Equipment Classification for Safety-Related Components	All Plants	C	Closed by NRC letter dated 10/31/88.

Page 129

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (L003)	Items 2.2.2--Vendor Interface for Safety-Related Components	All Plants	C	NNECO addressed open issues in response to GL 90-03, dated 4/19/91. Closed by NRC letter dated May 3, 1991.
75 (B078)	Items 3.1.1 & 3.1.2--Post-Maintenance Testing (Reactor Trip System Components)	All Plants	C	Closed by NRC letter dated 6/26/87.
75 (B079)	Item 3.1.3--Post-Maintenance Testing--Changes to Test Requirements (Reactor Trip System Components)	All Plants	C	Closed by NRC letter dated 11/24/86.
75 (B087)	Items 3.2.1 & 3.2.2--Post-Maintenance Testing (All Other Safety-Related Components)	All Plants	C	Closed by NRC letter dated 6/26/87.
75 (B088)	Item 3.2.3--Post-Maintenance Testing--Changes to Test Requirements (All Other Safety-Related Components)	All Plants	C	Closed by NRC letter dated 11/24/86.
75 (B080)	Item 4.1--Reactor Trip System Reliability (Vendor-Related Modifications)	All Plants	C	Closed by NRC letter dated 11/24/86.
75 (B081)	Items 4.2.1 & 4.2.2--Reactor Trip System Reliability--Maintenance and Testing (Preventative Maintenance and Surveillance Program for Reactor Trip Breakers)	All PWRs	C	Closed by NRC letter dated 11/24/86.

NRC/NU COUNTERPARTS MEETING

APRIL 21, 1994

Page 130

<u>GSI/(MPA 'o.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
75 (B082)	Item 4.3--Reactor Trip System Reliability--Design Modifications (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All <u>W</u> and B&W Plants	C	Closed by NUREG 1031.
75 (B090)	Item 4.3--Reactor Trip System Reliability--Tech Spec Changes (Automatic Actuation of Shunt Trip Attachment for Westinghouse and B&W Plants)	All <u>W</u> and B&W Plants	C	Closed by NRC letter dated 8/7/87.
75 (B091)	Item 4.4--Reactor Trip System Reliability (Improvements in Maintenance and Test Procedures for B&W Plants)	All B&W Plants	N/A	--
75 (B092)	Item 4.5.1--Reactor Trip System Reliability--Diverse Trip Features (System Functional Testing)	All Plants	C	Closed by NRC letter dated 6/26/87.
75 (B093)	Items 4.5.2 & 4.5.3--Reactor Trip System Reliability--Test Alternatives and Intervals (System Functional Testing)	All Plants	C	Closed by NRC letters dated 2/24/87 and 6/19/89.
86 (B084)	Long Range Plan for Dealing With Stress Corrosion Cracking in BWR Piping	All BWRs	N/A	--
93 (B098)	Steam Binding of Auxiliary Feed-water Pumps	All PWRs	C	Closed by NRC letter dated 6/29/88.
99 (L817)	RCS/RHR Suction Line Valve Interlock on PWRs	All PWRs	C	Completed during the third refueling outage.

<u>GSI/(MPA No.)</u>	<u>Title</u>	<u>Applicability</u>	<u>Status*</u>	<u>Comments</u>
124	Auxiliary Feedwater System Reliability	ANO-1&2, Rancho Seco, Prairie Island 1&2, Crystal River-3 Ft. Calhoun	NC	NUREG 1031.
A-13 (B017)	Snubber Operability Assurance-- Hydraulic Snubbers	All Plants	NC	NUREG 1031.
A-13 (B022)	Snubber Operability Assurance-- Mechanical Snubbers	All Plants	NC	NUREG 1031.
A-16 (D012)	Steam Effects on BWR Core Spray Distribution	Oyster Creek & NMP-1	N/A	--
A-35 (B023)	Adequacy of Offsite Power Systems	All Plants	NC	NUREG 1031.
B-10	Behavior of BWR Mark III Contain- ments	All BWR Mark III Plants	N/A	--
B-36	Develop Design, Testing and Main- tenance Criteria for Atmosphere Cleanup System Air Filtration and Adsorption Units for Engineered Safety Features Systems and for Normal Ventilation Systems	All Plants With OL Applications After 04/01/80	NC	NUREG 1031.
B-63 (B045)	Isolation of Low Pressure Systems Connected to the Reactor Coolant System Pressure Boundary	All Plants	NC	NUREG 1031.

- *1. Provide a separate entry for each licensed reactor unit. If the information is identical for multiple units, so state.
2. If a GSI is not applicable to a unit(s), enter "NA."
3. If a GSI is applicable but no changes were necessary to implement the resolution, enter "NC." If the GSI implementation was completed prior to issuance of the operating license, enter "NC," as no postlicensing changes were necessary.
4. If a GSI is applicable, submittal of information and/or changes were necessary and such submittals were made or changes are complete, enter "C." Also identify the licensee's document(s) to the NRC which certified completion, and the document date(s).
5. If a GSI is applicable and changes are necessary but such changes are not yet fully implemented, enter "I" and the projected month and year of completion. Provide a brief explanation of the outstanding work in the "Comments" column.
6. If implementation guidance for a resolved GSI was issued recently and the licensee is still evaluating the appropriate response, enter "E" and the projected response date.
7. The "Comments" column may be used to explain any entry in the "Status" column.

VI. SUMMARY AND CONCLUSIONS

VI. SUMMARY AND CONCLUSIONS

- ACTION ITEM REVIEW
- SCHEDULE NEXT MEETING