

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N Y I P S 2 2 0 0 0 - 0 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 1 4 5
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 REPORT SOURCE L 5 d 5 0 0 0 2 4 7 7 0 2 1 3 8 3 8 0 2 2 7 8 3 9
8 9 DOCKET NUMBER 60 61 63 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

2 During a plant start-up, measured reactor coolant system leakage increased to 7.4 GEM.
3 A plant shutdown was commenced. Tech Spec. 3.1.F.2.C (1) limits identified leakage
4 to 10 GPM. A containment entry team found RHR valve 731 packing was leaking through
5 a controlled leakoff collection system to the Reactor Coolant Drain Tank (RCDT). The
6 valve leakage reached 14 GPM. All leakage was directed to the RCDT and Waste Disposal
7 System. Public health and safety were unaffected. Similar events: RO 76-2-1 and
8 76-2-19.

9 SYSTEM CODE C F 11 CAUSE CODE D 12 CAUSE SUBCODE Z 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE E 15 VALVE SUBCODE D 16
17 LER/RO REPORT NUMBER 8 3 21 EVENT YEAR 8 3 22 SEQUENTIAL REPORT NO. 7 0 3 26 OCCURRENCE CODE 0 1 28 REPORT TYPE T 30 REVISION NO. 0 32
ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT A 20 SHUTDOWN METHOD A 21 HOURS 0 0 3 0 22 ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 6 3 5 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

0 The cause of the leakage was failed valve gland packing. The valve is a 14" motor
1 operated Copes Vulcan Gate Valve (DWG E-1-133420). The valve was repacked and
2 satisfactorily tested.

5 FACILITY STATUS C 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Visual Observation 32
8 9 10 11 12 13 44 45 46 80

6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
8 9 10 11 44 45 80

7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
8 9 10 11 12 13 80

8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
8 9 10 11 12 13 80

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
8 9 10 11 12 13 80

0 PURITY ISSUED N 44 DESCRIPTION NA 45
8 9 10 11 12 13 80