



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

CONNECTICUT YANKEE ATOMIC POWER COMPANY

DOCKET NO. 50-213

HADDAM NECK PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 171  
License No. DPR-61

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Connecticut Yankee Atomic Power Company (the licensee), dated January 17, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-61 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 171, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director  
Project Directorate 1-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 17, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 171

FACILITY OPERATING LICENSE NO. DPR-61

DOCKET NO. 50-213

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

VIII  
XIV  
3/4 4-51  
B3/4 4-13

Insert

VIII  
XIV  
3/4 4-51  
B3/4 4-13

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

---

---

<u>SECTION</u>	<u>PAGE</u>
3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE	
Leakage Detection Systems.....	3/4 4-29
Operational Leakage.....	3/4 4-31
3/4.4.7 CHEMISTRY.....	3/4 4-33
TABLE 3.4-1 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS.....	3/4 4-34
TABLE 4.4-3 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS SURVEILLANCE REQUIREMENTS.....	3/4 4-35
3/4.4.8 SPECIFIC ACTIVITY.....	3/4 4-36
FIGURE 3.4-2 DOSE EQUIVALENT I-131 REACTOR COOLANT SPECIFIC ACTIVITY LIMIT VERSUS PERCENT OF RATED THERMAL POWER WITH THE REACTOR COOLANT SPECIFIC ACTIVITY GREATER THAN 1 microCurie/gram DOSE EQUIVALENT I-131.....	3/4 4-37
TABLE 4.4-4 REACTOR COOLANT SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM.....	3/4 4-38
3/4.4.9 PRESSURE/TEMPERATURE LIMITS	
Reactor Coolant System.....	3/4 4-39
FIGURE 3.4-3 CONNECTICUT YANKEE LIMIT CURVE FOR HYDROSTATIC AND LEAK TESTING APPLICABLE FOR 22.0 EFFECTIVE FULL POWER YEARS.....	3/4 4-41
FIGURE 3.4-4 CONNECTICUT YANKEE REACTOR COOLANT SYSTEM HEATUP LIMITATIONS FOR 22.0 EFFECTIVE FULL POWER YEARS.....	3/4 4-42
FIGURE 3.4-5 CONNECTICUT YANKEE REACTOR COOLANT SYSTEM COOLDOWN LIMITATIONS FOR 22.0 EFFECTIVE FULL POWER YEARS.....	3/4 4-43
Pressurizer.....	3/4 4-45
Low Temperature Overpressure Protection Systems.....	3/4 4-46
3/4.4.10 STRUCTURAL INTEGRITY.....	3/4 4-48
3/4.4.11 REACTOR COOLANT SYSTEM VENTS.....	3/4 4-49

INDEX

BASES

---

<u>SECTION</u>		<u>PAGE</u>
3/4.4.7	CHEMISTRY.....	B 3/4 4-7
3/4.4.8	SPECIFIC ACTIVITY.....	B 3/4 4-7
3/4.4.9	PRESSURE/TEMPERATURE LIMITS.....	B 3/4 4-8
3/4.4.10	STRUCTURAL INTEGRITY.....	B 3/4 4-12
3/4.4.11	REACTOR COOLANT SYSTEM VENTS.....	B 3/4 4-12
<u>3/4.5</u>	<u>EMERGENCY CORE COOLING SYSTEMS</u>	
3/4.5.1 & 3/4.5.2	ECCS SUBSYSTEMS.....	B 3/4 5-1
3/4.5.3	REFUELING WATER STORAGE TANK.....	B 3/4 5-2
3/4.5.4	pH CONTROL SYSTEM.....	B 3/4 5-2
<u>3/4.6</u>	<u>CONTAINMENT SYSTEMS</u>	
3/4.6.1	PRIMARY CONTAINMENT.....	B 3/4 6-1
3/4.6.2	CONTAINMENT AIR RECIRCULATION SYSTEM.....	B 3/4 6-3
3/4.6.3	CONTAINMENT ISOLATION VALVES.....	B 3/4 6-3
<u>3/4.7</u>	<u>PLANT SYSTEMS</u>	
3/4.7.1	TURBINE CYCLE.....	B 3/4 7-1
3/4.7.2	STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	B 3/4 7-2
3/4.7.3	SERVICE WATER SYSTEM.....	B 3/4 7-2
3/4.7.4	SNUBBERS.....	B 3/4 7-3
3/4.7.5	SEALED SOURCE CONTAMINATION.....	B 3/4 7-4
3/4.7.6	FIRE SUPPRESSION SYSTEMS.....	B 3/4 7-4
3/4.7.7	FIRE RATED ASSEMBLIES.....	B 3/4 7-5
3/4.7.8	FLAMMABLE LIQUIDS CONTROL.....	B 3/4 7-5
3/4.7.9	FEEDWATER ISOLATION VALVES.....	B 3/4 7-6
3/4.7.10	EXTERNAL FLOOD PROTECTION.....	B 3/4 7-6
3/4.7.11	PRIMARY AUXILIARY BUILDING AIR CLEANUP SYSTEM.....	B 3/4 7-6

"This page intentionally blank"

## REACTOR COOLANT SYSTEM

### BASES

---

---

#### 3/4.4.11 REACTOR COOLANT SYSTEM VENTS (Continued)

cooling. The OPERABILITY of at least one RCS vent path from the reactor vessel head and the pressurizer steam space ensures the capability exists to perform this function.

The valve redundancy of the RCS vent paths serves to minimize the probability of inadvertent or irreversible actuation while ensuring that a single failure of a vent valve, power supply or control system does not prevent isolation of the vent path.

The function, capability and testing requirements of the RCS vents are consistent with the requirements of Item II.B.1 of NUREG-0737, "Clarification of TMI Action Plan Requirements," November 1980.