



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

March 2, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-026/01T-0
ER 100456 FILE 841-23
PLA- 1555

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

This transmission confirms the verbal report of 3/2/83, by F.T. Eisenhuth to G.G. Rhoads of your staff, concerning the inoperability of both trains of the Standby Gas Treatment System. This inoperability was the result of inappropriate application of a protective permit for personnel safety. Upon removal of the permit, the system was restored to operable status, being out of service for a period of 24 hours.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8.f.

H.W. Keiser
H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/cg

cc: Director, Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director, Office of Management & Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE29