



U.S. Department of Energy

Idaho Operations Office • Idaho National Engineering Laboratory

Experiment Data Report For Semiscale MOD-2A Natural Circulation Test Series (Test S-NC-1)

Thomas M. O'Connell

November 1981

Prepared for the
U.S. Nuclear Regulatory Commission
Under DOE Contract No. DE-AC07-76ID01570

B112210215 811130
PDR NUREG
CR-2379 R PDR



NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

GPO Sales Program
Division of Technical Information and Document Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

and

National Technical Information Service
Springfield, Virginia 22161

NUREG/CR-2379
EGG-2134
Distribution Category: R2

**EXPERIMENT DATA REPORT FOR SEMISCALE
MOD-2A NATURAL CIRCULATION TEST SERIES
(TEST S-NC-1)**

Thomas M. O'Connell

Published November 1981

**EG&G Idaho, Inc.
Idaho Falls, Idaho 83415**

Prepared for the
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
Under DOE Contract No. DE-AC07-76ID01570
FIN No. A6038

ABSTRACT

This report presents test data recorded for Test S-NC-1 (ANCI and BNCl) of the Semiscale Mod-2A Natural Circulation Test Series. This is one of several Semiscale tests that investigate the thermal-hydraulic phenomena resulting from operational transients involving loss of mechanical primary coolant circulation in a pressurized water reactor. These tests give experimental data used to develop and assess the analytical capability of computer models predicting the results of small-break loss-of-coolant accidents or operational transients involving the loss of primary pumping ability.

The primary objective of Test S-NC-1 was to experimentally characterize the thermal-hydraulic

behavior of a system during single-phase (subcooled) steady-state natural circulation flow conditions. Of special interest were the effects on single-phase natural circulation flow promoted by changes in core power, primary pressure, and external heater power.

This report presents the uninterpreted data from Test S-NC-1 (ANCI and BNCl) for future data analysis. The data, presented by graphs in engineering units, have been analyzed only to the extent necessary to ensure that they are reasonable and consistent.

SUMMARY

Test S-NC-1 is one in the Semiscale Mod-2A Natural Circulation Test Series conducted by EG&G Idaho, Inc., for the United States Government. The NC Series investigates the thermal-hydraulic phenomena resulting from operational transients involving the loss of mechanical primary coolant circulation in a pressurized water reactor, and provides experimental data that can be used to develop and assess the analytical capability of computer models designed to predict and analyze such transients. The objective of Test S-NC-1 was to experimentally characterize the thermal-hydraulic behavior of a system during single-phase (subcooled), steady-state, natural circulation flow conditions. Of special interest were the effects on single-phase, natural circulation flow promoted by changes in core power, primary pressure, and external heater power.

The Mod-2A system is equipped with a pressure vessel that contains an electrically heated core and other simulated reactor internals and an external downcomer assembly; an intact loop with steam generator, pump, and pressurizer; and a broken loop with steam generator, pump, and rupture assembly. For this test, the broken loop and vessel upper head were removed and replaced with end caps, leaving the intact loop, vessel with downcomer, and intact loop steam generator. The

intact loop pump was removed to eliminate leakage, and replaced with a spool piece designed to have a hydraulic resistance scaled for a locked rotor condition.

Natural circulation of the primary fluid was established at a variety of primary system pressures and core power levels, using the core as a heat source and steam generator secondary as a heat sink: low pressure, 0.48 MPa; intermediate pressure, 3.5 MPa; high pressures, 9.1 MPa, 10.1 MPa, and 11.2 MPa; and core power between 30 and 100 kW, 1-1/2% to 5% decay power. The primary pressure was changed as noted above to ensure sufficient subcooling in the primary for single-phase conditions. Secondary pressure was maintained constant during each case.

Generally, Test S-NC-1 proceeded as specified. Conditions that did not conform to the specified test configuration were considered acceptable for analysis within the test objectives.

Test S-NC-1 data are available from the NRC/RSR Data Bank at the Idaho National Engineering Laboratory. Address inquiries to EG&G Idaho, Inc., P.O. Box 1625, Idaho Falls, Idaho 83415.

CONTENTS

ABSTRACT	ii
SUMMARY	iii
I. INTRODUCTION	1
II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-NC-1	3
System Configuration	3
Test Preparation	11
Warmup	11
Test Sequence	12
Table: Data for Test Conditions	12
III. DATA PRESENTATION	17
IV. REFERENCES	28
APPENDIX A—DATA ACQUISITION SYSTEM CAPABILITIES AND UNCERTAINTY ANALYSIS	A-1

NOTE: The appendix to this report is presented on microfiche sheet 003 attached to the inside of the back cover.

FIGURES

1. Semiscale Mod-2A system configuration for separate effect natural circulation— isometric	4
2. Semiscale Mod-2A system configuration for separate effect natural circulation— schematic	5
3. Semiscale Mod-2A intact loop pump bypass assembly— isometric	6
4. Semiscale Mod-2A core vessel and downcomer—Test S-NC-1 cross section	7
5. Semiscale Mod-2A heated core plan view	8
6. Semiscale Mod-2A intact loop steam generator tubes—horizontal cross section	9
7. Semiscale Mod-2A intact loop steam generator thermocouple locations	10
8. Semiscale Mod-2A steam generator fluid thermocouple installation	11

NOTE: Figures 9 through 416 are presented on microfiche attached to the inside of the back cover.

9. Fluid temperature in intact loop hot leg (TFI*1) from ANC1
10. Fluid temperature in intact loop hot leg (TFI*3E) from ANC1
11. Fluid temperature in intact loop hot leg (TFI*4) from ANC1
12. Fluid temperature in intact loop steam generator inlet leg (TFI*5) from ANC1
13. Fluid temperature in intact loop steam generator outlet leg (TFI*9) from ANC1
14. Fluid temperature in intact loop pump suction leg (TFI*15) from ANC1
15. Fluid temperature in intact loop pump bypass (TFI*PBB) from ANC1
16. Fluid temperature in intact loop cold leg (TFI*21) from ANC1
17. Fluid temperature in intact loop cold leg (TFI*22) from ANC1
18. Fluid temperature in vessel downcomer (TFV*DC-18) from ANC1
19. Fluid temperature in vessel downcomer (TFV*DC-84) from ANC1
20. Fluid temperature in vessel downcomer (TFV*DC-270) from ANC1
21. Fluid temperature in vessel downcomer (TFV*DC-293) from ANC1
22. Fluid temperature in vessel downcomer (TFV*DC-436) from ANC1
23. Fluid temperature in vessel (TFV*LP-552) from ANC1
24. Fluid temperature in vessel (TFV*UPR-38) from ANC1
25. Fluid temperature in vessel (TFV*UPM-13) from ANC1
26. Fluid temperature in core, grid spacer 1 (TFV*D4 + 6) from ANC1
27. Fluid temperature in core, grid spacer 4 (TFV*B3 + 126) from ANC1
28. Fluid temperature in core, grid spacer 5 (TFV*B3 + 166) from ANC1
29. Fluid temperature in core, grid spacer 6 (TFV*B3 + 206) from ANC1
30. Fluid temperature in core, grid spacer 8 (TFV*A4 + 286) from ANC1
31. Fluid temperature in core, grid spacer 9 (TFV*A4 + 326) from ANC1
32. Fluid temperature in core, grid spacer 10 (TFV*A4 + 366) from ANC1
33. Fluid temperature in steam generator, primary side (TFIP + LH30) from ANC1
34. Fluid temperature in steam generator, primary side (TFIP + SH84) from ANC1
35. Fluid temperature in steam generator, primary side (TFIP + LH152) from ANC1

- 36. Fluid temperature in steam generator, primary side (TFIP + LH211) from ANC1
- 37. Fluid temperature in steam generator, primary side (TFIP + LH452) from ANC1
- 38. Fluid temperature in steam generator, primary side (TFIP + LH668) from ANC1
- 39. Fluid temperature in steam generator, primary side (TFIP + LH785) from ANC1
- 40. Fluid temperature in steam generator, primary side (TFIP + SH815) from ANC1
- 41. Fluid temperature in steam generator, primary side (TFIP + LH922) from ANC1
- 42. Fluid temperature in steam generator, primary side (TFIP + SC668) from ANC1
- 43. Fluid temperature in steam generator, primary side (TFIP + SC333) from ANC1
- 44. Fluid temperature in steam generator, primary side (TFIP + LC333) from ANC1
- 45. Fluid temperature in steam generator, primary side (TFIP + SC211) from ANC1
- 46. Fluid temperature in steam generator, primary side (TFIP + LC211) from ANC1
- 47. Fluid temperature in steam generator feed water supply (TFSC*IGFWU) from ANC1
- 48. Fluid temperature in steam generator, steam discharge (TFSC*IGSTM) from ANC1
- 49. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+914) from ANC1
- 50. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+457) from ANC1
- 51. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+152) from ANC1
- 52. Fluid temperature in steam generator, secondary side (TFIS + SH84) from ANC1
- 53. Fluid temperature in steam generator, secondary side (TFIS + SC333) from ANC1
- 54. Fluid temperature in steam generator, secondary side (TFIS + SH452) from ANC1
- 55. Fluid temperature in steam generator, secondary side (TFIS + LH30) from ANC1
- 56. Fluid temperature in steam generator, secondary side (TFIS + LC30) from ANC1
- 57. Fluid temperature in steam generator, secondary side (TFIS + LH84) from ANC1
- 58. Fluid temperature in steam generator, secondary side (TFIS + LC84) from ANC1
- 59. Fluid temperature in steam generator, secondary side (TFIS + LH152) from ANC1
- 60. Fluid temperature in steam generator, secondary side (TFIS + LH211) from ANC1

61.	Fluid temperature in steam generator, secondary side (TFIS + LC211) from ANCI
62.	Fluid temperature in steam generator, secondary side (TFIS + LC333) from ANCI
63.	Fluid temperature in steam generator, secondary side (TFIS + LH394) from ANCI
64.	Fluid temperature in steam generator, secondary side (TFIS + LH452) from ANCI
65.	Fluid temperature in steam generator, secondary side (TFIS + LC452) from ANCI
66.	Fluid temperature in steam generator, secondary side (TFIS + LH536) from ANCI
67.	Fluid temperature in steam generator, secondary side (TFIS + LH785) from ANCI
68.	Fluid temperature in steam generator, secondary side (TFIS + LH922) from ANCI
69.	Fluid temperature in pressurizer (TF*PRZ + 132) from ANCI
70.	Fluid temperature in pressurizer surge line (TF*PRZ-73) from ANCI
71.	Metal temperature of intact loop hot leg (TMI*1) from ANCI
72.	Metal temperature of intact loop hot leg (TMI*4) from ANCI
73.	Metal temperature of intact loop pump suction leg (TMI*15) from ANCI
74.	Metal temperature of intact loop pump bypass (TMI*PBB) from ANCI
75.	Metal temperature of vessel downcomer (TMV*DC-18) from ANCI
76.	Metal temperature of vessel downcomer (TMV*DC-223) from ANCI
77.	Metal temperature of vessel downcomer (TMV*DC-294) from ANCI
78.	Metal temperature of vessel downcomer (TMV*DC-435) from ANCI
79.	Metal temperature of vessel (TMV*LPR587) from ANCI
80.	Metal temperature of vessel (TMV*SC-352) from ANCI
81.	Metal temperature of vessel (TMV*SC-212) from ANCI
82.	Metal temperature, steam generator, on tube (TMIG + LH30) from ANCI
83.	Metal temperature, steam generator, on tube (TMIG + LH84) from ANCI
84.	Metal temperature, steam generator, on tube (TMIG + LH211) from ANCI
85.	Metal temperature, steam generator, on tube (TMIG + LH668) from ANCI
86.	Metal temperature, steam generator, on tube (TMIG + LC30) from ANCI
87.	Metal temperature, steam generator, on tube (TMIG + LC211) from ANCI

Microfiche sheet	001
88. Metal temperature, steam generator, on tube (TMIG + LC452) from ANCI	
89. Metal temperature, steam generator, on tube (TMIG + SC452) from ANCI	
90. Metal temperature, steam generator, on filler piece (TMIG + FP2C) from ANCI	
91. Metal temperature, steam generator inlet leg, under external heater (TMEH*7) from ANCI	
92. Metal temperature, steam generator outlet leg, under external heater (TMEH*8) from ANCI	
93. Metal temperature, intact loop pump suction leg, under external heater (TMEH*16) from ANCI	
94. Metal temperature, intact loop cold leg, under external heater (TMEH*22) from ANCI	
95. Metal temperature, vessel downcomer, under external heater (TMEH*D-237) from ANCI	
96. Metal temperature, vessel, under external heater (TMEH*V-360) from ANCI	
97. Metal temperature, vessel, under external heater (TMEH*V-196) from ANCI	
98. Metal temperature, vessel, under external heater (TMEH*V + 101) from ANCI	
99. Material temperature, intact loop hot leg, under insulation (TEH*3) from ANCI	
100. Material temperature, steam generator inlet leg, under insulation (TEH*7) from ANCI	
101. Material temperature, steam generator outlet leg, under insulation (TEH*8) from ANCI	
102. Material temperature, intact loop pump suction, under insulation (TEH*12) from ANCI	
103. Material temperature, intact loop pump bypass, under insulation (TEH*PBB) from ANCI	
104. Material temperature, intact loop cold leg, under insulation (TEH*22) from ANCI	
105. Material temperature, vessel downcomer, under insulation (TEH*D-237) from ANCI	
106. Material temperature, vessel, under insulation (TEH*V-196) from ANCI	
107. Material temperature, vessel, under insulation (TEH*V + 101) from ANCI	
108. Core heater temperature, Rod B-2 (THV*B2 + 39) from ANCI	
109. Core heater temperature, Rod B-2 (THV*B2 + 196) from ANCI	
110. Core heater temperature, Rod B-3 (THV*B3 + 354) from ANCI	

- 111. Core heater temperature, Rod B-4 (THV*B4 + 322) from ANCI
- 112. Core heater temperature, Rod C-2 (THV*C2 + 321) from ANCI
- 113. Core heater temperature, Rod C-3 (THV*C3 + 79) from ANCI
- 114. Core heater temperature, Rod C-3 (THV*C3 + 231) from ANCI
- 115. Core heater temperature, Rod C-4 (THV*C4 + 187) from ANCI
- 116. Core heater temperature, Rod D-2 (THV*D2 + 254) from ANCI
- 117. Core heater temperature, Rod D-4 (THV*D4 + 179) from ANCI
- 118. Core heater temperature, Rod D-4 (THV*D4 + 352) from ANCI
- 119. Core heater temperature, Rod A-2 (THV*A2 + 112) from ANCI
- 120. Core heater temperature, Rod A-3 (THV*A3 + 208) from ANCI
- 121. Core heater temperature, Rod A-3 (THV*A3 + 291) from ANCI
- 122. Core heater temperature, Rod A-4 (THV*A4 + 355) from ANCI
- 123. Core heater temperature, Rod B-1 (THV*B1 + 183) from ANCI
- 124. Core heater temperature, Rod B-1 (THV*B1 + 253) from ANCI
- 125. Core heater temperature, Rod B-5 (THV*B5 + 252) from ANCI
- 126. Core heater temperature, Rod C-1 (THV*C1 + 292) from ANCI
- 127. Core heater temperature, Rod C-5 (THV*C5 + 290) from ANCI
- 128. Core heater temperature, Rod E-4 (THV*E4 + 230) from ANCI
- 129. Pressure in intact loop, hot leg (PI*1) from ANCI
- 130. Pressure in intact loop, steam generator inlet leg (PI*5) from ANCI
- 131. Pressure in steam generator tube, primary side (PIG*LH970) from ANCI
- 132. Pressure in intact loop, steam generator outlet leg (PI*9) from ANCI
- 133. Pressure in intact loop, pump suction leg (PI*14) from ANCI
- 134. Pressure in intact loop, pump bypass (PI*PBB) from ANCI
- 135. Pressure in intact loop, cold leg (PI*22) from ANCI
- 136. Pressure in vessel downcomer (PV*DC-435) from ANCI
- 137. Pressure in vessel lower plenum (PV*LP-442) from ANCI

- 138. Pressure in vessel upper plenum (PV*UP-13) from ANCI
- 139. Pressure in pressurizer steam dome (P*PRZ + 158) from ANCI
- 140. Pressure in steam generator feedwater supply line (PSC*IGFDW) from ANCI
- 141. Pressure in steam generator steam discharge line (PSC*IGSTM) from ANCI
- 142. Differential pressure in intact loop hot leg (D-V13A*11) from ANCI
- 143. Differential pressure in intact loop hot leg (DI*3C-G55E) from ANCI
- 144. Differential pressure in steam generator tube (DIG-55E + 92) from ANCI
- 145. Differential pressure in steam generator tube (DIG55E + 462) from ANCI
- 146. Differential pressure in steam generator tube (DIG55E + 905) from ANCI
- 147. Differential pressure across steam generator plenum (DIG-55E55X) from ANCI
- 148. Differential pressure in intact loop, steam generator outlet leg (D*IG-55X*9)
from ANCI
- 149. Differential pressure in intact loop pump suction (DPI*9*14) from ANCI
- 150. Differential pressure in intact loop pump suction (DPI*14*PBA) from ANCI
- 151. Differential pressure across intact loop pump suction (DPI*9*PBA) from ANCI
- 152. Differential pressure in intact loop cold leg (DPI*PBB*22) from ANCI
- 153. Differential pressure in intact loop cold leg (D*I22 + VD29) from ANCI
- 154. Differential pressure across pressurizer surge line (DP*PRZ*I3C) from ANCI
- 155. Liquid level, intact loop steam generator, primary side (LIP970-55E) from ANCI
- 156. Liquid level, intact loop steam generator, primary side (LIP970-55X) from ANCI
- 157. Liquid level in vessel downcomer (LVD + 29-170) from ANCI
- 158. Liquid level in vessel downcomer (LVD170-578) from ANCI
- 159. Liquid level in vessel downcomer (LVD + 29-578) from ANCI
- 160. Liquid level in vessel (LV-578-501) from ANCI
- 161. Liquid level in vessel (LV-501-105) from ANCI
- 162. Liquid level in vessel (LV-105 + 140) from ANCI
- 163. Liquid level in vessel (LV-578-13M) from ANCI

- 164. Liquid level in vessel (LV-13M + 140) from ANCI
- 165. Liquid level in vessel (LV-578 + 140) from ANCI
- 166. Differential pressure in intact loop steam generator feedwater line (DPSC*IGFDW) from ANCI
- 167. Differential pressure in intact loop steam generator steam line (DPSC*IGSTM) from ANCI
- 168. Liquid level, intact loop steam generator, secondary side (LI1117S460) from ANCI
- 169. Liquid level, intact loop steam generator, secondary side (LI1117 + 90) from ANCI
- 170. Volumetric flow rate in intact loop pump suction leg (QI*15) from ANCI
- 171. Volumetric flow rate in intact loop pump bypass (QI*PB) from ANCI
- 172. Volumetric flow rate in intact loop cold leg (QI*22) from ANCI
- 173. Volumetric flow rate in vessel downcomer (QV*DC-423) from ANCI
- 174. Density in intact loop hot leg (RI*1T) from ANCI
- 175. Density in intact loop hot leg (RI*1B) from ANCI
- 176. Density in intact loop hot leg (RI*1C) from ANCI
- 177. Density in intact loop steam generator inlet leg (RI*5M) from ANCI
- 178. Density in intact loop steam generator inlet leg (RI*5I) from ANCI
- 179. Density in intact loop steam generator inlet leg (RI*5C) from ANCI
- 180. Density in intact loop pump bypass (RI*PBT) from ANCI
- 181. Density in intact loop pump bypass (RI*PBM) from ANCI
- 182. Density in intact loop pump bypass (RI*PBC) from ANCI
- 183. Density in intact loop cold leg (RI*22T) from ANCI
- 184. Density in intact loop cold leg (RI*22B) from ANCI
- 185. Density in intact loop cold leg (RI*22C) from ANCI
- 186. Density in vessel downcomer (RV*DC-72) from ANCI
- 187. Density in vessel downcomer (RV*DC-260) from ANCI
- 188. Density in vessel downcomer (RV*DC-456) from ANCI
- 189. Density in vessel (RV*AB-6) from ANCI

Microfiche sheet	001
190. Density in vessel (RV*23 + 13) from ANCI	
191. Density in vessel (RV*23 + 113) from ANCI	
192. Density in vessel (RV*AB + 173) from ANCI	
193. Density in vessel (RV*23 + 183) from ANCI	
194. Density in vessel (RV*23 + 253) from ANCI	
195. Density in vessel upper plenum (RV*UP-11) from ANCI	
196. Mass flow in intact loop pump bypass (QI*PB and RI*PBC) from ANCI	
197. Mass flow in intact loop cold leg (QI*22 and RI*22C) from ANCI	
198. Mass flow in vessel downcomer (QV*DC-423 and RV*DC-456) from ANCI	
199. Core heater high power bus current (IV*HIPWBUS) from ANCI	
200. Core heater high power bus voltage (EV*HIPWBUS) from ANCI	
201. Core heater low power bus current (IV*LOPWBUS) from ANCI	
202. Core heater low power bus voltage (EV*LOPWBUS) from ANCI	
203. Core heater power, high power bus, calculated (KWH*HIC) from ANCI	
204. Core heater power, low power bus, calculated (KWH*LOC) from ANCI	
205. Core heater power, total, calculated (KWH*TOTC) from ANCI	
206. Fluid temperature in intact loop hot leg (TFI*1) from BNC1	
207. Fluid temperature in intact loop hot leg (TFI*3E) from BNC1	
208. Fluid temperature in intact loop hot leg (TFI*4) from BNC1	
209. Fluid temperature in intact loop steam generator inlet leg (TFI*5) from BNC1	
210. Fluid temperature in intact loop steam generator outlet leg (TFI*9) from BNC1	
211. Fluid temperature in intact loop pump suction leg (TFI*15) from BNC1	
212. Fluid temperature in intact loop pump bypass (TFI*PBB) from BNC1	
213. Fluid temperature in intact loop cold leg (TFI*21) from BNC1	
214. Fluid temperature in intact loop cold leg (TFI*22) from BNC1	
215. Fluid temperature in vessel downcomer (TFV*DC-18) from BNC1	
216. Fluid temperature in vessel downcomer (TFV*DC-84) from BNC1	

Microfiche sheet	001
217. Fluid temperature in vessel downcomer (TFV*DC-270) from BNC1	
218. Fluid temperature in vessel downcomer (TFV*DC-293) from BNC1	
219. Fluid temperature in vessel downcomer (TFV*DC-436) from BNC1	
220. Fluid temperature in vessel (TFV*LP-552) from BNC1	
221. Fluid temperature in vessel (TFV*UPR-38) from BNC1	
222. Fluid temperature in vessel (TFV*UPM-13) from BNC1	
223. Fluid temperature in core, grid spacer 1 (TFV*D4 + 6) from BNC1	
224. Fluid temperature in core, grid spacer 4 (TFV*B3 + 126) from BNC1	
225. Fluid temperature in core, grid spacer 5 (TFV*B3 + 166) from BNC1	
226. Fluid temperature in core, grid spacer 6 (TFV*B3 + 206) from BNC1	
227. Fluid temperature in core, grid spacer 8 (TFV*A4 + 286) from BNC1	
228. Fluid temperature in core, grid spacer 9 (TFV*A4 + 326) from BNC1	
229. Fluid temperature in core, grid spacer 10 (TFV*A4 + 366) from BNC1	
230. Fluid temperature in steam generator, primary side (TFIP + LH30) from BNC1	
231. Fluid temperature in steam generator, primary side (TFIP + SH84) from BNC1	
232. Fluid temperature in steam generator, primary side (TFIP + LH152) from BNC1	
233. Fluid temperature in steam generator, primary side (TFIP + LH211) from BNC1	
234. Fluid temperature in steam generator, primary side (TFIP + LH452) from BNC1	
235. Fluid temperature in steam generator, primary side (TFIP + LH668) from BNC1	
236. Fluid temperature in steam generator, primary side (TFIP + LH785) from BNC1	
237. Fluid temperature in steam generator, primary side (TFIP + SH815) from BNC1	
238. Fluid temperature in steam generator, primary side (TFIP + LH922) from BNC1	
239. Fluid temperature in steam generator, primary side (TFIP + SC668) from BNC1	
240. Fluid temperature in steam generator, primary side (TFIP + SC333) from BNC1	
241. Fluid temperature in steam generator, primary side (TFIP + LC333) from BNC1	
242. Fluid temperature in steam generator, primary side (TFIP + SC211) from BNC1	
243. Fluid temperature in steam generator, primary side (TFIP + LC211) from BNC1	

Microfiche sheet	001
244. Fluid temperature in steam generator feedwater supply (TFSC*IGFWU) from BNC1	
245. Fluid temperature in steam generator steam discharge (TFSC*IGSTM) from BNC1	
246. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+914) from BNC1	
247. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+457) from BNC1	
248. Fluid temperature in steam generator downcomer, secondary side (TFIS*D+152) from BNC1	
249. Fluid temperature in steam generator, secondary side (TFIS+SH84) from BNC1	
250. Fluid temperature in steam generator, secondary side (TFIS+SC333) from BNC1	
251. Fluid temperature in steam generator, secondary side (TFIS+SH452) from BNC1	
252. Fluid temperature in steam generator, secondary side (TFIS+LH30) from BNC1	
253. Fluid temperature in steam generator, secondary side (TFIS+LC30) from BNC1	
254. Fluid temperature in steam generator, secondary side (TFIS+LH84) from BNC1	
255. Fluid temperature in steam generator, secondary side (TFIS+LC84) from BNC1	
256. Fluid temperature in steam generator, secondary side (TFIS+LH152) from BNC1	
257. Fluid temperature in steam generator, secondary side (TFIS+LC211) from BNC1	
258. Fluid temperature in steam generator, secondary side (TFIS+LC333) from BNC1	
259. Fluid temperature in steam generator, secondary side (TFIS+LH394) from BNC1	
260. Fluid temperature in steam generator, secondary side (TFIS+LH452) from BNC1	
261. Fluid temperature in steam generator, secondary side (TFIS+LC452) from BNC1	
262. Fluid temperature in steam generator, secondary side (TFIS+LH536) from BNC1	
263. Fluid temperature in steam generator, secondary side (TFIS+LH785) from BNC1	
264. Fluid temperature in steam generator, secondary side (TFIS+LH922) from BNC1	
265. Fluid temperature in pressurizer (TF*PRZ+132) from BNC1	
266. Fluid temperature in pressurizer surge line (TF*PRZ-73) from BNC1	
267. Fluid temperature in pressurizer surge line hot leg inlet (TF*PRZ*I3D) from BNC1	
268. Metal temperature of intact loop hot leg (TMI*1) from BNC1	

Microfiche sheet 001

- 269. Metal temperature of intact loop hot leg (TMI*4) from BNC1
- 270. Metal temperature of intact loop pump suction leg (TMI*15) from BNC1
- 271. Metal temperature of intact loop pump bypass (TMI*PBB) from BNC1
- 272. Metal temperature of vessel downcomer (TMV*DC-18) from BNC1
- 273. Metal temperature of vessel downcomer (TMV*DC-223) from BNC1
- 274. Metal temperature of vessel downcomer (TMV*DC-294) from BNC1
- 275. Metal temperature of vessel downcomer (TMV*DC-435) from BNC1
- 276. Metal temperature of vessel (TMV* PR587) from BNC1
- 277. Metal temperature of vessel (TMV*SC-352) from BNC1

Microfiche sheet 002

- 278. Metal temperature of vessel (TMV*SC-212) from BNC1
- 279. Metal temperature, steam generator, on tube (TMIG + LH30) from BNC1
- 280. Metal temperature, steam generator, on tube (TMIG + LH84) from BNC1
- 281. Metal temperature, steam generator, on tube (TMIG + LH211) from BNC1
- 282. Metal temperature, steam generator, on tube (TMIG + LH668) from BNC1
- 283. Metal temperature, steam generator, on tube (TMIG + LC30) from BNC1
- 284. Metal temperature, steam generator, on tube (TMIG + LC211) from BNC1
- 285. Metal temperature, steam generator, on tube (TMIG + LC452) from BNC1
- 286. Metal temperature, steam generator, on tube (TMIG + SC452) from BNC1
- 287. Metal temperature, steam generator, on filler piece (TMIG + FP2C) from BNC1
- 288. Metal temperature, steam generator inlet leg, under external heater (TMEH*7)
from BNC1
- 289. Metal temperature, steam generator outlet leg, under external heater (TMEH*8)
from BNC1
- 290. Metal temperature, intact loop pump suction leg, under external heater (TMEH*16)
from BNC1
- 291. Metal temperature, intact loop cold leg, under external heater (TMEH*22) from BNC1
- 292. Metal temperature, vessel downcomer, under external heater (TMEH*D-237)
from BNC1

- 293. Metal temperature, vessel, under external heater (TMEH*V-360) from BNC1
- 294. Metal temperature, vessel, under external heater (TMEH*V-196) from BNC1
- 295. Metal temperature, vessel, under external heater (TMEH*V + 101) from BNC1
- 296. Material temperature, intact loop hot leg, under insulation (TEH*3) from BNC1
- 297. Material temperature, steam generator inlet leg, under insulation (TEH*7) from BNC1
- 298. Material temperature, steam generator outlet leg, under insulation (TEH*8)
from BNC1
- 299. Material temperature, intact loop pump suction, under insulation (TEH*12)
from BNC1
- 300. Material temperature, intact loop pump bypass, under insulation (TEH*PBB)
from BNC1
- 301. Material temperature, intact loop cold leg, under insulation (TEH*22) from BNC1
- 302. Material temperature, vessel downcomer, under insulation (TEH*D-237) from BNC1
- 303. Material temperature, vessel, under insulation (TEH*V-360) from BNC1
- 304. Material temperature, vessel, under insulation (TEH*V-196) from BNC1
- 305. Material temperature, vessel, under insulation (TEH*V + 101) from BNC1
- 306. Core heater temperature, Rod B-2 (THV*B2 + 39) from BNC1
- 307. Core heater temperature, Rod B-2 (THV*B2 + 195) from BNC1
- 308. Core heater temperature, Rod B-3 (THV*B3 + 354) from BNC1
- 309. Core heater temperature, Rod B-4 (THV*B4 + 322) from BNC1
- 310. Core heater temperature, Rod C-2 (THV*C2 + 321) from BNC1
- 311. Core heater temperature, Rod C-3 (THV*C3 + 79) from BNC1
- 312. Core heater temperature, Rod C-3 (THV*C3 + 231) from BNC1
- 313. Core heater temperature, Rod C-4 (THV*C4 + 187) from BNC1
- 314. Core heater temperature, Rod D-2 (THV*D2 + 254) from BNC1
- 315. Core heater temperature, Rod D-4 (THV*D4 + 179) from BNC1
- 316. Core heater temperature, Rod D-4 (THV*D4 + 352) from BNC1
- 317. Core heater temperature, Rod A-2 (THV*A2 + 112) from BNC1

Microfiche sheet	002
318. Core heater temperature, Rod A-3 (THV*A3 + 208) from BNC1	
319. Core heater temperature, Rod A-3 (THV*A3 + 291) from BNC1	
320. Core heater temperature, Rod A-4 (THV*A4 + 355) from BNC1	
321. Core heater temperature, Rod B-1 (THV*B1 + 183) from BNC1	
322. Core heater temperature, Rod B-1 (THV*B1 + 253) from BNC1	
323. Core heater temperature, Rod B-5 (THV*B5 + 252) from BNC1	
324. Core heater temperature, Rod C-1 (THV*C1 + 292) from BNC1	
325. Core heater temperature, Rod C-5 (THV*C5 + 290) from BNC1	
326. Core heater temperature, Rod E-4 (THV*E4 + 230) from BNC1	
327. Pressure in intact loop, hot leg (PI*1) from BNC1	
328. Pressure in intact loop, steam generator inlet leg (PI*5) from BNC1	
329. Pressure in steam generator tube, primary side (PIG*LH970) from BNC1	
330. Pressure in intact loop, steam generator outlet leg (PI*9) from BNC1	
331. Pressure in intact loop, pump suction leg (PI*14) from BNC1	
332. Pressure in intact loop, pump bypass (PI*PBB) from BNC1	
333. Pressure in intact loop, cold leg (PI*22) from BNC1	
334. Pressure in vessel downcomer (PV*DC-435) from BNC1	
335. Pressure in vessel lower plenum (PV*LP-442) from BNC1	
336. Pressure in vessel upper plenum (PV*UP-13) from BNC1	
337. Pressure in pressurizer steam dome (P*PRZ + 158) from BNC1	
338. Pressure in steam generator feedwater supply line (PSC*IGFDW) from BNC1	
339. Pressure in steam generator steam discharge line (PSC*IGSTM) from BNC1	
340. Differential pressure in intact loop hot leg (D-V13A*I1) from BNC1	
341. Differential pressure in intact loop hot leg (DPI*I*3C) from BNC1	
342. Differential pressure in intact loop hot leg (DI*3C-G55E) from BNC1	
343. Differential pressure in steam generator tube (DIG-55E + 92) from BNC1	
344. Differential pressure in steam generator tube (DIG55E + 462) from BNC1	

- 345. Differential pressure in steam generator tube (DIG55E + 90E) from BNC1
- 346. Differential pressure in intact loop, steam generator outlet leg (D*IG-55X*9) from BNC1
- 347. Differential pressure in intact loop pump suction (DPI*9*14) from BNC1
- 348. Differential pressure in intact loop pump suction (DPI*14*PBA) from BNC1
- 349. Differential pressure across intact loop pump suction (DPI*9*PBA) from BNC1
- 350. Differential pressure in intact loop cold leg (DPI*PBB*22) from BNC1
- 351. Differential pressure in intact loop cold leg (D*122 + VD29) from BNC1
- 352. Differential pressure across pressurizer surge line (DP*PRZ*13C) from BNC1
- 353. Liquid level, intact loop steam generator, primary side (LIP970-55E) from BNC1
- 354. Liquid level, intact loop steam generator, primary side (LIP970-55X) from BNC1
- 355. Liquid level in vessel downcomer (LVD + 29-170) from BNC1
- 356. Liquid level in vessel downcomer (LVD170-578) from BNC1
- 357. Liquid level in vessel downcomer (LVD + 29-578) from BNC1
- 358. Liquid level in vessel (LV-578-501) from BNC1
- 359. Liquid level in vessel (LV-501-105) from BNC1
- 360. Liquid level in vessel (LV-105 + 140) from BNC1
- 361. Liquid level in vessel (LV-578-13M) from BNC1
- 362. Liquid level in vessel (LV-13M + 140) from BNC1
- 363. Liquid level in vessel (LV-578 + 140) from BNC1
- 364. Differential pressure in intact loop steam generator feedwater line (DPSC*IGFDW) from BNC1
- 365. Differential pressure in intact loop steam generator steam line (DPSC*IGSTM) from BNC1
- 366. Liquid level, intact loop steam generator, secondary side (L11117S460) from BNC1
- 367. Liquid level, intact loop steam generator, secondary side (L1S1117 + 90) from BNC1
- 368. Volumetric flow rate in intact loop hot leg (QI*1) from BNC1
- 369. Volumetric flow rate in intact loop steam generator inlet leg (QI*6) from BNC1

Microfiche sheet	002
370. Volumetric flow rate in intact loop pump bypass (QI*PB) from BNC1	
371. Volumetric flow rate in intact loop cold leg (QI*22) from BNC1	
372. Volumetric flow rate in vessel downcomer (QV*DC-423) from BNC1	
373. Volumetric flow rate in vessel upper plenum (Qv*UP + 1) from BNC1	
374. Density in intact loop hot leg (RI*1B) from BNC1	
375. Density in intact loop steam generator inlet leg (RI*5M) from BNC1	
376. Density in intact loop steam generator inlet leg (RI*5I) from BNC1	
377. Density in intact loop steam generator inlet leg (RI*5C) from BNC1	
378. Density in intact loop pump bypass (RI*PBT) from BNC1	
379. Density in intact loop pump bypass (RI*PBM) from BNC1	
380. Density in intact loop pump bypass (RI*PBC) from BNC1	
381. Density in intact loop cold leg (RI*22T) from BNC1	
382. Density in intact loop cold leg (RI*22B) from BNC1	
383. Density in intact loop cold leg (RI*22C) from BNC1	
384. Density in vessel downcomer (RV*DC-72) from BNC1	
385. Density in vessel downcomer (RV*DC-260) from BNC1	
386. Density in vessel downcomer (RV*DC-456) from BNC1	
387. Density in vessel (RV*AB-6) from BNC1	
388. Density in vessel (RV*23 + 13) from BNC1	
389. Density in vessel (RV*23 + 113) from BNC1	
390. Density in vessel (RV*AB + 173) from BNC1	
391. Density in vessel (RV*23 + 183) from BNC1	
392. Density in vessel (RV*23 + 253) from BNC1	
393. Density in vessel upper plenum (RV*UP-11) from BNC1	
394. Mass flow in intact loop, steam generator inlet leg (QI*6, RI*5C) from BNC1	
395. Mass flow in intact loop pump bypass (QI*PB and RI*PBC) from BNC1	
396. Mass flow in intact loop cold leg (QI*22 and RI*22C) from BNC1	

397.	Mass flow in vessel downcomer (QV*DC-423 and RV*DC-456) from BNC1	
398.	Core heater high power bus current (IV*HIPWBUS) from BNC1	
399.	Core heater high power bus voltage (EV*HIPWBUS) from BNC1	
400.	Core heater low power bus current (IV*LOPWBUS) from BNC1	
401.	Core heater low power bus voltage (EV*LOPWBUS) from BNC1	
402.	Core heater power, high power bus, calculated (KWH*HIC) from BNC1	
403.	Core heater power, low power bus, calculated (KWH*LOC) from BNC1	
404.	Core heater power, total, calculated (KWH*TOTC) from BNC1	
405.	External heater voltage, vessel (EH*BAND357) from BNC1	
406.	External heater current, vessel (IH*BAND357) from BNC1	
407.	External heater voltage, intact loop pump suction leg (EH*BAND358) from BNC1	
408.	External heater current, intact loop pump suction leg (IH*BAND358) from BNC1	
409.	External heater voltage, intact loop cold leg (EH*BAND360) from BNC1	
410.	External heater current, intact loop cold leg (IH*BAND360) from BNC1	
411.	External heater voltage, intact loop hot leg (EH*BAND361) from BNC1	
412.	External heater current, intact loop hot leg (IH*BAND361) from BNC1	
413.	External heater power (calculated), vessel (KW*EH*VESS) from BNC1	
414.	External heater power (calculated), intact loop pump suction leg (KW*EH*ILPS) from BNC1	
415.	External heater power (calculated), intact loop cold leg (KW*EH*CL) from BNC1	
416.	External heater power (calculated), intact loop hot leg (KW*EH*HL) from BNC1	

TABLES

1.	Sequence of major operations	13
2.	System parameters for steady-state test conditions	14
3.	Loop temperature distribution with and without external heaters (case 2 condition)	15
4.	Measured and calculated system parameters for steady-state test conditions	16
5.	Data presentation for Semiscale Mod 2-A Test S-NC-1	18

EXPERIMENT DATA REPORT FOR SEMISCALE MOD-2A NATURAL CIRCULATION TEST SERIES (TEST S-NC-1)

I. INTRODUCTION

The Semiscale Mod-2A experiments represent the current phase of the Semiscale Program conducted by EG&G Idaho, Inc., for the United States Government. The program, sponsored by the Nuclear Regulatory Commission (NRC) through the Department of Energy (DOE), is part of the overall NRC water reactor research program to investigate the response of a pressurized water reactor (PWR) system to hypothesized loss-of-coolant accidents (LOCAs) and to operational transients involving the loss of mechanical primary coolant circulation. The underlying objectives of the Semiscale Program are to quantify the physical processes that control system behavior during operational transients or a LOCA, and to provide an experimental data base for assessing reactor safety evaluation models. The Semiscale Mod-2A Program has the further objective of providing support to other experimental programs in the forms of instrumentation assessment, test series time optimization, selection of test parameters, and comparative evaluation of test results.

Test S-NC-1, consisting of two parts, ANCI and BNCI, was conducted June 24, 1981, in the Semiscale Mod-2A system, as part of the Mod-2A Natural Circulation Test Series (Test Series NC). This series investigates the thermal and hydraulic phenomena of natural circulation as a principal core heat rejection mechanism during small-break loss-of-coolant accidents (LOCAs) and operational transients involving the loss of mechanical primary coolant circulation in a PWR. The series also provides thermal-hydraulic data that can be used to assess and develop computer codes that predict PWR system behavior resulting from a loss of mechanical coolant circulation. Additional objectives for this test series include evaluation of low flow, natural circulation-type measurement techniques, identification of system thermal-

hydraulic and measurement response during transitions between different modes of natural circulation, examination of the effect of noncondensable gas on natural circulation, and comparison of data to natural circulation tests performed in other facilities. Results will also aid in assessing the capability of conventional PWR process instrumentation to detect natural circulation. Due to scaling compromises in the Mod-2A system, test results may not be directly applicable to PWRs, but rather, may help identify dominant parameters for quantifying PWR natural circulation characteristics and limitations.

The primary objective of Test S-NC-1 was to investigate the effect of core power on single-phase natural circulation flow at a variety of system pressures, and with this data, to assess the code capability to calculate single-phase natural circulation and to predict system sensitivity to changes in core power and primary pressure. In particular, modeling of the steam generator and system hydraulic resistances and heat transfer models were key features for evaluation. Other objectives were to evaluate instrumentation capability to detect and quantify low, natural circulation type, flow rates and small differential temperatures and pressures, and to examine Semiscale system typicality (scaling) by comparing results in the Mod-2A system with those obtained in other systems.

Test S-NC-1 is a steady-state experiment designed to produce data that are independent of loop-to-loop instabilities that could occur during transients. It is also a separate effects test, which uses only a subsystem of the Mod-2A system so that important system parameters during natural circulation can be better examined. Hardware configuration and test parameters were scaled from, and representative of, typical PWR systems and operating conditions.

This report presents the test data in an uninterpreted but readily usable form for use by the nuclear community in advance of detailed analysis and interpretation. Section II briefly describes the system configuration, procedures, and sequence of events for Test S-NC-1; Section III gives the data graphs, comments, and supporting information necessary for interpretation of the data. A description of the overall Semiscale Program and test series, and a

more detailed description of the Natural Circulation Test Series, are in References 1 and 2. Preliminary analysis and interpretation of S-NC-1 data are presented in Reference 3. Additional information describing the data acquisition system capabilities, posttest adjustments made to the data, and the methodology used to establish uncertainty limits for the data are given in Appendix A.

II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-NC-1

The following system configuration, procedures, conditions, and events are specific to Test S-NC-1.

System Configuration

For Semiscale Natural Circulation Test S-NC-1, only part of the Mod-2A system was used, as shown in Figures 1 and 2. The test configuration consisted of the vessel with electrically heated core and external downcomer, intact loop tube-and-shell steam generator, and loop piping. The broken loop was removed and the vessel/downcomer penetrations for the broken loop hot and cold legs were capped. Normally, the Mod-2A system includes an intact loop pump; however, this was removed and replaced with a special instrumented spool piece, as shown in Figure 3. This spool piece was orificed to represent the scaled hydraulic resistance of a pressurized water reactor primary pump in the locked rotor (stopped) configuration. The vessel was modified from the normal Mod-2A configuration for these tests by removing the vessel upper head as shown in Figure 4. This was necessary to ensure a uniform heatup of the entire system and to avoid condensation on upper head structures. The vessel core consists of a 5 x 5 array of internally heated electric rods, 23 of which were powered. The rods are geometrically similar to nuclear rods with a heated length of 3.66 m and an outside diameter of 1.072 cm. All 23 heated rods were powered equally. Figure 5 shows a plan view of the vessel core.

The intact loop steam generator is a two-pass, tube-and-shell design. Primary fluid flows through vertical, inverted, U-shaped tubes, and secondary coolant passes through the shell side. The steam generator has 2 short, 2 medium, and 2 long tubes representative of the range of bend elevations in a PWR steam generator. A horizontal cross section of the intact loop steam generator tubes is shown in Figure 6. The "off center" arrangement of tubes was required to provide better volume scaling of the secondary. The same tube stock (2.22 cm OD x 0.124 cm wall) and tube spacing (3.175-cm triangular pitch) used for PWR U-tubes were used in the steam generator. Since the heat transfer area was specified by the ratio of PWR-to-Semiscale core power, the number of tubes was thereby fixed by the specified

tube diameter and lengths. Fillers were installed in the shell side to provide a more properly scaled secondary fluid volume.

Elevations of steam generator nozzles, plenums, and tubes are similar to those of a PWR; however, the steam dome is shorter than a PWR's steam dome. The steam drying equipment is of a simpler and less efficient design, but this is of little importance at the low steaming rates used in the NC test series.

Basically, the system was configured as a heat source (represented by the vessel core) and a heat sink (represented by the steam generator secondary) all connected by loop piping. External heaters were installed on the vessel and loop piping to offset environmental heat loss. The heaters are controlled by four independent, variable power supplies.

The Natural Circulation Test Series presents unique ranges of hydraulic conditions relative to the majority of previous Semiscale testing. Low flow rates are the main measurement challenge. For this purpose, turbine meters and drag screens throughout the system have been ranged as low as presently possible. The steam generator primary and secondary sides have been extensively instrumented with thermocouples. At several axial locations throughout the steam generators, pairs of primary and secondary fluid thermocouples, along with primary tube wall metal thermocouples have been attached to the primary tube walls, as shown in Figure 7. One long tube and one short tube is extensively instrumented; the middle tubes have no thermocouples installed. Tubes that are instrumented are identified on Figure 6.

Depiction of a typical fluid thermocouple installation is shown in Figure 8. The thermocouple leads are attached to the OD of the primary tubes. Penetrations of the primary tube wall by fluid thermocouples are sealed with a gold braze. The metal thermocouples are attached to the OD of the primary tube wall. A groove in the primary tube wall accepts a special thermocouple that has had the tip flattened for a distance of 0.017 cm. The thermocouple is secured in the groove with a braze. In addition to tube thermocouples, the steam dome has several fluid thermocouples, and




Figure 1. Semiscale Mod-2A system configuration for separate effect natural circulation—isometric.




Figure 2 Semiscale Mod-2A system configuration for separate effect natural circulation—schematic.




Figure 3. Semiscale Mod-2A intact loop pump bypass assembly—*isometric*.







Figure 4. Semiscale Mod-2A core vessel and downcomer—Test S-NC-1 cross section.



Test S-NC-1
INEL-A-19 594

Figure 5. Semiscale Mod-2A heated core plan view.



INEL-A-18 467

Figure 6. Semiscale Mod-2A intact loop steam generator tubes—horizontal cross section.




Figure 7. Semiscale Mod-2A intact loop steam generator thermocouple locations.




Figure 8. Semiscale Mod-2A steam generator fluid thermocouple installation.

the downcomer has fluid thermocouples at several axial positions. Other steam generator instrumentation includes primary tube (primary side) differential pressure ports allowing measurements of collapsed liquid level in the tubes. The sense lines connecting the measurement location and the differential pressure cell penetrate the side of the steam generator shell at several elevations. Differential pressure ports are located on the long primary tube that has the thermocouples as well as a middle tube and a short tube. Differential pressure ports are located at the following elevations (in cm) above the tube sheet: 970 cm in the long tube, 905 cm in the middle tube, 92, 462, and 838 cm in the short tube. The differential pressure ports are all located on the upflow side of the primary tubes. Ports are also located in the inlet and outlet plena.

References 1 and 2 give further details of the Semiscale Mod-2A system and its configuration for Test S-NC-1.

Test Preparation

In preparation for the test, the system was filled with treated demineralized water and vented at strategic points to ensure a liquid-full condition. Treated demineralized water in the steam generator feedwater tank was heated to 497 K, and the required liquid level was established in the steam generator secondary side. Before warmup, the system was checked for leakage, and system instrumentation checked for operation.

Warmup

Warmup to initial test conditions was accomplished using core power as a heat source and the steam generator secondary as a heat sink. Natural circulation flow thermally conditioned the system to specified steady-state values.

Test Sequence

For the first data point, makeup pumps were used to pressurize the primary system; for the remaining points pressurizer heaters were used to establish system pressure. For all cases, the primary pressure was maintained such that a minimum (no less than 2 K) of subcooling existed within the primary coolant system. Steam generator secondary fluid was kept at saturation throughout the test, and the steam generator tubes remained covered with water (collapsed level). Once a specified condition was met, sufficient time was allowed to establish a steady-state flow and temperature distribution. Except during the first steady-state condition, data were taken continuously.

A total of seven steady-state conditions were established, two of which involved varied external heater operation. The first low-pressure condition (0.48 MPa system pressure, 30 kW core power) was established without the use of external heaters because heat loss was very low. Next, the system was brought to a quasi-steady-state condition (3 MPa system pressure, 1.4 MPa secondary pressure, and 30 kW core power) without external heaters in operation. Following this, the vessel/downcomer external heater power was turned on to a predetermined value based on results from the Heat Loss Characterization Series, and the system allowed to reach another quasi-steady-state condition. Next, the loop external heaters were turned on and after flow and temperature stabilization the second steady-state data point was taken. While maintaining system primary fluid subcooling, by using core power, secondary feed and bleed, and the pressurizer, the third, fourth, and fifth steady-state data points were established (8.5 MPa, 10.1 MPa, and 11 MPa system pressure; 30 kW, 60 kW, and 100 kW core power), with external heater power being adjusted according to results from the Heat Loss Characterization Test Series to maintain a net adiabatic pressure boundary.

One major experimental variable was primary system pressure. Primary pressure was adjusted via pressurizer pressure to maintain adequate subcooling in the hot leg, so that single-phase natural circulation was assured. Cyclic pressurizer heater operation caused small oscillations of primary pressure during steady-state; however, the magnitude was so small that no significant effect was observed. Secondary pressure was kept at the specified value for each steady-state natural circulation case, by controlling the steam discharge rate. The liquid level in the steam generator secondary was kept above the top of the longest tube, so that steam generator tubes were entirely covered with secondary coolant throughout the test. Also throughout the test, secondary pressure was lower than primary pressure, and the steam generator acted as a heat sink. Table 1 lists the sequence of major operations on a plot time basis.

Core power was another important test variable. Core power was varied to three different values during the test, to observe the effect on single-phase natural circulation. The sharp increase in core power between 160 and 250 minutes corresponds to operational variations during the pressurization process.

Data from Test S-NC-1 is presented in the following sections. This test consisted of five steady-state natural circulation cases representing a variety of system pressures and core powers and two quasi-steady-state cases designed to obtain information on external heater effects. The first set of data, labeled ANCI, is the data taken during steady-state condition 1. The second set of data, labeled BNC1, is the data taken during the two quasi-steady-state conditions and during the final four steady-state conditions.

Tabular Data for Test Conditions

Tables 2 and 4 show conditions in the Semiscale Mod-2A system at each steady-state test condition. Table 3 compares loop temperature distributions with and without external heaters on.

Table 1. Sequence of major operations

<u>Real Time</u>	<u>Operations</u>	<u>Time After Tape Started (min)</u>
8:00	System heatup	--
11:25	Case 1 condition (ANC1) data (taken for 10 minutes)	0 to 500 seconds
13:23	Data tape start (BNC1)	0
13:54	Vessel heater on	31
14:53	Hot leg, pump suction, cold leg heaters on	90
15:02	Feeding steam generator	99
15:31	Raising primary pressure	128
15:35	Case 2 condition data (taken for 10 minutes)	132
16:04	Increased all band heater power	161
17:55	Case 3 condition data (taken for 10 minutes)	272
18:26	Case 4 condition data (taken for 6 minutes)	303
18:51	Case 5 condition data (taken for 10 minutes)	328
19:01	End of data acquisition (BNC1)	338

Table 2. System parameters for steady-state test conditions

<u>Parameters</u>	<u>ANCl</u>	<u>BNC1</u>			
	<u>Case 1</u>	<u>Case 2</u>	<u>Case 3</u>	<u>Case 4</u>	<u>Case 5</u>
Primary system pressure (MPa)	0.48	3.5	9.1	10.1	11.2
Steam generator secondary pressure (MPa)	0.16	1.35	5.8	5.8	5.8
Core power (kW)	32.7	31.4	31.9	60	99.2
Total external heater power (kW)	--	31.98	41.9	41.9	41.9
Minimum subcooling (K)	5	14	6	5	2
Hot leg temperature (K)	410	498	568	577	586
Core ΔT (K)	32	27	20	29	29
ΔT across steam generator (K)	32	30	20	28	27
Mass flow rate (kg/s)	0.21	0.29	0.32	0.40	0.47

Table 3. Loop temperature distribution with and without external heaters (case 2 condition)

Location	Temperature Distribution (± 2 K)	
	External Heaters Off	External Heaters On
Hot leg near vessel (Spool 1)	465	500
Steam generator entrance (Spool 5)	463	500
Steam generator outlet (Spool 9)	447	469
Pump replacement spool (Spool PB)	442	472
Cold leg near vessel (Spool 22)	442	470
Downcomer near bottom (Elevation-435)	437	470

a. Heater power is 19.62 kW vessel-downcomer, 3.77 kW hot leg, 6.69 pump suction, 1.9 kW cold leg.

Table 4. Measured and calculated system parameters for steady-state test conditions

Parameter	Cases (measured/calculated)				
	1	2	3	4	5
Primary system pressure (MPa)	0.48	3.5	9.1	10.1	11.2
	0.42	3.0	8.5	11.0	11.0
Steam generator secondary pressure (MPa)	0.16	1.35	5.8	5.8	5.8
	0.12	1.6	6.0	6.0	6.0
Core Power (kW)	32.7	31.4	31.9	60.0	99.1
	30.0	30.0	30.0	60.0	100.0
Minimum subcooling	5	14	6	5	2
	13	17	11	18	6
Hot leg temperature (K)	410	498	568	577	586
	404	490	561	573	585
Core ΔT (K) ^a	33	27	22	30	40
	15	15	13	23	30
Core inlet flow rate (kg/s) ^a	0.21	0.29	0.32	0.40	0.47
	0.45	0.44	0.45	0.49	0.52
Mid-plane heater surface temperature (K)	408	493	565	578	590
Steam generator liquid level (cm) ^b	998	998	998	998	998
	1015	723	975	839	817
Steam generator ΔT (K)	30	30	20	28	27
	15	15	13	23	30

a. See Reference 3 for explanation.

b. During the test, the steam generator liquid level was maintained above the top of the tubes. The minimum level was 998 cm.

III. DATA PRESENTATION

This report presents the data from Semiscale Mod-2A Test S-NC-1 with brief comment. Processing analysis serves only to obtain appropriate engineering units and to ensure that data are reasonable and consistent. In all cases, analysis assumed a homogeneous fluid in converting transducer output to engineering units.

The performance of the system during Test S-NC-1 was monitored by 276 detectors. A digital data acquisition system recorded data for Test S-NC-1 part 1 (ANC1) at an effective sample rate of 1.82 points per second per channel and for Test S-NC-1 part 2 (BNC1) at 0.455 points per second per channel.

The data are presented as graphs in engineering units, the scales selected not reflecting the obtainable resolution of the data. Reference 1 and

Appendix A describe the data processing techniques further. Figures 1 through 8 give information for interpretation of the data graphs. Table 5 groups the measurements according to type, identifies the location and range of the detector and actual recording range of the data acquisition system, comments briefly on the data, and references the detector and comments to their corresponding figure. Figures 9 through 416 (data graphs) present all the data obtained. Appendix A explains the capabilities of the data acquisition system, explains posttest data adjustments, and presents an analysis of the uncertainty associated with data measurements in the Semiscale Mod-2A System.

The data plots (Figures 9 through 416) and the appendix are on microfiche attached to the inside back cover of this report.

Table 5. Data presentation for S-NC-1

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
FLUID TEMPERATURE					
<u>Intact Loop</u>					
		0 to 1533 K	0 to 820 K		
TFI*1	Hot leg, Spool 1, 50 cm from vessel center.			9;205	
TFI*3E	Hot leg, Spool 3, port E, 270 cm from vessel center.			10;207	
TFI*4	Hot leg, Spool 4, 300 cm from vessel center.			11;208	
TFI*5	Hot leg, Spool 5, 363 cm from vessel center.			12;209	
TFI*9	Cold leg, Spool 9, 1017 cm from down-comer center.			13;210	
TFI*15	Cold leg, Spool 15, 642 cm from down-comer center.			14;211	
TFI*PB8	Cold leg, Spool PB, 210 cm from down-comer center.			15;212	
TFI*21	Cold leg, Spool 21, 138 cm from down-comer center.			16;213	
TFI*22	Cold leg, Spool 22, 48 cm from down-comer center.			17;214	
<u>Downcomer</u>					
		0 to 1533 K	0 to 820 K		
TFV*DC-18	Downcomer extension, 18 cm below cold leg center.			18;215	
TFV*DC-84	Downcomer extension, 84 cm below cold leg center.			19;216	
TFV*DC-270	Downcomer extension, 270 cm below cold leg center.			20;217	
TFV*DC-293	Downcomer extension, 293 cm below cold leg center.			21;218	
TFV*DC-436	Downcomer instrument spool, 436 cm below cold leg center.			22;219	
<u>Vessel</u>					
		0 to 1533 K	0 to 820 K		
<u>Vessel Lower Plenum</u>					
TFV*LP-552	552 cm below cold leg centerline.			23;220	
<u>Vessel Upper Plenum</u>					
		0 to 1533 K	0 to 820 K		
TFV*UPR-38	38 cm below cold leg centerline at 240°.			24;221	
TFV*UPM-13	13 cm below cold leg centerline at 180°.			25;222	
<u>Core Grid Spacers</u>					
		0 to 1533 K	0 to 1580 K		
<u>Grid Spacer 1</u>					
	490 cm below cold leg centerline, 6 cm above bottom of heated length.				
TFV*G1-6	In space defined by Columns D and E, Rows 4 and 5.			26;223	
<u>Grid Spacer 4</u>					
	370 cm below cold leg centerline, 126 cm above bottom of heated length.				
TFV*G3-126	In space defined by Columns B and C, Rows 3 and 4.			27;224	
<u>Grid Spacer 5</u>					
	330 cm below cold leg centerline, 166 cm above bottom of heated length.				
TFV*G3+166	In space defined by Columns B and C, Rows 3 and 4.			28;225	
<u>Grid Spacer 6</u>					
	290 cm below cold leg centerline, 206 cm above bottom of heated length.				
TFV*G3+206	In space defined by Columns B and C, Rows 3 and 4.			29;226	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Grid Spacer 8</u>	210 cm below cold leg centerline, 286 cm above bottom of heated length.				
TPV*AA+286	In space defined by Columns A and B, Rows 4 and 5.			30;227	
<u>Grid Spacer 9</u>	170 cm below cold leg centerline, 326 cm above bottom of heated length.				
TPV*AA+326	In space defined by Columns A and B, Rows 4 and 5.			31;228	
<u>Grid Spacer 10</u>	130 cm below cold leg centerline, 366 cm above bottom of heated length.				
TPV*AA+366	In space defined by Columns A and B, Rows 4 and 5.			32;229	
<u>Steam Generator</u>		0 to 1533 K	0 to 820 K		
<u>Intact Loop, Primary Side</u>	Between Spools 7 and 8.				
TFIP*LN30	In long tube, hot side, 30 cm above top of tube sheet.			33;230	
TFIP*SH84	In short tube, hot side, 84 cm above top of tube sheet.			34;231	
TFIP*LN152	In long tube, hot side, 152 cm above top of tube sheet.			35;232	
TFIP*LN211	In long tube, hot side, 211 cm above top of tube sheet.			36;233	
TFIP*LN452	In long tube, hot side, 452 cm above top of tube sheet.			37;234	
TFIP*LN668	In long tube, hot side, 668 cm above top of tube sheet.			38;235	
TFIP*LN785	In long tube, hot side, 785 cm above top of tube sheet.			39;236	
TFIP*SHR15	In short tube, hot side, 815 cm above top of tube sheet.			40;237	
TFIP*LN922	In long tube, hot side, 922 cm above top of tube sheet.			41;238	
TFIP*SC668	In short tube, cold side, 668 cm above top of tube sheet.			42;239	
TFIP*SC333	In short tube, cold side, 333 cm above top of tube sheet.			43;240	
TFIP*LC333	In long tube, cold side, 333 cm above top of tube sheet.			44;241	
TFIP*SC211	In short tube, cold side, 211 cm above top of tube sheet.			45;242	
TFIP*LC211	In long tube, cold side, 211 cm above top of tube sheet.			46;243	
<u>Intact Loop, Secondary Side</u>		0 to 1533 K	0 to 820 K		
TFSC*IGFWU	In feedwater line to steam generator feed ring.			47;244	
TFSC*IGSTM	In steam line from steam generator steam dome.			48;245	
TFIS*D+914	In downcomer, 914 cm above top of tube sheet.			49;246	
TFIS*D+457	In downcomer, 457 cm above top of tube sheet.			50;247	
TFIS*D+152	In downcomer, 152 cm above top of tube sheet.			51;248	
TFIS*SHR84	On short tube, hot side, 84 cm above top of tube sheet.			52;249	
TFIS*SC333	On short tube, cold side, 333 cm above top of tube sheet.			53;250	
TFIS*SH452	On short tube, hot side, 452 cm above top of tube sheet.			54;251	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Intact Loop, Secondary Side (continued)</u>					
TFIS+LH30	On long tube, hot side, 30 cm above top of tube sheet.			55;252	
TFIS+LC30	On long tube, cold side, 30 cm above top of tube sheet.			56;253	
TFIS+LH84	On long tube, hot side, 84 cm above top of tube sheet.			57;254	
TFIS+LC84	On long tube, cold side, 84 cm above top of tube sheet.			58;255	
TFIS+LH152	On long tube, hot side, 152 cm above top of tube sheet.			59;256	
TFIS+LH211	On long tube, hot side, 211 cm above top of tube sheet.			60	RNCI only.
TFIS+LC211	On long tube, cold side, 211 cm above top of tube sheet.			61;257	
TFIS+LC333	On long tube, cold side, 333 cm above top of tube sheet.			62;258	
TFIS+LH394	On long tube, hot side, 394 cm above top of tube sheet.			63;259	
TFIS+LH452	On long tube, hot side, 452 cm above top of tube sheet.			64;260	
TFIS+LC452	On long tube, cold side, 452 cm above top of tube sheet.			65;261	
TFIS+LH536	On long tube, hot side, 536 cm above top of tube sheet.			66;262	
TFIS+LH785	On long tube, hot side, 785 cm above top of tube sheet.			67;263	
TFIS+LH922	On long tube, hot side, 922 cm above top of tube sheet.			68;264	
<u>Pressurizer</u>		0 to 1533 K	0 to 820 K		
TP*PRE-132	In top of pressurizer, 132 cm above exit to surge line.			69;265	
TP*PRE-73	In surge line, 73 cm below entrance to pressurizer.			70;266	
TP*PRE*130	In surge line, at entrance to intact loop, Spool 3 port D, 214 cm from vessel center.			267	RNCI only.
METAL TEMPERATURE	Chromel-Alumel thermocouples unless specified otherwise.				
<u>Intact Loop</u>					
		0 to 1533 K	0 to 820 K		
TM1*1	Hot leg, Spool 1, 1.6 mm from pipe inside diameter (ID), 68 cm from vessel center.			71;268	
TM1*4	Hot leg, Spool 4, 1.6 mm from pipe ID, 300 cm from vessel center.			72;269	
TM1*15	Cold leg, Spool 15, 1.6 mm from pipe ID, 668 cm from downcomer center.			73;270	
TM1*PB8	Cold leg, Spool PB, 1.6 mm from pipe ID, 243 cm from downcomer center.			74;271	
<u>Downcomer</u>		0 to 1533 K	0 to 820 K		
TMV*DC-18	Downcomer extension, 18 cm below cold leg center.			75;272	
TMV*DC-223	Downcomer extension, 223 cm below cold leg center.			76;273	
TMV*DC-254	Downcomer extension, 294 cm below cold leg center.			77;274	
TMV*DC-435	Downcomer instrument spool, 435 cm below cold leg center.			78;275	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Vessel</u>					
		0 to 1533 K	0 to 820 K		
TWV*LR587	Lower plenum, 587 cm below cold leg centerline at 740°.			79,276	
TWV*SC-352	Core housing, 352 cm below cold leg centerline.			80,277	
TWV*SC-212	Core housing, 212 cm below cold leg centerline.			81,278	
<u>Steam Generator</u>					
<u>Intact Loop</u>					
		0 to 1533 K	0 to 820 K		
TWIG*LM30	On long tube, hot leg OD, 30 cm above top of tube sheet.			82,279	
TWIG*LM84	On long tube, hot leg OD, 84 cm above top of tube sheet.			83,280	
TWIG*LM211	On long tube, hot leg OD, 211 cm above top of tube sheet.			84,281	
TWIG*LM452	On long tube, hot leg OD, 452 cm above top of tube sheet.				Detector failed.
TWIG*LM648	On long tube, hot leg OD, 648 cm above top of tube sheet.			85,282	
TWIG*LC30	On long tube, cold leg OD, 30 cm above top of tube sheet.			86,283	
TWIG*LC211	On long tube, cold leg OD, 211 cm above top of tube sheet.			87,284	
TWIG*LC452	On long tube, cold leg OD, 452 cm above top of tube sheet.			88,285	
TWIG*GC452	On short tube, cold leg OD, 452 cm above top of tube sheet.			89,286	
TWIG*FP20	On filler piece number 20.			90,287	
<u>External Heaters</u>					
	Thermocouples on pipe outside surface, under an external band heater.	0 to 1533 K	0 to 820 K		
<u>Intact Loop</u>					
TMEH*7	Hot leg, Spool 7, 447 cm from vessel center.			91,288	
TMEH*8	Cold leg, Spool 8, 1082 cm from down-comer center.			92,289	
TMEH*16	Cold leg, Spool 16, 542 cm from down-comer center.			93,290	
TMEH*22	Cold leg, Spool 22, 42 cm from down-comer center.			94,291	
<u>Vessel</u>					
		0 to 1533 K	0 to 820 K		
TMEH*D-257	On downcomer, 257 cm below cold leg center.			95,292	
TMEH*V-360	Core housing, 360 cm below cold leg centerline.			96,293	
TMEH*V-196	Core housing, 196 cm below cold leg centerline.			97,294	
TMEH*V-101	Upper plenum, 101 cm above cold leg centerline.			98,295	
MATERIAL TEMPERATURE					
	Chromel-Alumel thermocouples unless otherwise specified.				
<u>External Heaters</u>					
	Thermocouples on external band heater outside surface, under insulation.	0 to 1533 K	0 to 820 K		
<u>Intact Loop</u>					
TEH*3	Hot leg, Spool 3, 174 cm from vessel center.			99,296	
TEH*7	Hot leg, Spool 7, 447 cm from vessel center.			100,297	
TEH*8	Cold leg, Spool 8, 1082 cm from down-comer center.			101,298	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Infect Loop</u>					
<u>(continued)</u>					
TEM12	Cold leg, Spool 12, 90 cm from downcomer center.			102;299	
TEM*P8	Cold leg, Spool P8, 243 cm from downcomer center.			103;300	
TEM*22	Cold leg, Spool 22, 42 cm from downcomer center.			104;301	
<u>Vessel</u>		0 to 1533 K	0 to 820 K		
TEM*D-237	On downcomer, 237 cm below cold leg center.			105;302	
TEM*V-360	Core housing, 360 cm below cold leg centerline.			303	BNC1 on/y.
TEM*V-196	Core housing, 196 cm below cold leg centerline.			106;304	
TEM*V-101	Upper plenum, 101 cm above cold leg centerline.			107;305	
CORE HEATER CLADDING TEMPERATURE					
<u>High Power Bus Heaters</u>		0 to 1533 K	0 to 1580 K		
THV*B2+39	Heater at Column B, Row 2. Thermocouples at 39 cm (90°), and 196 cm (50°) above bottom of heated length.			108;306	
THV*B2+196				109;307	
THV*B3+354	Heater at Column B, Row 3. Thermocouple at 354 cm (180°) above bottom of heated length.			110;308	
THV*B4+322	Heater at Column B, Row 4. Thermocouple at 322 cm (0°) above bottom of heated length.			111;309	
THV*C2+321	Heater at Column C, Row 2. Thermocouple at 321 cm (180°) above bottom of heated length.			112;310	
THV*C3+79	Heater at Column C, Row 3. Thermocouples at 79 cm (75°), and 231 cm (34°) above bottom of heated length.			113;311	
THV*C3+231				114;312	
THV*C4+187	Heater at Column C, Row 4. Thermocouple at 187 cm (182°) above bottom of heated length.			115;313	
THV*D2+254	Heater at Column D, Row 2. Thermocouple at 254 cm (351°) above bottom of heated length.			116;314	
THV*D4+179	Heater at Column D, Row 4. Thermocouples at 179 cm (26°), and 352 cm (270°) above bottom of heated length.			117;315	
THV*D4+352				118;316	
<u>Low Power Bus Heaters</u>		0 to 1533 K	0 to 1580 K		
THV*A2+112	Heater at Column A, Row 2. Thermocouple at 112 cm (298°) above bottom of heater length.			119;317	
THV*A3+208	Heater at Column A, Row 3. Thermocouples at 208 cm (121°), and 291 cm (270°) above bottom of heated length.			120;318	
THV*A3+291				121;319	
THV*A4+355	Heater at Column A, Row 4. Thermocouple at 355 cm (270°) above bottom of heated length.			122;320	
THV*B1+183	Heater at Column B, Row 1. Thermocouples at 183 cm (131°), and 253 cm (1°) above bottom of heated length.			123;321	
THV*B1+253				124;322	
THV*B5+252	Heater at Column B, Row 5. Thermocouple at 252 cm (22°) above bottom of heated length.			125;323	
THV*C1+292	Heater at Column C, Row 1. Thermocouple at 292 cm (0°) above bottom of heated length.			126;324	
THV*C5+290	Heater at Column C, Row 5. Thermocouple at 290 cm (180°) above bottom of heated length.			127;325	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Low Power Bus Heaters</u>					
<u>(continued)</u>					
THV*EG+230	Heater at Column E, Row 4. Thermo-couple at 230 cm (355") above bottom of heater length.			128;326	
<u>PRESSURE</u>					
<u>Intact Loop</u>					
PI*1	Hot leg, Spool 1, 60 cm from vessel center.	0 to 17.24 MPa	0 to 21.95 MPa	129;327	
PI*5	Hot leg, (steam generator inlet leg), Spool 5, 363 cm from vessel center.		0 to 21.03 MPa	130;328	
PI*LR970	Steam generator primary side, in long tube, hot side, 970 cm above top of tube sheet.		0 to 20.72 MPa	131;329	
PI*9	Cold leg (steam generator outlet leg), Spool 9, 1017 cm from downcomer center.		0 to 22.85 MPa	132;330	
PI*14	Cold leg (pump suction leg), Spool 14, 700 cm from downcomer center.		0 to 20.26 MPa	133;331	
PI*PB8	Cold leg (pump bypass leg), Spool PB, 210 cm from downcomer center.		0 to 21.76 MPa	134;332	
PI*22	Cold leg, Spool 22, 60 cm from downcomer center.		0 to 21.54 MPa	135;333	
<u>Vessel</u>					
PV*DC-435	In downcomer instrument spool, 435 cm below cold leg center.	0 to 17.24 MPa	0 to 20.04 MPa	136;334	
PV*LP-442	In lower plenum, 442 cm below cold leg centerline.		0 to 20.66 MPa	137;335	
PV*UP-13	In upper plenum, 13 cm below cold leg centerline.		0 to 21.64 MPa	138;336	
<u>Pressurizer</u>					
P*PRZ-158	In pressurizer steam dome, 158 cm above exit to surge line.	0 to 17.24 MPa	0 to 20.81 MPa	139;337	
<u>STEAM GENERATOR</u>					
<u>Intact Loop</u>					
PSC*IGFDW	In feedwater supply line to intact generator.	0 to 17.74 MPa	0 to 21.06 MPa	140;338	
PSC*IGSTM	In steam discharge line from intact generator.	0 to 6.897 MPa	0 to 8.548 MPa	141;339	
<u>DIFFERENTIAL PRESSURE</u>					
Elevation difference between transducer taps is zero unless specified otherwise.					
<u>Intact Loop</u>					
D-V13A*11	From vessel upper plenum at 13 cm (0") below cold leg center to hot leg. Spool 1, 60 cm from vessel center. Upper plenum tap is 33 cm below Spool 1 tap.	14.97 kPa	±6.82 kPa	142;340	
DI*1*30	From hot leg, Spool 1, 60 cm from vessel center to hot leg. Spool 3, port C, 204 cm from vessel center.	14.97 kPa	±7.005 kPa	341	BNCI only.
DI*3C-0538	From hot leg, Spool 3, port C, 204 cm from vessel center to steam generator entrance plenum, 55 cm below the top of the tube sheet and 488 cm from vessel center. Spool 3 tap is 185 cm below steam generator tap.	±24.87 kPa	±33.20 kPa	143;342	
DI*55E+92	From steam generator entrance plenum, 55 cm below top of tube sheet to short tube, upflow leg at 92 cm above top of tube sheet. Entrance plenum tap is 147 cm below tube tap.	±24.87 kPa	±33.78 kPa	144;343	
DI*55E+462	From steam generator entrance plenum, 55 cm below top of tube sheet to short tube, upflow leg at 462 cm above top of tube sheet. Entrance plenum tap is 317 cm below tube tap.	±24.81 kPa	±101.1 kPa	145;344	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Inert Loop</u> (continued)					
DIG55E-838	From steam generator entrance plenum, 55 cm below top of tube sheet to short tube, upflow side of apex at 838 cm above top of tube sheet. Entrance plenum tap is 893 cm above tube tap.	±124.35 kPa	±162.7 kPa		Detector failed.
DIG55E-905	From steam generator entrance plenum, 55 cm below top of tube sheet to middle tube, upflow side of apex at 905 cm above top of tube sheet. Entrance plenum tap is 960 cm below tube tap.	±124.35 kPa	±167.4 kPa	146;345	
DIG-55E55X	From steam generator entrance plenum to steam generator exit plenum, across steam generator primary side. Both taps are 55 cm below top of tube sheet.	±74.61 kPa	±101.5 kPa	147	ANCL only.
DIG*10-552*9	From steam generator exit plenum, 55 cm below top of tube sheet to cold leg, Spool 9, 1017 cm from downcomer center. Exit plenum tap is 108 cm above Spool 9 tap.	±4.97 kPa	±6.80 kPa	148;346	
DP1*9*14	From cold leg, Spool 9, 1017 cm from downcomer center to cold leg, Spool 14, 700 cm from downcomer center. Spool 9 tap is 380 cm above Spool 14 tap.	±24.87 kPa	±34.68 kPa	149;347	
DP1*14*PB8	From cold leg, Spool 14, 700 cm from downcomer center to cold leg Spool PB, port A, 402 cm from downcomer center. Spool 14 tap is 283 cm below Spool PB tap.	±24.87 kPa	±33.73 kPa	150;348	
DP1*9*PB8	From cold leg, Spool 9, 1017 cm from downcomer center to cold leg, Spool PB, port A, 402 cm from downcomer center. Spool 9 tap is 97 cm above Spool PB tap.	±12.43 kPa	±17.18 kPa	151;349	
DP1*PB8*8	From cold leg, Spool PB, port A, 402 cm from downcomer center to cold leg, Spool PB, port B, 210 cm from downcomer center. Across pump replacement orifice.	±689.50 kPa	±891.5 kPa		Detector failed.
DP1*PB8*22	From cold leg, Spool PB, port B, 210 cm from downcomer center to cold leg, Spool 22, 60 cm from downcomer center.	±24.87 kPa	±33.44 kPa	152;350	
D*122-VD29	From cold leg, Spool 22, 60 cm from downcomer center to downcomer inlet annulus, 29 cm above cold leg centerline. Spool 22 tap is 29 cm below inlet annulus tap.	±24.87 kPa	±33.47 kPa	153;351	
<u>Pressurizer</u>					
LPRZ138-25	Liquid level in pressurizer, from 138 cm above exit to surge line, to 25 cm above exit to surge line. Elevation difference between taps is 133 cm.	±12.43 kPa	±18.15 kPa		Detector failed.
DP*PRZ*13C	From pressurizer bottom, 25 cm above exit to surge line, to hot leg, Spool 3, port C. Across surge line. Elevation difference between taps is 136 cm.	±3467.5 kPa	±3442.0 kPa	154;352	
<u>Steam Generator</u>					
LIP970-55E	Primary side liquid level. From long tube, upflow side of apex, at 970 cm above top of tube sheet, to entrance plenum, 55 cm below top of tube sheet. Elevation difference between taps is 1025 cm.	±124.35 kPa	±164.3 kPa	155;353	
LIP970-55X	From long tube, upflow side of apex, at 970 cm above top of tube sheet to exit plenum, 55 cm below top of tube sheet. Elevation difference between taps is 1025 cm.	±198.96 kPa	±274.8 kPa	156;354	

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Vessel</u>					
	Liquid level.				
LVD+29-170	Downcomer inlet annulus, 29 cm above cold leg centerline to downcomer extension, 170 cm below cold leg centerline. Elevation difference between taps is 199 cm.	±24.87 kPa	±31.22 kPa	157;355	
LVL170-578	Downcomer extension, 170 cm below cold leg centerline to vessel lower head, 578 cm below cold leg centerline. Elevation difference between taps is 308 cm.	±70.61 kPa	±107.6 kPa	158;356	
LVD+29-578	Downcomer inlet annulus, 29 cm above cold leg centerline to vessel lower head, 578 cm below cold leg centerline. Elevation difference between taps is 607 cm.	±124.35 kPa	±172.5 kPa	150;357	
LV-578-501	Vessel lower head, 578 cm below cold leg centerline to lower core region, 501 cm below cold leg centerline. Elevation difference between taps is 77 cm.	±11.43 kPa	±16.97 kPa	160;358	
LV-501-105	Vessel lower core region, 501 cm below cold leg centerline to heater rod ground hub, 105 cm below cold leg centerline. Elevation difference between taps is 396 cm.	±198.96 kPa	±266.0 kPa	161;359	
LV-105+140	Vessel heater rod ground hub, 105 cm below cold leg centerline to upper plenum end cap, 140 cm above cold leg centerline. Elevation difference between taps is 245 cm.	±74.61 kPa	±117.3 kPa	162;360	
LV-578-13M	Vessel lower head 578 cm below cold leg centerline to lower section of upper plenum, 13 cm below cold leg centerline. Elevation difference between taps is 565 cm.	±124.35 kPa	±176.1 kPa	163;361	
LV-13M+140	Vessel lower section of upper plenum, 13 cm below cold leg centerline (at 180°) to upper plenum end cap, 140 cm above cold leg centerline. Elevation difference between taps is 153 cm.	±74.87 kPa	±113.28 kPa	164;362	
LV-578+140	Vessel lower head, 578 cm below cold leg centerline to upper plenum end cap, 140 cm above cold leg centerline. Elevation difference between taps is 718 cm.	±124.35 kPa	±168.4 kPa	165;363	
<u>Steam Generator</u>					
	Secondary side.				
DSFC*1GPA	Across orifice in intact loop steam generator feedwater supply line.	±198.96 kPa	±270.2 kPa	166;364	
DSFC*1G8TH	Across orifice in intact loop steam generator steam exhaust line.	±124.35 kPa	±168.2 kPa	167;365	
L111178A60	Intact loop secondary side liquid level from 1117 cm above top of tube sheet to 660 cm above top of tube sheet. Elevation difference between taps is 657 cm.	±124.35 kPa	±174.2 kPa	168;366	
L181117+90	Intact loop secondary side liquid level from 1117 cm above top of tube sheet to 90 cm above top of tube sheet. Elevation difference between taps is 1027 cm.	±124.35 kPa	±170.3 kPa	169;367	
<u>VOLUMETRIC FLOW RATE</u>					
	Turbine flowmeter, bidirectional.				
<u>Intact Loop</u>					
QI*1	Hot leg, Spool 1, 38 cm from vessel center.	±1.9 t/s to ±19 t/s	±9.0 t/s	368	BNCI only. ^c
QI*6	Hot leg (steam generator inlet leg), Spool 6, 408 cm from vessel center.	±0.16 t/s to ±1.6 t/s	±4.0 t/s	369	BNCI only. ^c
QI*15	Cold leg (pump suction leg), Spool 15, 629 cm from downcomer center.	±1.9 t/s to ±19.0 t/s	±9.0 t/s	170	ANCI only. ^c
QI*28	Cold leg (pump bypass instrument spool), Spool 28 downstream from orifice, 225 cm from downcomer center.	±0.15 t/s to ±1.5 t/s	±4.0 t/s	171;370	
QI*22	Cold leg, Spool 22, 38 cm from downcomer center.	±1.26 t/s to ±12.6 t/s	±9.0 t/s	172;371	---

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Vessel</u>					
QV*DC-423	Downcomer instrument spool, 423 cm below cold leg center.	±0.13 k/s to 41.58 k/s	±4.0 k/s	173;372	
QV*UP-1	Core exit, 1 cm above cold leg centerline.	±2.8 k/s to ±28.0 k/s	±10.0 k/s	373	BNC1 on p. 5
DENSITY					
<u>Intact Loop</u>					
		1.6 to 1600 kg/m ³	0 to 1400 kg/m ³		
RI*17	Hot leg, Spool 1, 77 cm from vessel center. T (tangential) ranges 270° to 360°. B (body) ranges 30° to 330°. C is a mathematical composite of T and B.			174	ANCI only.
RI*18				175;374	
RI*1C				176	ANCI only.
RI*5M	Hot leg (steam generator inlet leg), Spool 5 (vertical), 367 cm from vessel center. M (middle) ranges 0° to 180°. I (inside) ranges 40° to 120°. C is a mathematical composite of M and I.			177;375	
RI*5I				178;376	
RI*5C				179;377	
RI*PBT	Cold leg (pump bypass leg), Spool PB, 200 cm from downcomer center. T (top) ranges 40° to 20°. M (middle) ranges 7° to 180°. C is a mathematical composite of T and M.			180;378	
RI*PRM				181;379	
RI*PBC				182;380	
RI*22T	Cold leg, Spool 22, 73 cm from downcomer center. T (tangential) ranges 270° to 360°. B (body) ranges 30° to 330°. C is a mathematical composite of T and B.			183;381	
RI*22B				184;382	
RI*22C				185;383	
<u>Vessel</u>					
		1.6 to 1600 kg/m ³	0 to 1600 kg/m ³		
RV*DC-72	Downcomer, 72 cm below cold leg centerline. B (body) ranges 30° to 330°.			186;384	
RV*DC-260	Downcomer, 260 cm below cold leg centerline. B (body) ranges 30° to 330°.			187;385	
RV*DC-456	Downcomer, 456 cm below cold leg centerline. B (body) ranges 30° to 330°.			188;386	
RV*AB-6	Six cm above bottom of core heated length, between heater rod Columns A and B.			189;387	
RV*23+13	13 cm above bottom of core heated length, between heater rod Rows 2 and 3.			190;388	
RV*23+113	113 cm above bottom of core heated length, between heater rod Rows 2 and 3.			191;389	
RV*AB+173	173 cm above bottom of core heated length, between heater rod Columns A and B.			192;390	
RV*23+183	183 cm above bottom of core heated length, between heater rod Rows 2 and 3.			193;391	
RV*23+253	253 cm above bottom of core heated length, between heater rod Rows 2 and 3.			194;392	
RV*AB+332	332 cm above bottom of core heated length, between heater rod Columns A and B.				Detector failed.
RV*23+342	342 cm above bottom of core heated length between heater rod Rows 2 and 3.				Detector failed.
RV*UF-11	Vessel at base of core flow instrument housing, 11 cm below cold leg centerline.			195;393	
MASS FLOW RATE	Mass flow rate obtained by combining density (gamma attenuation technique) with volumetric flow rate (turbine flowmeter).	Range for mass flow is determined from ranges of individual detectors used in calculation.			

Table 5. (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Intact Loop</u>					
QI*5, RI*5C	Hot leg (steam generator inlet leg), Spool 5/5.			394	BNC1 only. ^c
QI*PB, RI*PBC	Cold leg (pump bypass leg), Spool PB.			196;395	
QI*22, RI*22C	Cold leg, Spool 22.			197;396	c
<u>Vessel</u>					
QV*DC-423, RV*DC-456	Downcomer instrument spool.			196;397	
CORE CHARACTERISTICS					
<u>High Power Bus</u>					
IV*HIPWBUS	Core current.	0 to 10,000 A	0 to 10,030 A	199;398	
EV*HIPWBUS	Core voltage.	0 to 400 V	0 to 402 V	200;399	
<u>Low Power Bus</u>					
IV*LOPWBUS	Core current.	0 to 10,000 A	0 to 9330 A	201;400	
EV*LOPWBUS	Core voltage.	0 to 400 V	0 to 402 V	202;401	
<u>Calculated Power</u>					
KW*HIC	Power for high power bus.			203;402	
KW*LOC	Power for low power bus.			204;403	
KW*TOTC	Total power for high and low power bus.			205;404	
BAND HEATER CHARACTERISTICS					
<u>Power Supply 357</u>					
EH*BAND357	Heater voltage.	0 to 200 V	0 to 250 V	405	BNC1 only.
IH*BAND357	Heater current.	0 to 300 A	0 to 400 A	406	BNC1 only.
KW*EH*VESS	Calculated power.			413	BNC1 only.
<u>Power Supply 358</u>					
	Intact loop, pump suction (Spools 13 through 16).				
EH*BAND358	Heater voltage.	0 to 200 V	0 to 250 V	407	BNC1 only.
IH*BAND358	Heater current.	0 to 500 A	0 to 400 A	408	BNC1 only.
KW*EH*ILFG	Calculated power.			414	BNC1 only.
<u>Power Supply 360</u>					
	Intact loop, cold leg (Spools 7B, 21, and 22).				
EH*BAND360	Heater voltage.	0 to 200 V	0 to 250 V	409	BNC1 only.
IH*BAND360	Heater current.	0 to 100 A	0 to 200 A	410	BNC1 only.
KW*EH*CL	Calculated power.			415	BNC1 only.
<u>Power Supply 361</u>					
	Intact loop, hot leg (Spools 1 through 12).				
EH*BAND361	Heater voltage.	0 to 200 V	0 to 250 V	411	BNC1 only.
IH*BAND361	Heater current.	0 to 150 A	0 to 200 A	412	BNC1 only.
KW*EH*HL	Calculated power.			416	BNC1 only.

a. Statements at the beginning of a measurement category regarding location and comments, range, and figure apply to all subsequent measurements within the given category unless specified otherwise.

b. Detectors that were subjected to overrange conditions during portions of the test were capable of withstanding these conditions without change in operating or measuring characteristics when the physical conditions were again within the detector range.

c. Transducer not calibrated below the stated detector range. Use data for trend identification only.

IV. REFERENCES

1. L. J. Ball et al., *Semiscale Program Description*, TREE-NUREG-1210, May 1978.
2. G. G. Loomis and K. Soda, *Experimental Operating Specification—Semiscale Mod-2A Natural Circulation Test Series (Series NC)*, EGG-SEMI-5427, April 1981.
3. G. G. Loomis, K. Soda et al., *Quick Look Report For Semiscale Mod-2A Test S-NC-1*, EGG-SEMI-5492, July 1981.

120555064215 2 ANR2
US NRC
ADM DOCUMENT CONTROL DESK
PDR
016
WASHINGTON DC 20555

EG&G Idaho, Inc.
P.O. Box 1625
Idaho Falls, Idaho 83415