



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1340, JACKSON, MISSISSIPPI 39205

March 7, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Failure to Perform Weekly
Pre-Lube of the HPCS Diesel
LER 83-054/03 L-0
AECM-83/0159

Mississippi Power & Light (MP&L) Corrective Action Request (CAR) No. 688, dated October 15, 1982, identified the failure to perform a weekly pre-lube of the HPCS diesel per Safety Evaluation Report (SER) Section 9.6.6. On February 3, 1983, MP&L determined the event was reportable under Technical Specification 6.9.1.13.c. Attached is LER 83-054/03 L-0.

Yours truly,

J.P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8303160300 830307
PDR ADOCK 05000416
S PDR

83 MAR 11 9:08
GENERAL REGIONAL
ATLANTA, GEORGIA

OFFICIAL COPY
LE 22