



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

March 4, 1983

FILE: B09-13510C
SERIAL: BSEP/83-719

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
LICENSE NO. DPR-71
DOCKET NO. 50-325
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

At 1805 on February 13, 1983, a Unit No. 1 fire barrier penetration LCO was generated on a fire barrier penetration located in the 20' elevation east wall of the Service Water Building. This was done to permit running temporary power supply cables needed for the installation of a plant modification. Due to the complexity of the work involved with the modification, the seven-day specified time frame of the LCO has been exceeded. Appropriate stationed fire watchers will remain in effect until completion of the involved work and cancellation of the subject LCO.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/mcg/LETG1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

83 MMR 9
A 9: 54
NRC REGION II
ATLANTA, GA

8303160348 830304
PDR ADCK 05000325
S PDR

OFFICIAL COPY

IE 22