NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

Attachment to AECM-83/0147
Page 1 of 1

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: M S G G S 1 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)
CON'T 0 1	REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 4 1 6 (7) EVENT DATE: 0 2 0 4 8 3 (8) REPORT DATE: 0 3 0 4 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2	On February 4, 1983, fire rated doors 1A401 and 1A302 alarmed and would not reset.
0 3	The doors were verified closed and a maintenance work authorization was written to
0 4	investigate the cause. An hourly fire watch was established in accordance with
0 5	T.S.3.7.7. The event had no effect on the health and safety of the public and did
0 6	not constitute a threat to plant safety. This is reported pursuant to T.S.6.9.1.13.b.
0 7	
0 8	

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	A B (11)	E (12)	B (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 3	—	0 5 0	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	A (25)	P 3 0 2 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0	Loose supervision switches caused the doors to alarm. The switches were adjusted
1 1	and tightened, and the doors were returned to service on February 9, 1983 (within
1 2	the seven day time limit of the action statement). This is submitted as a final
1 3	report.
1 4	

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	G (28)	0 0 0 (29)	NA	A (31)	Alarmed Condition

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

8303160403 830304
PDR ADOCK 05000416
S PDR

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

NAME OF PREPARER Ron Byrd PHONE