



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 7, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Inoperable
Fire Dams and Penetration
Seals
LER 82-126/99 X-1
AECM-83/0155

This letter submits an update to a previous report submitted on December 1, 1982. The event for which the report was submitted occurred on October 26, 1982, when several fire dams and penetration seals were broken to allow replacement of damaged cables in the Control Room. The report was submitted pursuant to Technical Specification 3.7.7.a.

All corrective action is complete. Attached is LER 82-126/99 X-1, which is a final report.

Yours truly,

J.P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

LC 22