

MISSISSIPPI POWER & LIGHT COMPANY Helping Build Mississippi

05 31 MAR 11 AS:00 P. O. BOX 1640, JACKSON, MISSISSIPPI 39205 March 7, 1983

JAMES P. McGAUGHY, JR. ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Region II 101 Marietta St., N.W., Suite 2900 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station Unit 1 Docket No. 50-416 License No. NPF-13 File 0260/L-835.0 Update Report - HPCS Diesel Generator RTD LER 82-020/03 X-1 AECM-83/0158

TE22

This letter submits an update to a previous report submitted on August 13, 1982. The event for which the report was submitted occurred on July 18, 1982, when Diesel Generator 13 was shutdown prior to completion of a functional test because of a generator RTD high temperature alarm. The event was reported pursuant to Technical Specification 6.9.1.13.c.

A review of affected procedures has determined that they are adequate to prevent a similar event to occur during surveillance testing. Attached is LER 82-020/03 X-1, which is a final report.


Yours truly, for J.P. M. Engly

JPM: sap Attachment

cc: Mr. N. L. Stampley (w/a) Mr. R. B. McGehee (w/o) Mr. T. B. Conner (w/o) Mr. G. B. Taylor (w/o)

> Mr. Richard C. DeYoung, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk (w/a) U. S. Nuclear Regulatory Commission Washington, D. C. 20555



Aember Middle South Utilities System