

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N C B E P 2 | 2 0 0 - 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE | L | 6 0 5 0 - 0 3 2 4 | 7 1 1 1 9 8 1 | 8 1 2 1 1 8 1 | 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During routine surveillance it was discovered that control room chart recorder/indicator,
0 3 | 2-CAC-AR-1263, model no. Mark II, was showing an unexpected downscale trend in drywell
0 4 | oxygen concentration. A check of the respective local primary containment atmospheric
0 5 | monitor analyzer 2-CAC-AT-1263-(1) 2, showed it was operating normally and exhibiting
0 6 | expected indications. This event did not affect the health and safety of the public.
0 7 | _____

0 8 | _____ Technical Specifications 3.3.5.3, 6.9.1.9b _____ 80

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP SUBCODE | VALVE SUBCODE
S E (11) | A (12) | C (13) | I N S T R U (14) | I (15) | Z (16)
9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 1 | | 1 2 6 | | 0 3 | | 0 |
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPR-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
B (18) | H (19) | Z (20) | Z (21) | 0 0 0 0 | Y (23) | Y (24) | N (25) | L 1 3 0 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | A slipping instrument drive cord, attributed to relieved cord tensioning from normal
1 1 | instrument operation, occurred due to a failure to perform required preventative main-
1 2 | tenance on the instrument within the specified time frame. The drive cord was properly
1 3 | tensioned and the instrument was returned to service. The involved I&C maintenance
1 4 | personnel will be counseled concerning this event. _____ 80

1 5 | FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)
E (28) | 0 7 8 (29) | NA | A (31) | Operator Surveillance
7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)
Z (33) | Z (34) | NA | NA
7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES | DESCRIPTION (39)
0 0 0 (37) | Z (38) | NA
7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES | DESCRIPTION (41)
0 0 0 (40) | NA
7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION (43)
Z (42) | NA
7 8 9 10 80

2 0 | PUBLICITY | DESCRIPTION (45)
N (44) | NA
7 8 9 10 80

8112240124 811211
PDR ADOCK 05000324
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. PASTVA, JR. PHONE 919-457-9521

LER ATTACHMENT - RO # 2-81-126

Facility: BSEP Unit No. 2

Event Date: November 19, 1981

As a result of this event, the involved I&C Maintenance personnel will be counseled on the importance of strict adherence in performing required preventative maintenance on plant equipment within the specified time frames. In addition, a review of all I&C related preventative maintenance procedures will be done to ensure they are being performed as required.