

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | A | L | J | M | F | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5  
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

REPORT SOURCE: L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 4 | 7 | 1 | 1 | 0 | 9 | 8 | 1 | 8 | 1 | 2 | 0 | 2 | 8 | 1 | 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 | At 1026 on 11/09/81, the 2B Steam Generator Pressure Instrumentation Loop to the  
3 | Hot Shutdown Panel was declared inoperable when the associated indicator (PI3371B)  
4 | failed low. Tech. Spec. 3.3.3.5, in part, requires the instrumentation loop to be  
5 | operable. Tech. Spec. 3.3.3.5 action statement requirements were met. Health/Safety  
6 | of the public was not affected.  
7 |  
8 |

9 | SYSTEM CODE: I | C | 11 | CAUSE CODE: E | 12 | CAUSE SUBCODE: G | 13 | COMPONENT CODE: I | N | S | T | R | U | 14 | COMP. SUBCODE: P | 15 | VALVE SUBCODE: Z | 16 |  
17 | LER RO REPORT NUMBER: 8 | 1 | 21 | 22 | SEQUENTIAL REPORT NO.: 0 | 4 | 7 | 24 | 26 | OCCURRENCE CODE: 0 | 3 | 28 | 29 | REPORT TYPE: L | 30 | REVISION NO.: 0 | 32 |  
ACTION TAKEN: A | 18 | FUTURE ACTION: Z | 19 | EFFECT ON PLANT: Z | 20 | SHUTDOWN METHOD: Z | 21 | HOURS: 0 | 0 | 0 | 0 | 37 | 40 | ATTACHMENT SUBMITTED: N | 23 | NPRD-4 FORM SUB.: N | 24 | PRIME COMP. SUPPLIER: N | 25 | COMPONENT MANUFACTURER: W | 1 | 2 | 0 | 47 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This event was caused by the failure of the loop power supply card. The card was  
11 | replaced and following a satisfactory functional test, the instrumentation loop was  
12 | returned to service at 2332 on 11/09/81.  
13 |  
14 |

15 | FACILITY STATUS: E | 28 | POWER: 0 | 9 | 9 | 29 | OTHER STATUS: NA | 30 | METHOD OF DISCOVERY: A | 31 | DISCOVERY DESCRIPTION: Operator Observation | 32 |

16 | ACTIVITY RELEASED: Z | 33 | CONTENT OF RELEASE: Z | 34 | AMOUNT OF ACTIVITY: NA | 35 | LOCATION OF RELEASE: NA | 36 |

17 | PERSONNEL EXPOSURES NUMBER: 0 | 0 | 0 | 37 | TYPE: Z | 38 | DESCRIPTION: NA | 39 |

18 | PERSONNEL INJURIES NUMBER: 0 | 0 | 0 | 40 | DESCRIPTION: NA | 41 |

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z | 42 | DESCRIPTION: NA | 43 |

20 | PUBLICITY ISSUED: N | 44 | DESCRIPTION: NA | 45 | NRC USE ONLY