

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | I | D | C | C | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 0 | 4 | \_\_\_\_\_ | 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 6 | 7 | 1 | 1 | 2 | 7 | 8 | 1 | 8 | 1 | 2 | 1 | 5 | 8 | 1 | 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | DURING NORMAL OPERATION, AN EXTREME HIGH DELTA-P ACROSS THE TRAVELING SCREENS WAS  
03 | DISCOVERED. THE SCREEN WASH PUMPS COULD NOT CLEAN THE SCREENS THEREFORE IT WAS  
04 | DECIDED TO REDUCE REACTOR POWER AND SHUTDOWN NO. 24 CIRC. WATER PUMP. THIS SOLVED THE  
05 | PROBLEM. HOWEVER, CONDENSER DELTA-T ROSE TO 20.5°F WHICH IS 0.5°F ABOVE E.T.S.  
06 | 2.1.1.2.3 LIMITS. POWER WAS REDUCED AS REQUIRED BY E.T.S. 2.1.1.2.4 TO 85 PERCENT.  
07 | THIS BROUGHT DELTA-T DOWN TO WITHIN T.S. LIMITS. E.T.S. 2.1.1.2.3 WAS VIOLATED FOR 13  
08 | MINUTES WITH NO RESULTING CONSEQUENCES. NO PREVIOUS OCCURRENCES OF A SIMILAR NATURE. | 9

09 | SYSTEM CODE | H | F | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | H | T | E | X | C | H | 14 | COMP. SUBCODE | D | 15 | VALVE SUBCODE | Z | 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
17 | LER/RO REPORT NUMBER | 8 | 1 | 21 22 | SEQUENTIAL REPORT NO. | 0 | 6 | 5 | 24 26 | OCCURRENCE CODE | / | 27 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32  
18 | ACTION TAKEN | X | 33 | FUTURE ACTION | Z | 34 | EFFECT ON PLANT | B | 35 | SHUTDOWN METHOD | Z | 36 | HOURS | 0 | 0 | 0 | 3 | 37 40 | ATTACHMENT SUBMITTED | N | 41 | NPRD-4 FORM SUB. | N | 42 | PRIME COMP. SUPPLIER | L | 43 | COMPONENT MANUFACTURER | 1 | 0 | 7 | 5 | 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | CLADOPHORA ACCUMULATING ON THE TRAVELING SCREENS CAUSED THE HIGH DELTA-P. TO CORRECT  
11 | THIS SITUATION NO. 24 CIRC. WATER PUMP WAS SHUT DOWN. THIS CAUSED CONDENSER DELTA-T  
12 | TO RISE ABOVE TECH. SPEC. LIMITS. REACTOR POWER WAS REDUCED TO 85 PERCENT TO BRING  
13 | DELTA-T DOWN TO WITHIN TECH. SPEC. LIMITS.  
14 | \_\_\_\_\_

15 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | OPERATOR OBSERVATION | 32  
7 8 9 10 12 13 44 45 46 80

16 | ACTIV. CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36  
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39  
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41  
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43  
7 8 9 10 80

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | \_\_\_\_\_ | 45 | \_\_\_\_\_ | 46 | \_\_\_\_\_ | 47 | \_\_\_\_\_ | 48 | \_\_\_\_\_ | 49 | \_\_\_\_\_ | 50 | \_\_\_\_\_ | 51 | \_\_\_\_\_ | 52 | \_\_\_\_\_ | 53 | \_\_\_\_\_ | 54 | \_\_\_\_\_ | 55 | \_\_\_\_\_ | 56 | \_\_\_\_\_ | 57 | \_\_\_\_\_ | 58 | \_\_\_\_\_ | 59 | \_\_\_\_\_ | 60 | \_\_\_\_\_ | 61 | \_\_\_\_\_ | 62 | \_\_\_\_\_ | 63 | \_\_\_\_\_ | 64 | \_\_\_\_\_ | 65 | \_\_\_\_\_ | 66 | \_\_\_\_\_ | 67 | \_\_\_\_\_ | 68 | \_\_\_\_\_ | 69 | \_\_\_\_\_ | 70 | \_\_\_\_\_ | 71 | \_\_\_\_\_ | 72 | \_\_\_\_\_ | 73 | \_\_\_\_\_ | 74 | \_\_\_\_\_ | 75 | \_\_\_\_\_ | 76 | \_\_\_\_\_ | 77 | \_\_\_\_\_ | 78 | \_\_\_\_\_ | 79 | \_\_\_\_\_ | 80 | \_\_\_\_\_  
7 8 9 10 68 69 80

8112240156 811215  
PDR ADOCK 05000316  
S PDR

NAME OF PREPARER G. J. PEAK PHONE (616) 465-5901 ext. 1414