



State of New Jersey  
Department of Environmental Protection and Energy

Robert C. Shinn, Jr.  
Commissioner

Division of Environmental Safety, Health,  
and, Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
CN 415  
Trenton, New Jersey 08540-0415  
Tel (609) 987-2032  
Fax (609) 987-6354

May 20, 1994

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Technical Specification Change Request No. 214

By letter dated April 6, 1994, GPU Nuclear Corporation, licensee of the Oyster Creek Nuclear Generating Station (OCNGS), submitted the subject amendment to the Nuclear Regulatory Commission. The proposed change would eliminate the OCNGS Technical Specification scram and isolation functions, initiated by a trip signal from the main steam line radiation monitors.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering reviewed the above amendment in accordance with the requirements of 10CFR50.91(b), and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager  
Bureau of Nuclear Engineering

9405270136 940520  
PDR ADOCK 05000219  
P PDR

Acc 1/10

c: Acting Assistant Director McMahon  
Radiation Protection Programs  
N.J. DEPE

A. Dromerick  
NRC Sr. Project Manager

L. Briggs  
NRC Sr. Resident Inspector

D. Chawaga  
NRC Region I State Liaison

M. Laggart, GPU Nuclear