FORM 366

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: (1)

1 G A E I H 1 (2) 0 0 - 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

1 REPORT SOURCE L (6) 0 5 0 0 0 3 2 1 (7) 1 2 0 3 8 1 (8) 1 2 1 7 8 1 (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During steady state pwr. operation the site found that the torus Vac. Relief Iso. Valve 2T48-F310 failed to close resulting in a potential loss of Prim. Cont. integrity (3.6.1.1"HNP-2"). During work per MR 2-81-4588 (due to 2T48-F310 failing to close) conditions of potential inoperability of torus/rx. bldg. DP. SW. 1 & 2T48-N210 & N211 were revealed (3.7.A.3"HNP-1" & 3.6.4.2"HNP-2"). Neither plt. oper. nor the health or safety of the public was affected. This is a non-repetitive event.

9 SYSTEM CODE S H (11) — CAUSE CODE B (12) — CAUSE SUBCODE C (13) — COMPONENT CODE I N S T R U (14) — COMP. SUBCODE S (15) — VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 — SEQUENTIAL REPORT NO. 1 2 9 — OCCURRENCE CODE 0 1 — REPORT TYPE T — REVISION NO. 0

ACTION TAKEN G (18) — FUTURE ACTION F (19) — EFFECT ON PLANT Z (20) — SHUTDOWN METHOD Z (21) — HOURS (22) 0 0 0 0 — ATTACHMENT SUBMITTED Y (23) — NPRD-4 FORM SUB. N (24) — PRIME COMP. SUPPLIER A (25) — COMPONENT MANUFACTURER B 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The cause of this event has been attributed to error in the installation of the torus/rx. bldg. pressure sensing lines, allowing water to accumulate within the lines. Standing Order 81-34 has been issued to purge the lines with air on a daily basis. Action is being taken to reroute the lines thus permitting drainage into the torus of any condensed moisture.

5 FACILITY STATUS E (28) — % POWER 0 9 9 (29) — OTHER STATUS (30) NA — METHOD OF DISCOVERY A (31) — DISCOVERY DESCRIPTION (32) Engineering Evaluation

6 ACTIVITY RELEASED Z (33) — CONTENT OF RELEASE Z (34) — AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) — TYPE Z (38) — DESCRIPTION (39) NA

8 PERSONNEL INJURIES NUMBER 0 0 0 (40) — DESCRIPTION (41) NA

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) — DESCRIPTION (43) NA

10 PUBLICITY ISSUED N (44) — DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER C. L. Coggin - Supt. Plt. Eng. Serv. PHONE 912-367-7851

8112240164 811217
PDR ADOCK 05000321
S PDR