

May 25, 1994

MFN No. 076-94 Docket No. STN 52-004

Document Control Desk U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Attention:

Richard W. Borchardt, Director

Standardization Project Directorate

Subject:

Reply to a Notice of Nonconformance,

NRC Inspection Report No. 99900403/93-01

References: Letter, P. W. Marriott (GE) to R. W. Borchardt (NRC),

Same Subject, dated December 17, 1993

The purpose of this letter is to confirm a correction to the reference letter. We advised the NRC of this correction in a telephone call between John Leatherman and Richard Borchardt, dated May 25, 1994.

The reference letter addressed NRC staff findings on the Gravity Driven Cooling System Integrated Systems Test (GIST) test program, documented in the subject report. The GE response to Nonconformance 93-01-02 stated that certain items of documentation had been placed in the Design Record File (DRF) to address Nonconformance 93-01-02. GE has determined through subsequent review that the documentation in the DRF is not as complete as represented in the report attached to the reference letter.

Specifically, it has been determined that the "as-built" facility piping drawings were not complete and that documentation of verification was insufficient. We have taken immediate action to correct this situation. The requisite information is currently being gathered, and will be included in the DRF by June 3, 1994 (including appropriate verification).

We apologize for any inconvenience which this may have caused you. We look forward to NRC closing this nonconformance in the near future.

2500000 9405270258 940525 PDR QA999 EMVGENE

MFN No. 076-94 Page 2

If you have any questions regarding this letter or the reference, please call me at (408) 925-6948 or Terry McIntyre of my staff at (408) 925-1441.

Sincerely,

P. W. Marriott, Manager Advanced Plant Technologies M/C 781, (408) 925-6948

cc: M. Malloy, Project Manager F. W. Hasselberg, Project Manager