LICENSEE EVENT REPORT

Unit 1

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-0000-00 (3) | 41111 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000327 (7) | 111881 (8) | 121781 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0200 CST on 11/18/81 with Unit 1 in Mode 1 (578 degrees F and 2235 psig)
03 auxiliary feedwater pressure control valve 1-PCV-3-122 would not operate during
04 the performance of stroke time test SI-166.1. This event resulted in entering
05 the action statement of limiting condition for operation 3.7.1.2. There was no effect
06 on public health or safety. Previous occurrences - one (reference SQRO-50-328/81141).
07
08
7 8 9 80

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	CH (11)	E (12)	B (13)	VALVEX (14)	E (15)	H (16)
	9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	81	—	142	/	03	L	—	0
	21 22	23	24 26	27	28 29	30	31	32

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0000	N (23)	N (24)	L (25)	X999
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation revealed that the servo valve located in the hydraulic system would
11 not operate due to clogged passages from contaminated hydraulic fluid. The servo
12 valve and hydraulic fluid were replaced and the system was returned to service at
13 1737 CST on 11/18/81.
14
7 8 9 80

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	100 (29)	NA	B (31)	Surveillance Test
	7 8 9	10 12	13 44	45 46	80

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA
	7 8 9	10	11 44	45 80

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	000 (37)	Z (38)	NA
	7 8 9 11	12	13 80

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	000 (40)	NA
	7 8 9 11	12 80

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA
	7 8 9	10 80

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	N (44)	NA	
	7 8 9	10 68	69

8112240249 811217
PDR ADOCK 05000327
S PDR

Name of Preparer W. D. Romine / M. R. Harding Phone (615) 842-8317