

DC-
D-2

45

JAN 17 1982

MEMORANDUM FOR: R. Lefnus, Assistant Director for Safety Assessment, NRC
 T. Speis, Assistant Director for Reactor Safety, NRC
 SUBJECT: EVALUATION REPORT ON SEP TOPIC VI-4, CONTAINMENT ISOLATION SYSTEM FOR THE PALISADES NUCLEAR POWER PLANT, UNIT 1 (DOE ID: 54-255) - REVISION 1

Enclosed is Revision 1 to our evaluation report on Topic VI-4, "Containment Isolation System" of the Systematic Evaluation Program, for the Palisades Nuclear Power Plant, Unit 1. This report takes into account the comments received from the Consumers Power Company, by letters dated August 17, 1981 and January 4, 1982. The revisions are highlighted in the right hand margin of the revision page. Based on our review of the licensee's comments, the conclusions presented in Evaluation Report remain essentially unchanged.

U.S. NUCLEAR
Thomas P. Speis

Thomas P. Speis, Assistant Director
for Reactor Safety
Division of Systems Integration

Enclosure:
As stated

CC: (w/o enc)
 R. Lefnus
 J. Kurter
 (w/enc)
 M. Russell
 W. Butler
 D. Shapaker
 S. Crowe
 J. S. Gao

Central files
CSE Rdg
TSpeis

XAV
82021B0460 B20127
ADDER 05000255



OFFICED	CONTACT	TYPE	RECEIVED	CSB:DSI	CSB:DSI	CSB:DSI	AP:DSI
SUBMISSION				JGwo:jpf	JShapaker	WButler	TSpeis
DATED				1/12/82	1/12/82	1/12/82	1/12/82

OFFICIAL RECORD COPY

Containment Systems Branch
Evaluation Report on SEP Topic VI-4,
Containment Isolation System for the
Palisades Nuclear Plant, Unit 1
Docket No. 50-255
Revision 1

I Introduction


The Palisades Nuclear Power Plant, Unit 1 began commercial operation in 1971. Since then safety review criteria have changed. As part of the Systematic Evaluation Program (SEP), the containment isolation system for the Palisades plant has been re-evaluated. The purpose of this evaluation is to document the deviations from current safety criteria as they relate to the containment isolation system. The significance of the identified deviations, and recommended corrective measures to improve safety, will be the subject of a subsequent, integrated assessment of the Palisades plant.

II Review Criteria

The safety criteria used in the current evaluation of the containment isolation system for the Palisades plant are contained in the following references:

- 1) 10 CFR Part 50, Appendix A, General Design Criteria for Nuclear Power Plants (GDC 54, 55, 56 and 57).
- 2) MUREG-75/DS7, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants (SRP 6.2.4, Containment Isolation System).
- 3) Regulatory Guide 1.11, Instrument Lines Penetrating Primary Reactor Containment.

ENCLOSURE



els up to 100 MWe) appears achievable using either MHD or high temperature turbines.

- 2 -

- 4) Regulatory Guide 1.141, Revision 1, Containment Isolation Provisions for Fluid Systems.

III Related Safety Topics

The review areas identified below are not covered in this report, but are related and essential to the completion of the re-evaluation of the containment isolation system for the Palisades plant. These review areas are included in other SEP topics or ongoing Generic Reviews, as indicated below:

- (1) III-1, Classification of Structures, Components and Systems (Seismic and Quality)
- (2) III-4.C, Internally Generated Missiles
- (3) III-5.A, Effects of Pipe Break on Structures, Systems and Components Inside Containment
- (4) III-5.B, Pipe Break Outside Containment
- (5) III-6, Seismic Design Considerations
- (6) III-12, Environmental Qualification of Safety-Related Equipment
- (7) VII-6, Containment Leak Testing
- (8) VII-2, Engineered Safety Feature System Control Logic and Design
- (9) VIII-2, Onsite Emergency Power Systems - Diesel Generator
- (10) VIII-4, Electrical Penetrations of Reactor Containment
- (11) KUREG-0737, Clarification of TMI Action Plan Requirements, Item II.E.4.2, Containment Isolation Dependability
- (12) NUREG-0660, NRC Action Plan Developed as a Result of the TMI-2 Accident, Item II.E.4.4, Containment Purging and Venting Requirements

- 3 -

IV. Review Guidelines

The containment isolation system of a nuclear power plant is an engineered safety feature that functions to allow the normal or emergency passage of fluids through the containment boundary while preserving the ability of the boundary to prevent or limit the escape of fission products to the environs that may result from postulated accidents. General Design Criteria 54, 55, 56 and 57 of Appendix A to 10 CFR Part 50 pertain to the containment isolation system of a nuclear power plant.

General Design Criterion 54 establishes design and test requirements for the leak detection provisions, the isolation function and the containment capability of the isolation barriers in lines penetrating the primary reactor containment. From the standpoint of containment isolation, leak detection provisions should be capable of quickly detecting and responding to a spectrum of postulated pipe break accident conditions. To accomplish this, diverse parameters should be monitored to initiate the containment isolation function. The parameters selected should assure a positive, rapid response to the developing accident condition. This aspect of the containment isolation system review will be addressed during the review of the post-TMI requirements approved for implementation, as stated in NUREG-0737 at Item II.E.4.2.

Leak detection capability should also be provided at the system level to alert the operator of the need to isolate a system train equipped with remote manual isolation valves. SRP 6.2.4, at Item II.11, provides guidance in this regard.

OFFICE	RI:DEPOS	RI:DEPOS	RI:EGS	RI:DRA	RI:TA		
SUMMARY	Martin:cb	Snyder	SETER	ATTOR	Heyneke		
DATED	2/10/82	811-B2	2.	(2)	701	IV	5-1

NRC FORM 310 (10-80) NUREG-0650

NUREG-0650, Item II.E.4.2

- 4 -

With respect to the design requirements for the isolation function, all non-essential systems should be automatically isolated (with manual valves sealed closed), and valve closure times should be selected to assure rapid isolation of the containment in the event of an accident. The review of the classification of systems as essential or non-essential, and the automatic isolation provisions for non-essential systems by appropriate signals, will be addressed in conjunction with the review of the post-TMI requirements as stated in NUREG-0737 at Item II.E.4.2. The closure time of the containment ventilation system isolation valves will be evaluated in conjunction with the ongoing generic review of purging practices at operating plants (see NUREG-0650 at Item II.E.4.4).

The electrical power supply, instrumentation and controls systems should be designed to engineered safety features criteria to assure accomplishment of the containment isolation function. This aspect of the review is covered under SEP Topics VII-2 and VIII-2. Also, resetting the isolation signal should not result in the automatic re-opening of containment isolation valves. This will be addressed in conjunction with the review of the post-TMI requirements approved for implementation, as stated in NUREG-0737, at Item II.E.4.2.

With respect to the capabilities of containment isolation barriers in times penetrating primary containment, the isolation barriers should be designed to engineered safety feature criteria, and protected against missiles, pipe whip and jet impingement. Typical isolation barriers include valves, closed systems and blind flanges. Furthermore, provisions should be made to permit periodic leak testing of the isolation barriers.

5/1

Post Office Box 1258, Fort Worth, Texas 76101 Telephone (817) 255-1300
B202190226 B11215
NMS LIC 30
42-0643E-C3 CF

RE
CI

- 5 -

The adequacy of the missle, pipe whip and jet impingement protection will be covered under SEP Topics III-4.C, III-5.A and III-5.B. The acceptability of the design criteria originally used in the design of the containment isolation system components will be covered in SEP Topics III-1, III-6 and III-12.

The adequacy of the leak testing program will be covered under SEP Topic VI-6. The acceptability of electrical penetrations will be covered in SEP Topic VIII-4.

GDC 55, 56 and 57 establish explicit requirements for isolation valving in lines penetrating the containment. Specifically, they address the number and location of isolation valves (e.g., redundant valving, with one located inside containment and the other located outside containment), valve actuation provisions (e.g., automatic or remote manual isolation valves), valve position (e.g., locked closed, or the position of greater safety in the event of an accident or power failure), and valve type (e.g., a simple check valve is not a permissible automatic isolation valve outside containment). Figures 1 and 2 depict the explicit valve arrangements specified in GDC 55 and 56, and GDC 57, respectively.


GDC 55 and 56 also permit containment isolation provisions for lines penetrating the primary containment boundary that differ from the explicit requirements, provided the basis for acceptability is defined. This proviso is typically invoked when establishing the containment isolation requirements for essential (i.e., safety related) systems, or there is a clear improvement in safety.

- 32 -

11								Containment Containment	Containment Containment
----	--	--	--	--	--	--	--	----------------------------	----------------------------

GENERAL DESIGN CRITERIA 55 AND 56 ISOLATION VALVE CRITERIA

MISSILE PROTECTION
INSIDE OUTSIDE



CONTAINMENT
INSIDE OUTSIDE




Figure 1

GENERAL DESIGN CRITERION 57

ISOLATION VALVE CRITERIA

MISSILE PROTECTION
INSIDE OUTSIDE

CONTAINMENT
INSIDE OUTSIDE





Fig. 5-2

Standard Review Plan (SRP) 6.2.4 at Item II.3 presents guidelines for acceptable alternate containment isolation provisions for certain classes of lines. Containment isolation provisions that are found acceptable on the "other defined basis" represent conformance with the GDC and do not constitute exceptions.

The following evaluation addresses deviations in the containment isolation provisions from the explicit requirements of the GDC.

Evaluation

The containment isolation provisions for the lines penetrating the primary reactor containment of the Palisades Nuclear Power Plant, Unit 1 are tabulated in Table 1. This information was obtained from the documents referenced in Section VII. The containment isolation provisions, as tabulated in Table 1, were evaluated against the requirements of GDC 54, 55, 56 and 57 (Appendix A to 10 CFR Part 50), and the supplementary guidance of SRP 6.2.4 (Containment Isolation System), where applicable. Deviations from the explicit requirements of GDC 54, 55, 56 and 57, and the acceptance criteria of SRP 6.2.4 are tabulated in Table 2. We have transmitted a draft evaluation to the licensee. As a result, Table 1 was revised and modified by the licensee to reflect changes in the plant. This revised evaluation report takes into account the comments and updated information received from the licensee.

Table 1 gives the licensee's penetration class designation for many of the lines penetrating containment. The isolation valve arrangements for these penetration classes are shown in Figures 3 and 4. The figures were

OFFICE	RI:DEPOS	RT:DEPOS	RI:DEPOS	RI:DRA	RI:RA		
SUMMARY	Martinict	Snyder	Seifer	A1	Haynes		
DATE	2/10/82	2-1-82	2-1-				2-13-82

G FORM 216 (10-62) MARCH 1966

OFFICIAL RECORD COPY

MAY 1971 EDITION

- 7 -

obtained from Reference 8. Following are evaluations of these penetration classes against GDC 55, 56 and 57.

Penetration Class A1

Penetration Class A1 shows influent and effluent lines open to the containment with two isolation valves in series outside containment.

GDC 56 applies to the lines in Penetration Class A1. GDC 56 specifies that one valve should be located inside containment and one valve should be located outside containment. Consequently, the isolation valving arrangement for Penetration Class A1 differs from the explicit requirements of GDC 56 from the standpoint of valve location. Locating both containment isolation valves outside containment may be acceptable if the criteria used in the design of the piping between the containment the first valve are sufficiently conservative to provide adequate assurance of integrity. This matter is discussed under SEP Topic III-1.

The following containment penetrations are included in Penetration Class A1: 1, 4, 4a, 52 and 68.

Penetration Class A2

Penetration Class A2 shows three isolation configurations that are open to the containment. GDC 56 applies to the lines in Penetration Class A2. One of the isolation configurations (i.e., the line having a locked-closed valve inside containment and a locked-closed valve outside containment) satisfies the explicit requirements of GDC 56. The following containment penetrations have this isolation configuration in Penetration Class A2: 64, 66 and 72.

- 36 -

OFFICE	025 #1	025 #1					
SUPERVISOR	Parsons	Parsons					
DATE	3/2/87	3/2/87					

OFFICIAL RECORD COPY

MARCH 1987-2000

- 8 -

The isolation configuration having a blind flange inside containment and a locked closed valve outside containment differs from the explicit requirements of GDC 56 from the standpoint of isolation barrier type. GDC 56 does not address the use of blind flanges. However, a blind flange is an acceptable isolation barrier in lieu of a valve. The basis for this appears in SRP 6.2.4 at Item II.3. Also, the locked-closed valve could be an automatic isolation valve and still satisfy GDC 56. The following containment penetrations have this isolation configuration in Penetration Class A2: 18, 18a and 27.

With regard to penetration 27 (ILRT fill line), the power operated valve MOV-P1 outside containment is verified closed monthly under surveillance procedure MO 29 of the plant Technical Specifications. Since the line is flanged and gasket inside containment, the administrative control exercised over the valve is judged to be adequate. Therefore, the valve is a sealed closed isolation valve in accordance with the guidelines of SRP 6.2.4 at Item II.3.

The isolation configuration having both a locked closed valve and a simple check valve outside containment differs from the explicit requirements of GDC 56 from the standpoint of valve location and valve type. GDC 56 specifies that one valve should be located inside containment and one valve should be located outside containment, and that a simple check valve may not be used as an automatic isolation valve outside containment. For this configuration to be acceptable, the check valve should be located inside containment. Also, the locked closed valve could be an automatic isolation valve to satisfy GDC 56.

- 37 -

TABLE 1 NOTES

SEARCHED
SERIALIZED
INDEXED
FILED

OFFICIAL RECORD COPY

- 9 -

The following containment penetrations have the above isolation configuration in Penetration Class A2: 10 and 65. A judgment regarding the acceptability of the simple check valve outside containment as a bonafide containment isolation valve will be made in conjunction with the integrated assessment of the plant.

With regard to penetration 55 (instrument air line), the actuation provisions for valve CY 1211 differ from the explicit requirements of GDC 56 in that the valve is remote manually isolated. Since the instrument air line is non-essential, valve CY 1211 should be automatically isolated.

Penetration Class B1

Penetration Class B1 shows two series isolation valves outside containment in a line coming from the reactor coolant system. As shown, one of the valves is an automatic isolation valve and the other is a normally open, manual valve. Depending on the line, however, a simple check valve or remote manual valve is used. GDC 55 applies to the lines in Penetration Class B1. GDC 55 specifies that one valve should be located inside containment and one valve should be located outside containment, with the valves being either locked closed or automatic isolation valves.

The isolation valving arrangement for Penetration Class B1, therefore, differs from the explicit requirements of GDC 55 from the standpoint of valve location, type, and actuation. Locating both isolation valves outside containment may be acceptable if piping and valve design criteria are sufficiently conservative to preclude a breach of integrity. This matter is

- 38 -

UNIT 1
OF 2

TS

PENETRATION
Satisfy
DatePENETRATION
Satisfy
DateUNIT 1
OF 2

OFFICE	HQSE DE	HGE DE	HSE/ICE	A/C DE		
SURNAME	JShaw	JShaw	Queen	Queen		
DATE	1/25/82	1/25/82	1/25/82	1/25/82		

OFFICIAL RECORD COPY

MLW: 100-122-00

- 10 -


discussed under SEP Topic III-1. The use of a local manual valve for containment isolation is not acceptable, and should be upgraded to an automatic isolation valve.

The following containment penetrations are included in Penetration Class B1, 36, 40 and 45.

For penetration 36 (reactor coolant system letdown line), the parallel power operated valves CV 2012 and CV 2122 respond to controls to maintain a prescribed backpressure in the line. Although the valve controls are designed to ramp the valves closed in response to a drop in line pressure (e.g., as caused by a LOCA), the control circuitry is not safety-grade and does not assure valve closure throughout the course of an accident. Therefore, valves CV 2012 and CV 2122 should have automatic isolation capability in response to the sensing of diverse parameters characteristic of postulated accidents. Also, the isolation actuation circuitry should be safety-grade and capable of overriding valve control circuitry for normal plant operation. For penetration 45 (charging pump discharge line), the simple check valve outside containment is an inappropriate automatic isolation valve; a judgment regarding its acceptability will be made in conjunction with the integrated assessment of the plant. Also, the actuation provisions for the air operated valve CV 2111 differ from the explicit requirements of GDC 55 in that the valve is a remote manual isolation valve. A remote manual isolation valve is provided in lieu of an automatic isolation valve because the line has a post-accident safety function (emergency core cooling) which necessitates the valve being open in the event of an accident. Consequently, automatic isolation of



VTS



- 11 -

the line is not appropriate. However, the capability does exist to remote manually isolate the line if the need to do so should arise. The actuation provisions for the valve is acceptable based on the guidelines of SRP 6.2.4, at Item II.3.

Penetration Class B2

Penetration Class B2 shows a locked closed valve inside containment and a locked closed valve outside containment in a reactor coolant system effluent line. GDC 55 applies to the lines in Penetration Class B2. The isolation arrangement satisfies the explicit requirements of GDC 55.

The following containment penetration is included in Penetration Class B2: 35.

Penetration 35 shows two relief valves (RV 3154 and RV 0401), located between the two series isolation valves inside containment, which relieve to the containment. Consequently, the relief valves also have a containment isolation function in the reverse flow direction.

Penetration Class C1

Penetration Class C1 shows two types of valve arrangements for closed systems inside containment that are missile protected; namely, a single simple check valve outs te containment for influent lines and a single automatic isolation valve outside containment for effluent lines. GDC 57 applies to the lines in Penetration Class C1. GDC 57 specifies that a single automatic, remote manual or locked closed isolation valve outside containment is acceptable, but a simple check valve is not an acceptable automatic isolation valve. The isolation valve arrangement having a

- 12 -

single simple check valve outside containment differs from the explicit requirements of GDC 57 from the standpoint of valve type.

The following containment penetrations are included in Penetration Class C1: 2, 3, 7, 8, 16 and 55.

For Penetrations 7 and 8, the main feedwater isolation valves (18"-N218R-0702 and 18"-N218R-0701, respectively) should be power operated, automatic isolation valves. In this regard, a power operated stop check valve would be acceptable. For penetrations 16 and 55, the containment isolations provisions satisfy the explicit requirements of GDC 57.

Penetration Class C2

Penetration Class C2 shows isolation valve arrangements for influent and effluent lines of closed systems inside containment that are not missile protected. The valve arrangements consist of two valves in series, outside containment.

GDC 56 applies to the lines in Penetration Class C2. GDC 56 specifies that one automatic or locked closed valve should be located inside containment and one such valve should be located outside containment; also, a simple check valve may not be used as an automatic isolation valve outside containment.

The valve arrangements of Penetration Class C2 differ from the explicit requirements of GDC 56 from the standpoint of valve location and valve type. All valve arrangements would satisfy the explicit requirements of GDC 56 if one valve was located inside containment, particularly the simple check valve.

at GDC unless very exhaustively addressed to clear strings written procedures, the R&C, and tech review staffs may become insulated from real operating experience + and feedback.

B2021B0464 B20122
CF SUBJ
L-4-2REGION CF

OFFICIAL RECORD COPY

- 13 -

GDC 56 permits isolation valve arrangements that differ from the explicit requirements provided the basis for acceptability is defined. With respect to Penetration Class C2, then, locating both isolation valves outside containment may be acceptable since missile protection is not provided inside containment. The acceptability of this is contingent on the criteria used in the design of the piping between the containment and first valve, and the first valve, which must provide adequate assurance of integrity.

The following containment penetrations are included in Penetration Class C2: 5, 6, 11, 14, 15, 25, 26, 37, 38, 40A, 40B, 41, 42, 44, 46, 47, 49, 67 and 69.

For penetrations 11, 14, 26, 27, 41, 42 and 67, the simple check valve is not an appropriate automatic isolation valve outside containment. A power operated automatic isolation valve would be acceptable. However, a judgment decision regarding the acceptability of the simple check valve will be made at the time of the integrated assessment of the plant.

Penetration 25 shows a capped test connection which should be equipped with two locked closed isolation valves in series. Penetration 44 shows a manual isolation valve (3/4"-2084) which is not depicted by the isolation valve arrangements of Penetration Class C2, and which differs from the explicit requirements of GDC 56 from the stand-point of valve actuation; the subject valve should be a power operated valve that is automatically actuated.

Office: 125
Section: 22
Date: 27
Rev. Form 3-4-68, Revision 1

OFFICIAL RECORD COPY

- 14 -

Penetration Class C3

Penetration Class C3 shows two, locked closed isolation valves in series, outside containment, for effluent lines from systems that are closed inside containment and not missile protected. GDC 56 applies to the lines in Penetration Class C3. The valve arrangements described above differs from the explicit requirements of GDC 56 from the standpoint of valve location, namely, one valve should be located inside containment. However, locating both valves outside containment may be acceptable, based on the discussion under Penetration Class C2.

The following containment penetration is included in Penetration Class C3: 33.

The following discussion pertains to those containment penetrations not covered by the Penetration Classes discussed above.

- a) Penetrations 9, 20, 24, 29, 34, 43, 57, 58, 59, 60, 61, 62, 63, 70, 71 and 73:

These containment penetrations are spares. Of these, penetrations 21, 29 and 73 show pipe caps and blind flanges being used as isolation barriers. Threaded and/or tack welded pipe caps, and blind flanges without leak testing provisions, are not suitable isolation barriers.

- b) Penetrations 12 and 13:

These containment penetrations satisfy the explicit requirements of GDC 56, and are acceptable. However, with respect to the test, vent and drain lines, pipe caps are not suitable isolation barriers; two locked closed isolation valves in series should be provided for



- 15 -

these lines. Also, the flow element located between the isolation valves at penetration 13 should be moved downstream of the outboard isolation valves, or the licensee should justify that the flow element is an acceptable isolation barrier.

c) Penetrations 17 and 48:

These two containment penetrations serve the containment pressure instrumentation (8 lines). Since signals for the actuation of engineered safety features are derived from this instrumentation, it is imperative that these lines be open and remain open. Consequently, power-operated valves, which could potentially spuriously close, are not provided in these lines.

The instrument lines, however, are provided with test connections that are only capped. Again, pipe caps are not suitable isolation barriers; two locked closed isolation valves in series should be provided in each test line.

d) Penetrations 19, 50 and 51:

These containment penetrations are the personnel air lock, emergency access air lock and equipment hatch, respectively. Several lines are associated with these penetrations that are equipped only with pipe caps for isolation barriers. Pipe caps are not suitable isolation barriers and should be replaced with locked closed manual valves or blind flanges that are leak testable.

rationale for accepting the isolation provisions of the emergency sump recirculation lines appears in SRP 6.2.4, at Item II.3.

h) Penetrations 30 and 31:

With regard to penetrations 30 and 31 (containment spray pump discharge lines), the actuation provisions for the power operated valves CV-3001 (penetration 30) and CV-3002 (penetration 31) differ from the explicit requirements of GDC 56 in that they are remote manual isolation valves. Remote manual isolation valves are provided in lieu of automatic isolation valves because the lines, which are part of the containment spray system, have a post-accident safety function (depressurization of the containment following a pipe break accident) which necessitates their being opened in the event of an accident. Consequently, automatic isolation of these lines is not appropriate. However, the capability does exist to remote manually isolate these lines if the need to do so should arise. The actuation provisions for these valves are acceptable based on the guidelines of SRP 6.2.4, at Item II.3.

i) Penetracion 39:

For penetration 39, the simple check valve outside containment is replaced with a blank flange during plant operation. To be an acceptable isolation barrier, the blank flange should be leak testable.

testing equipment was available. In order to obtain review approval, the PW had to negotiate a TS requiring the mechanical shutter testing commence at a future, indicated date.

- 16 -

CONTAINMENT ISOLATION SYSTEM PENETRATION CLASSES





Figure 3

CONTAINMENT ISOLATION SYSTEM PENETRATION CLASSES



LEGEND

- MANUAL VALVE NORMALLY OPEN
- MANUAL VALVE LOCKED CLOSED
- CHECK VALVE
- || BLIND FLANGE

- ISOLATION SIGNAL
RMC SIGNAL
- AIR OPERATED WITH
REMOTE MANUAL
CONTROL AND AUTO-
MATIC ISOLATION

Figure 4

JAMES L. NELLIGAN
STAFF SENIOR MEMBER

ASSISTANT TO THE CHIEF OF STAFF
FOR DEFENSE POLICY
WHITEHOUSE OFFICE BUILDING
WASHINGTON, D.C. 20500
(202) 453-0800

Congress of the United States

ARMED SERVICES COMMITTEE
SUBCOMMITTEE
PEACEKEEPING
INVESTIGATION

EXECUTIVE COMMITTEE OF THE
REPUBLICAN STUDY COMMITTEE

- 20 -

VII Conclusions

The following summarizes the deviations from review guidelines that have been identified and described in Section V of this report:

1. The isolation valving arrangements of the following containment penetrations do not meet the requirements of GDC 55 or 56 from the standpoint of valve location: Penetrations 1, 4, 4a, 10, 11, 21, 21a, 25, 26, 28, 30, 31, 33, 36, 37, 38, 39, 40, 40a, 40b, 41, 42, 44, 45, 46, 47, 48, 49, 52, 52a, 52b, 56, 65, 67, 68 and 69.

The isolation valves in these penetrations are located outside containment. The acceptability of this is contingent on the acceptability of the piping design criteria. Also, the licensee should discuss the unique characteristics of the valves closest to the containment to terminate valve shaft or bonnet seal leakage, or the provisions in the plant for control of leakage.

2. The isolation valves of the containment penetration numbers listed below differ from the explicit requirements of GDC 55, 56 and 57 from the standpoint of valve type by using one check valve in series with other type isolation valves located outside containment: Penetrations 7, 8, 10, 11, 14, 26, 30, 31, 37, 39, 41, 42, 45, 65 and 67.

A simple check valve located outside containment is not an appropriate automatic isolation valve. The judgment regarding its acceptability will be made in conjunction with the integrated assessment of the plant.

Carlton Kammeyer, Director
December 22, 1981
Page 2

All correspondence relative to this situation should be directed to the Illinois District Office.

- 21 -

For penetrations 7 and 8, the main feedwater line, those check valves should be power operated, automatic isolation valves.

3. The isolation barriers in the containment penetrations listed below differ from the explicit requirements of GDC 55, 56 and 57 from the standpoint that pipe caps or blind flanges are used as containment isolation barriers.

Penetrations having pipes or test connections capped outside containment: 13, 17, 17A, 21, 21A, 22, 27, 28, 29, 35, 39, 48 and 73;

Penetrations having blind flanges inside containment: 18, 27, 29 and 73; or outside containment: 1, 4 and 39.

A blind flange inside or outside containment is an acceptable isolation barrier in lieu of an isolation valve if the blind flange is leak testable.

Pipe caps used in lines penetrating containment or test connections are not acceptable isolation barriers and should be replaced with locked closed valves or blind flanges that are leak testable.

There are some penetrations equipped with pipe caps, such as penetrations 21, 29 and 73. To be acceptable, the pipe cap should be fully welded with the same quality as the containment weld, or replaced with a blind flange that is leak testable.

Contact:
C. E. Rossi
32714n

- 1/25/82 1/29/82
F Rose
1/29/82 1/29/82

OFFICIAL RECORD COPY

- 22 -

4. The power operated valves CV-3001 (penetration 3C) and CV-3002 (penetration 3I) of the containment spray pump discharge lines differ from the explicit requirement of GDC 56 from the standpoint of valve actuation. Remote manual isolation valves are provided instead of automatic isolation valves because the systems have a post-accident safety function which necessitates their being opened in the event of an accident. The actuation provision for these valves are acceptable based on the guidelines of SRP 6.2.4, at Item II.3.
5. The containment sump suction lines which are part of the ECCS and the containment heat removal system have post-accident safety functions. Therefore, automatic isolation of these lines (penetrations 53 and 54) is not desirable; remote manual isolation valves are acceptable.
6. Penetration 44 shows a manual isolation valve (3/4"-20E4) in series with an air operated isolation valve, which differs from the explicit requirements of GDC 56 from the standpoint of valve acuation. This manual valve should be a power operated automatic isolation valve.
7. There are several lines associated with the following penetrations which are equipped with pipe caps: the personnel air lock (penetration 19); emergency access air lock (penetration 50); and equipment hatch (penetration 51).

These pipe caps are not suitable isolation barriers and should be replaced with locked closed manual valves or blind flanges that are leak testable.

Dentist file

B. GDC 55 and 56 specify that automatic isolation valves should, upon loss of actuating power, take the position that provides greater safety. The position of a isolation valve for normal and shutdown operating conditions, and post-accident conditions, depends on the fluid system function. In the event of power failure to a valve operator, the valve position should be consistent with the line function. In this regard, separate power supplies for isolation valves in series may be required to assure the isolation of non-essential lines. The licensee has provided information (see Table I) on the position of isolation valves, whether or not the line is essential and the isolation signals for each isolation valve. This information shows that automatic isolation valves assume positions of greater safety on loss of actuating power and, therefore, GDC 55 and 56 are satisfied.

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT #1

TABLE I

PAGE 1 OF 13

PENETRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PIPE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC	POSITION		ESS- EN- TIAL	ACTUA- TION	REMARKS		
						PIPE MATERIAL	PIPE DN	POST LOCAT.	NBR FAIL.			
1	Purge Air Supply (40" #)	A1	CV1807 CV1808 S01VAR	AO B/PF VLV AO B/PF VLV MAN OL TRIT VLV TRIT CMMR	X X X X	SC SC SC CAP	o/c o/c o -	C C C -	CIR CIR -	Blank Flanged; Vent. Syst. Valves Presently Not Used in Modes 1-4		
2	Main Btu Line (Btu/PSIA) (40" #)	C1	CV0510 H010510A	POD CHKE VLV NO B/PD/DO VLV	X X	SC SC	C C	C C	C C	LOW R/D PRESS SW	Loss of Air, CV-0510 Remains in Position Due to Cross Con- nections with High Press Air and Accumulators	
3	Main Btu Line (Btu/PSIA) (40" #)	C1	CV0501 H010501A	POD CHKE VLV NO B/PD/DO VLV	X X	SC SC	C C	C C	C C	LOW R/D PRESS SW	Loss of Air, CV-0501 Remains in Position Due to Cross Con- nections with High Press Air and Accumulators	
4	Purge Air Exhaust (40" #)	A1	CV1803 CV1805 CV1806 S01VAR	AO B/PF VLV AO B/PF VLV AO B/PF VLV MAN OL TRIT VLV	X X X X	SC SC SC SC	o/c o/c o/c o	C C C -	C C C -	CIR CIR CIR -	Blank Flanged; Vent. Syst. Valves Presently Not Used in Modes 1-4	
4a	Purge Air Exhaust Sample Line (1" #)	A1	100VAR 101VAR S01VAR	MAN GA VLV MAN GA VLV MAN OL TRIT VLV TRIT CMM / w CAP	X X X X	LC LC LC C	C C C -	- - -	- <td>-</td> <td>-</td> <td>-</td>	-	-	-
5	R/R (PSOA) Bottom Blow Down (2" #)	C2	CV0767 CV0771 S67061	AO ANGLE VLV AO ANGLE VLV MAN OL TRIT VLV TRIT CMM / w CAP	X X X X	SC SC SC C	C C C -	C C C -	C C C -	CIR CIR -	-	
6	R/R (PSOA) Bottom Blow Down (2" #)	C2	CV0768 CV0770 S67061	AO ANGLE VLV AO ANGLE VLV MAN OL TRIT TRIT CMM / w CAP	X X X X	SC SC SC C	o o o -	o o o -	o o o -	CIR CIR -	-	
7	Feedwater to R/R (PSOA) (10" #)	C1	746PM S0108-704 101 82108-702	MAN OL VLV CHPK VLV CHPK VLV	X X X	SC SC SC	C C C	- - -	- T T	REVAP REV	Aux PW Main PW	

CONTAINMENT IGNITION SYSTEM SIP REVIEW ITEMS
PLANT: PAI-1A1E'S NPP UNIT #1

JAN[L]

PAGE 9 OF 11

PLANT NO.	SYSTEM NAME AND SERVICE LINE SITE	PIPE CLASS NO.	VALVE TYPE OR DESCRIPTION	LOCATION LOC	POLE NO.	MAIN HAL. NO.	MAIN LOCA. HAL.	LESS-ACTUA- TION THAL.	REMARKS	
8	Pneumatic to BIO (EVRA)	C1 16" 821Ra-701 821Ra-702	147PV	HAN GI. MAIN VLV CIRCUIT VLV CIRCUIT VLV	X	LC 0 C	C 0 C	-	REVIS REVAP Main P Aux PV	
9	Diaphragm	-	-	-	-	-	-	-	-	
10	Service Air (16")	A2	120CAR 120CAR 120CA	HAN DA VLV CIRCUIT VLV HAN GI. TRIP VLV TEST CIRCUIT CAP	X	LC 0 C C	C 0/C C C	-	REVIS REVAP	
11	Condensate to Shield Cooling Dome Tank (16")	C2	C100 YO KOICHE SWATRI SWARD	AO DA VLV CIRCUIT VLV HAN GI. TRIP VLV HAN GI. TRIP VLV TEST CIRCUIT CAP	X	0 LC LC C	0/C C C C	-	CIR REVAP	
12	Service Water Supply (16")	-	COOL C100/9 C100/8 C100/7 C100/6 C100/5 STRAIN STRAIN STRAIN STRAIN STRAIN STRAIN 246CN 247CN	AC BUPP VLV AC BUPP VLV AC BUPP VLV AC BUPP VLV HAN DA VLV	X	0 X X X X X X X X X X X X	0 0 0 0 LC LC LC LC LC LC LC LC	0 0 0 0 C C C C C C C C	-	MAR
13	Service Water Return (16")	-	COOL C120RN C100/7 C100/1 C100/3 C100/1 C100/6 C100/1 C100/7 C100/2	AC BUPP VLV MAIN GI. TEST VLV AC BUPP VLV AD GI. VLV AC BUPP VLV AD GI. VLV AC BUPP VLV AD GI. VLV AC BUPP VLV AD GI. VLV	X	LC 0 X X X X X X X X	C 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0	-	MAR
										813 Trips Normal Fan Which In Turn Opens Valve

TABLE I

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT #1

PAGE 3 OF 31

PERFORATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PPIPE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC	NORMAL POSITION	TEST POSITION	TEST LOC A	TEST FAIL	ESS-EN-TIAL	ACTUA-TION	REMARKS
14	Component Cooling Water In (10 ⁴ #)	C2	CV0910 257-0910CC 907CC -	AC BITE VALV COPPER VALV MAN OIL TEST VALV TEST CMM / w CAP	X X X X	NO O LC C	NO O LC C	C C C C	O - - -	N	BIR BIR-P -	Auto Reopen on BIR Reset
15	Component Cooling Water Out (10 ⁴ #)	C2	CV0911 CV0910 907CC -	AC BITE/HD OP AC BITE/HD OP MAN OIL TEST VALV TEST CMM / w CAP TEST CMM / w CAP	X X X X X	NO NO LC C C	O O C C C	C C C C C	AE AE - - -	N	BIR BIR	Auto Reopen on BIR Reset CV-0911 & 0910 has Accumulator for loss of Air
16	RIN (RHOA) Surface Blow Down (2 ⁴ #)	C1	CV0719	AO ANHLR VALV	X	O	O/C	C	C	N	CIR	
17	Containment Pressure Instrumentation (k-4 ⁴ #)	N/A	1802 1802A 1802B 1802C 1804 1804A 1804B 1804C 1812 1812A 1812B 1812C 1814 1814A 1814B 1814C		X X X X X X X X X X X X X X X X X	LO O C O O O C C O C O O C C O C C	O O C O O O C C O C O O C C O C C	O O C O O O C C O C O O C C O C C	- - - - - - - - - - - - - - - - -	Y		PI-1802 (BIR & CIR Initiation) PI-1802A (BIR & CIR Initiation) PI-1804 (BIR & CIR Initiation) P-A-1804 (BIR & CIR Initiation) PT-1812 PT-1812A PT-1814
17a	Containment Dump Level Instruments		1814E 61800-NW 1814F 1814G TEST / w CAP		X X X X X	LO C LC C CAP	O C C C C	O C C C C	- - - - -	N		

OFFICIAL RECORD COPY

TABLE 1

(CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT #1

PAGE 1 OF 11

1

卷之三

BIBLIOTECA DE LA UNIVERSIDAD
CENTRAL DE VENEZUELA

TABLE I

CONTAINMENT ISRATION SYSTEM SEP REVIEW ITEMS

PAGE 3 OF 13

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT 2

TABLE I

PAGE 6 OF 11

LINE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PIPE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION DE IC	NOM- INAL SIZE	POSITION	NVR FAIL.	ESS- EN- TIAL	ACTUA- TION	REMARKS
							SHUT IN	SHUT OUT	POSS LOCA		
28	Containment Air Sample Line (4" #)		140 VAV	TROT CAP	X	10	O	O	-	S	
			141 VAV		X	10	C	O	-	S	
			142 VAV		X	10	C	O	-	S	
			140 VAV		X	10	C	O	-	S	
			-		X	C					
29	Capped Spore	-	-	PIPE FLANGE PIPE END /W CAP	X	C				S	
30	Containment Spray	X	CV3001	AO GL VLV	X	NC	C	O	O	T	CHP
			3258	MAN GATE VLV	X	10	O	O	-		
			3276	CHECK VLV	X	C	C	O	-		
			334423	GLOBE VLV	X	10	C	C	-		
			-	TROT CONN /W CAP	X	C	C	C	-		
31	Containment Spray	X	CV3002	AO GL VLV	X	NC	C	O	O	T	CHP
			3259	MAN DA VLV	X	10	O	O	-		
			3216	CHECK VLV	X	C	C	O	-		
			321723	MAN GL VLV	X	10	C	C	-		
			324623	H GL TROT VLV	X	10	C	C	-		
32	Low Pressure Safety Injection (12" #)	X	MO3008	MO GL VLV	X	NC	C	O	AI	T	RIB
			310193	CHECK VLV	X	C	C	O	-		RIB
			310310	MO GL VLV	X	NC	C	O	AI		RIB
			311023	CHECK VLV	X	C	C	O	-		RIB
			MO3012	MO GL VLV	X	NC	C	O	AI		RIB
			311393	CHECK VLV	X	C	C	O	-		RIB
			MO3014	MO GL VLV	X	NC	C	O	S		015
			314023	CHECK VLV	X	C	C	O	-		RIB
			316193	MAN DA VLV	X	10	C	C	-		
			3196	MAN DA VLV	X	NO	O	O	-		
			3197	MAN GL VLV	X	NO	O	O	-		
			CV3006	AO GL VLV	X	NO	O	O	O/C		MAN
			CV3025	AO GL VLV	X	NC	O	C	-		MAN
			3116	MAN DA VLV	X	C	C	C	-		
			310023	MAN DA VLV	X	O	O	O	-		
			310123	MAN DA VLV	X	O	O	O	-		

PT-030T
PT-030T

62

with remote manual isolation valves. See E.C.D. at Item 11.11.1 for codes guidance in this regard.

- 30 -

TMI-1

CONTINUOUS INSPECTION SYSTEMS FOR REINFORCED THERMOSET

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT #1

TABLE I

PAGE 8 OF 11

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION IN SC	WIR- ING MATERIAL	POSITION IN PIPE LINE	POS/ POST LOCA	PUR- CHASED PIPE	ES- SEN- TIAL	ALIHA- TION	REMARKS
36 cont.	Isolation To Purification Inn Exchanger (1 1/2")	B1	2140A CV2012 2140B CV2122	MAN GA VLV AO GL VLV MAN GA VLV AO GL VLV	X X X X	WC WC WC WC	O O O C	O O/C O C	- C - C	N		
37	Primary System Drain Pump Recirc (1 1/2")	C2	CV1001 K0101N 5020NN -	AO GL VLV CHECK VLV MAN GL TEST VLV TEST COWL /W CAP	X X X X	WC C C C	C C C C	C C C -	C -	N	C18	
38	Condensate Return From Steam Heating Units (2")	C2	CV1501 CV1502 5021VA - -	AO GA VLV AO GA VLV MAN GL TEST VLV VENT COWL /W CAP TEST COWL /W CAP	X X X X X	WC WC C C C	O/C O/C C C C	C C C -	C -	N	C18	
39	Containment Heating System (4")	X	CV1503 - 5011VA - -	AO GA VLV CHECK VLV MAN GL TEST VLV TEST COWL /W CAP VENT COWL /W CAP	X X X X X	WC C C C C	C C C -	C -	C -	N	C18	Check Valve Replaced w/Blank Flange When At Power
40	Fri-Cooling Syst. Sample Line (5")	B1	CV1910 CV1911 1170A 1170B	AO GL VLV AO GL VLV MAN GL TEST VLV MAN GL TEST VLV TEST COWL /W CAP	X X X X X	O/C O/C C C C	O/C O/C C C C	C C C -	C -	N	C18	
40a	Hydrogen Monitoring Return Line (Deionizer Room) (5")		BY-251KA BY-251KB 129M0R -	SOLENOID SOLENOID MAN GL VLV TEST COWL /W CAP	X X X X	C C C C	C C C C	O/C O/C C -	C -	N	MAN MAN	
40b	Hydrogen Monitor Supply Line (Deionizer Room) (5")		BY-2512A BY-2512B 129M0R -	SOLENOID SOLENOID MAN GL VLV TEST COWL /W CAP	X X X X	C C C C	C C C C	O/C O/C C C	C -			

TABLE I

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PAISADES NPP (NFT-B)

PAGE 8 OF 11

PENETRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PIPE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC	POSITION				ESS-INITIAL	ACTUATION	REMARKS
						HOR-MAL	SHUT-DOWN	POST-LOCA	MAN FAIL			
41	Degasser Pump Discharge (3" #)	C2	CV1004 401004 401005 -	AO GL VLV CHECK VLV MAN GL TRIT VLV TRIT CMM /W CAP	I I I I	NO NO LC C	O O C C	C C C C	C - - -	N	CIB	
42	Deionized Water To Quench Tank (2" #)	C2	CV0155 WD155B 1126PC	AO GL VLV CHECK VLV MAN GL TRIT VLV TRIT CMM /W CAP	I I I I	NO C LC C	O C C C	C C C C	C - - -	N	CIB	
43	Spare											
44	Controlled Bleed Off From RCP's (1 1/4" #)	C2	CV20A3 20A4 20A1 20A1A -	AO GL VLV MAN GL VLV MAN GA TRIT VLV MAN GA TRIT VLV TRIT CMM /W CAP	I I I I I	NO NO LC LC C	O O C C C	C O C C C	C - - - -	N	CIB	
45	Charging Pump Discharge (2" #)	B1	2110 CV2111	CHECK VLV AO GL VLV (W/HD OPERATOR)	I I	O NO	O O	O O	O	T	-	NAR
46	Containment Vent Header (4" #)	C2	CV1101 CV1102 511002 -	AO GL VLV AO GL VLV MAN GL TRIT VLV TRIT CMM /W CAP	I I I I	NO NO LC C	O O C C	C C C C	C C - -	N	CIB	
47	Primary System Drain Tank Pump Return	C2	CV1002 CV1007 50200M -	AO GL VLV AO GL VLV MAN GL TRIT VLV TRIT CMM /W CAP	I I I I	NO NO LC C	O O C C	C C C C	C C - -	N	CIB	
48	Containment Pressure Instrumentation (4-1/2" Lines)	I	V-1001 V-1001A V-1001B V-1001C V-1003 V-1003A	MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV	I I I I I I	LD LD LC LC LD LD	O O C C O -	O O C C O -	- - - - - -		PI-1001 (RIB & CIB Initiation) PI-1001A (RIB & CIB Initiation) PI-1003 (RIB & CIB Initiation) PI-1003A (RIB & CIB Initiation)	

Figure 1

- 33 -

PAGE 10 OF 13

TABLE I

CONTINUATION OF SYSTEMS IN SRS NPSR UNIT #1

ITEM NUMBER	ITEM DESCRIPTION	VALVE CLASS NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION IN FC	POSITION ACTUAL STATE ON FAIL		FSS- UP IN IN TMR LOC FAIL	REMARKS
					IN NORM	OUT NORM		
48	Containment Pump Line (100% NPSR)	X	V-1001B V-1001C V-1005A V-1005B V-1005C V-1013 V-1013A V-1013B V-1013C	MAN OA VLV MAN OA VLV	I	I	I	PP-1005 PP-1005A PP-1005B
49	Clean Oil to Receiver Tank Circulation Pump Function (5°F)	X	CV1016 CV1016 SV1016 SV1016 SV1016	AD OIL VLV AD OIL VLV TEST OIL / W CAP TEST OIL / W CAP MAN ISOLIN VLV	W	O	O	AUTO BY C18
50	Emergency Access Isolating Valve	X	-	FRONT PIVOT VLV FRONT TURK FRONT PIVOT VLV FRONT DAIR FRONT TURK MAN G TYPE VLV TEST CMM / W CAP O-RING TEST CMM	X	X	RC RC RC RC RC RC RC RC	N° Valve Between The Seats Capped
51	Equipment Door	X	-	O-RING TYPE CYLINDER / W CAP	X	O	O	
52	Containment Pump Drain to Rump Tank	A1	CV1103 CV1104 SV1016	AD OIL VLV AD OIL VLV TEST CMM VLV	RC RC RC RC RC RC	O O O O O O	818 CMH	

- 5 -

(P&ID)
100%

TABLE I

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PAULSADIES NPP UNIT #1

PAGE 11 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC NOR- MAL	POSITION			ESS- EN- TIAL	REMARKS	
						SHUT DN	POST LOCA	MVR FAIL			
52a	Containment Dump Level Instrumentation (3/8" #)		618DNW	MAN GA VLV	X	LO	O	O	-	LT-0382	
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			618DNW	MAN GA VLV	X	LC	C	C	-		
			-	3 TEST CORM/W/CAP	X	C					
52b	Containment Dump Level Instrumentation		619DNW	MAN GA VLV	X	LO	O	O	-	LT-0383	
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			619DNW	MAN GA VLV	X	LC	C	C	-		
			-	3 TEST CORM/W/CAP	X	C					
53	Containment Spray Pump Guttle	X	CV1020 31020	AIR OP VLV MAN GL TRIT VLV TEST CORM /W CAP	X X X	NC LC C	O C C	O C C	AT -	T BIRWT LL	Post Eoca Open On Bire LL
54	Containment Spray Pump Guttle	X	CV1010 31610	AIR OP VLV MAN TRIT VLV TEST CORM /W CAP	X X X	NC LC C	O C C	O C C	AT -	T BIRWT LL	Post Eoca Open On Bire LL
55	H10 (H500) Surface Blowdown (2")	C1	CV0138	SO VLV W/ HAND OPERATOR	X	O	O/C	C	C	R	CIB
56	Containment Dump Level Instrumentation		606A-VAR 6198-NRW 606B-VAR 606C-VAR		X X X X X	LO C LC C C	O C C C C	O C C C C	-	LT-0381	
57	Open	-		TEST CORM /W CAP	X						

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NPP UNIT #1

TABLE I

PAGE 12 OF 11

PIPE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PIPE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC	POSITION			U.S.- EN- TIAL	REMARKS
						NOR- MAL	HIGH ON	POST LOCA		
58	Bspare	-								
59	Bspare	-								
60	Bspare	-								
61	Bspare	-								
62	Bspare	-								
63	Bspare	-								
64	Reactor Cavity Fill & Recirc (6"	AP	1210PF 1200PF 5150PF -	MAN OA VLV MAN OA VLV MAN OL TRIT VLV TRIT CORN /W CAP	X	LC	C	C	-	
65	Instrument Air (2")	AP	CV1211 4000AB 6120AB -	AC OL VLV CHECK VLV MAN OL TRIT VLV TRIT CORN /W CAP	X	NO	O	O	-	
			6310AB	MAN OA VLV	X	O	O	O	-	
					X	LC	C	C	-	
					X	C	C	C	-	
					X	NO	O	O	-	
66	ILPT Instrument Line (15")	E	601VAR 610VAR 603VAR -	MAN OA VLV MAN OA VLV MAN OL TRIT VLV TRIT CORN /W CAP	X	LC	C	C	-	
			602VA	MAN OL TRIT VLV	X	LC	O	O	-	
			-	TRIT CORN /W CAP	X	C	C	C	-	
67	Clean Waste Receiver Tank Pump Recirc (1")	C2	CV103T 410-CRW 515CRW -	AC OL VLV CHECK VLV MAN OL TRIT VLV TRIT CORN /W CAP	X	NO	O	C	O	
					X	O	O	C	-	
					X	LC	O	O	-	
					X	C	C	C	-	

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PAI 1A/2A S/N 100113

TABLE I

PAGE 13 OF 13

ITEM NO.	SYSTEM NAME AND SERVICE LINE SIZE	VALVE CLASS NUMBER	VALVE TYPE OR NUMBER	LOCATION (C/L)	POSITION (H/D)	TEST TIME (H)	TEST LOC.	ISS-ACTION-INITIAL			REMARKS
								C101	C	C	
68	Air Supply To Air Room (17"Ø)	A1	AO TRIP VLV AO TRIP VLV MAN OIL TRIP VLV TRIP CMM /N CAP	X	I/C	0/C	C	-	-	-	Air Supply To CV-1811 & CV-1812 Is Also Tested Under LANT
69	Clean Water Receiver Tank Pump Ration (17"Ø)	C1	CV101 CV101A S1A1W	X	I/C	0/C	C	-	-	-	
70	Spare	-	-	X	HD	0	C	C	C	C	
71	Spares	-	-	X	I/C	0	C	-	-	-	
72	Reactor Refueling Gravity Drain (17"Ø)	AP	11TRIP 11TRIP S1101P	MAN DA VALVE MAN DA VALVE MAN OIL TRIP VLV TRIP CMM /N CAP	X	I/C	0/C	C	C	C	
73	Canned Spare	-	-	S00048	X	I/C	0/C	C	C	C	

The valve should be isolated through both means. Also, the locked closed valve could be an automatic isolation valve to satisfy GIC 3F.

- 37 -

TABLE I NOTES

1. Valve Type or Description - AO means air-to-open and AC means air-to-close.
2. Normal Position - NO - Normally open
NC - Normally closed
BC - Bolted Closed (e.g. flange)
LO - Locked Open
LC - Locked Closed
EO - Electrically Locked Open (key lock switch)
EC - Electrically Locked Closed (key lock switch)
3. Shutdown Position - Assumes normal shutdown with the plant on shutdown cooling.
4. Power Failure Position - Position shown is for either loss of power or loss of air unless otherwise noted.
5. Actuation - Signal which automatically causes valve to reposition unless otherwise specified. Symbols are:

CIS - Containment Isolation Signal
SIS - Safety Injection Signal
CEP - Containment High Pressure Signal
CER - Containment High Radiation Signal
MAN - Remotely actuated by Manual Operator action

NUCLEAR POWER PLANT ISOLATION SYSTEM

CONTAINMENT ISOLATION SYSTEM
TABLE

CONTAINMENT ISOLATION SYSTEM
SEP REVIEW FINDINGS

PLANT Palisades Plant Unit 1
PAGE 1 OF 7

OPERATOR NUMBER	LINE SERVICE	EXCEPTIONS					REVIEWER'S COMMENTS
		APPLICABLE GDC	LOCATION	NUMBER	TYPE	POSITION	
1	PURGE AIR SUPPLY (4R 1/2")	56	X				
2	MAINSTEAM LINE- (SIGESOA) (36 1/2")	57					
3	MAIN STEAM LINE- (SIGESOB) (36 1/2")	57					
4	PURGE AIR EXHAUST (4R 1/2")	56	X				
4a	PURGE AIR EXHAUST SAMPLE LINE (3 1/2")	56	X				
5	SIG (ESOA) BOTTOM R/IN DOWN (2 1/2")	56					
6	SIG (ESOB) BOTTOM R/IN DOWN (2 1/2")	56					NEW ISOLATION VALVES SHOULD BE FINGER RATED. AUTOMATIC ISOLATION VALVES TO SATISFY "DO NOT FAIL DURING ACCIDENTAL ACTUATION."
7	FEEDWATER TO S/G (ESOA) (18 1/2")	57		X			
8	FEEDWATER TO S/G (ESOB)	57		X			
9	SPARG	-					DECISION ON ACCEPTABILITY OF SIMPLE CHECK VALVE OUTSIDE CONTAINMENT IS NEEDED
10	SERVICE AIR (1 1/2")	56	X	X			
11	CONDENSATE TO SHIELD CONDENSATE TANK	56	X	X			"

TABLE

CONTAINMENT ISOLATION SYSTEM

PLANT Palisades Plant Unit 1
PAGE 2 OF 7

TAOLE

CONTAINMENT ISOLATION SYSTEM
SEP REVIEW FINDINGS / EXC

PLANT PATENTS PLANT UNIT
PAGE 2 OF 2

- 45 -

VI. Reference

1. License DPR-20-Palisades Plant - response to SEP Topic VI-4 - Containment Isolation System, 7/14/80.
2. Independent review of containment penetrations, MPR-639, Vol. I & II, MPP Association, Inc, 11/15/79.
3. License DPR-20-Palisades Plant - IE Bulletin 79-06B response update, 8/16/79.
4. DPR-20-Palisades Plant - requirements resulting from review of TMI-2 accident actions taken in response to NRC, 12/27/79.
5. Consumers Power Co. Licensee event report 80-021, Rev. 1, Misaligned containment sump valve, 8/20/80.
6. CE Post-TMI evaluation task 5 - containment isolation, 12/13/79.
7. Palisades plant design drawing: M-201 (rev. 22), M-202(21), M-203(15), M-204(16), M-205(23), M-206(11), M-207(33), M-208(19), M-214(1E), M-215(14), M-21E(20), M-219(10), M-220(17), M-221(10), M-222(1C), M-223(7), M-224(7), M-225(8), M-226(8), E-15(1), E-16(1), E-17(6).
8. Palisades plant #1, Final Safety Analysis Report, Vols. 1, 2 & 3.
9. Letter from R. A. Vincent (Consumers Power Company) to D. M. Crutchfield, dated August 10, 1981, Providing Comments on CSB Evaluation Report on SEP Topic VI-4 for the Palisades Nuclear Plant, Unit 1.
10. Letter from R. A. Vincent (Consumers Power Company) to D. M. Crutchfield, dated January 4, 1982, Providing Information on SEP Topic VI-4 for the Palisades Nuclear Plant, Unit 1.