Telephone (617) 872-8100 TWX 710-380-7619

## YANKEE ATOMIC ELECTRIC COMPANY



2.C.2.9 FYR 83-25

1671 Worcester Road, Framingham, Massachusetts 01701

March 4, 1983

United States Nuclear Regulatory Commission Region I 631 Park Avenue King of Prussia, PA 19406

Attention: Mr. Ronald C. Haynes, Regional Administrator

References: (a) License No. DFR-3 (Docket 50-29) (b) IE Bulletin 83-01, dated February 25, 1983

Subject: Response to IE Bulletin 83-01

Dear Mr. Haynes:

This letter is to inform you that the Yankee Plant does not use Westinghouse DB-type breakers using undervoltage trip attachment in Reactor Protective System applications and is therefore not affected by Reference (b).

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

H Heider

L. H. Heider Vice President/Manager of Operations

JK/dsm

COMMONWEALTH OF MASSACHUSETTS)

MIDDLESEX COUNTY

)ss

Then personally appeared before me, L. H. Heider, who, being duly sworn, did state that he is Vice President/Manager of Operations of Yankee Atomic Electric Company, that he is duly authorized to execute and file the foregoing request in the name and on the behalf of Yankee Atomic Electric Company and that the statements therein are true to the best of his knowledge and belief.



Robert H. Groce Notary Public My Commission Expires September 14, 1984

IEI