



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
REGARDING THE BWR OWNERS GROUP RESPONSE
TO GENERIC LETTER 89-19

1.0 DISCUSSION

On September 20, 1989, the NRC staff issued Generic Letter (GL) 89-19 regarding reactor vessel overflow protection. For boiling water reactors (BWRs), GL 89-19 discusses modifications to prevent a potential core melt event that bypasses containment. The probability of core melt is very low, but the potential consequences can be significant. As a result, GL 89-19 recommends that all BWR plant designs provide automatic reactor vessel overflow protection to mitigate main feedwater overflow events. The GL states that the design for the overflow protection system should be sufficiently separate from the main feedwater (MFW) control system to ensure MFW pump trip on a high water level signal in conjunction with a loss of power, loss of ventilation, or fire in the control portion of the MFW control system.

One of the base documents supporting GL 89-19 is NUREG 1218, "Regulatory Analysis for the Resolution of USI A-47," dated July 1989. Chapter 4 of NUREG 1218 discusses possible General Electric BWR plant design changes. The report communicates the NRC staff's recognition that the safety benefits gained by providing additional reactor vessel water level redundancy and independence to existing BWR overflow protection systems is not significant. The report also states that modifying existing systems to provide additional channels is not a viable alternative in consideration of the cost/benefit cost analysis. However, of the three plants that do not have automatic overflow protection capability, Oyster Creek is the only plant where modifications are warranted. Subsequently, the staff approved the licensee's proposed design of automatic overflow protection system as recommended in GL 89-19 to be installed at the next refueling outage. The remaining two plants are LaCrosse and Big Rock Point which are early vintage with low-power ratings and are located in low-density population areas. The risk reduction for these two plants was estimated to be insignificant; therefore, modifications are not warranted. LaCrosse has been permanently shutdown. The staff also notes that Shoreham is permanently shutdown and is, therefore, not subject to GL 89-19 proposed actions.

In response to GL 89-19 and NUREG 1218, the BWR Owners Group (BWROG) submitted a report entitled "BWROG Response to NRC GL 89-19, "Hardware Change Recommendations," dated April 2, 1990. The BWROG response was reviewed by Idaho National Engineering Laboratory (INEL) under contract to the NRC. The results of the INEL review are documented by "Technical Evaluation Report: Review of the BWR Owners Group Response to Reactor Vessel Overflow Protection;

(Generic Letter 89-19)," dated February 1991. The remainder of this safety evaluation (SE) is the staff's findings and conclusions based on its review of NUREG 1218, the BWROG response, and the INEL Evaluation.

2.0 FINDINGS AND CONCLUSIONS

This SE is applicable to Millstone, Unit 1, and the BWR plants identified in NUREG 1218, the BWROG report and the INEL Technical Evaluation Report (TER).

The NRC staff reviewed the INEL TER, the BWROG submittal, NUREG 1218 and BWR plant specific submittals. Based on this review, the staff has concluded that it is highly unlikely that a loss of power event or a fire would cause an overfill event by affecting the feedwater control circuitry and defeating the overfill protection since the feedwater control is an energize to actuate system (e.g., the isolation valve will close upon loss-of-power). The staff will confirm in the reviews of all plants that it is unlikely that any single event could disable overfill protection and the feedwater isolation. Based on a comparison of the methodologies and the numeric results obtained in these documents, the staff concurs with the conclusions and bases identified in the INEL TER. The staff also notes that while the INEL evaluation includes no conclusion on bypass capability for the 1-out-of-1 and 1-out-of-2 trip logic overfill protection systems, the existing bypass capability is considered to be acceptable by the staff and is unaffected by the resolution of USI A-47. The staff's findings are summarized as follows with the understanding that the TER provides the technical basis for the findings.

- (1) Upgrading BWRs with existing automatic reactor vessel overfill protection to the separation and independence criteria identified in GL 89-19, is not warranted based on the cost/safety-benefit analysis.
- (2) As stated in GL 89-19, the staff recommends the following items:
 - (a) that plant procedures and technical specifications, for all BWR plants with reactor vessel overfill protection, include provisions to periodically verify the operability of overfill protection and ensure that automatic overfill protection is available to mitigate main feedwater overfeed events during reactor power operation, and (b) that all BWR plants reassess and modify, if needed, their operating procedures and operator training to assure that operators can mitigate reactor vessel overfill events that may occur via the condensate booster pumps during reduced system pressure operation.

Principal Contributor: S. Rhow

Mr. B. Ralph Sylvia

- 2 -

May 23, 1994

If you have any questions concerning this matter, please contact me at (301) 504-1409.

Sincerely,

Original signed by:

Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Distribution:
Docket File
NRC & Local PDRs
PDI-1 Reading
SVarga
JCalvo
MBoyle
CVogan
DBrinkman
OGC
ACRS (10)
CCowgill, RGN-1
JWermiel, 8/H/3
KJabbour, 14/H/25
SRhow, 8/H/3

LA:PDI-1 <i>CV</i>	PM:PDI-1 <i>DB</i>	BC:KICB <i>JW</i>	D:PDI-1 <i>MB</i>		
CVogan	DBrinkman:smm	JWermiel	MBoyle		
5/20/94	5/20/94	5/23/94	5/23/94	1/1	1/1

OFFICIAL RECORD COPY
FILENAME: NM274967.LTR