The Light

COMPANY
Houston Lighting & Power South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

May 25, 1994 ST-HL-AE-4792 File No.: G02.04 10CFR2.201

U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

> South Texas Project Unit 1 Docket No. STN 50-498 Reply to Notice of Violation 94009-02 Regarding a Change to a Surveillance Test Procedure

Houston Lighting & Power Company has reviewed Notice of Violation 94009-02, dated April 25, 1994, regarding a change to a surveillance test procedure and submits the attached reply.

If you have any questions, please contact Mr. S. M. Head at (512) 972-7136 or me at (512) 972-7239.

> Jew W Myers Plant Manager, Unit 1

DNB/esh

Attachment: Reply to Notice of Violation 498/94009-02

310052

A Subsidiary of Housion Industries Incorporated

Houston Lighting & Power Company South Texas Project Electric Generating Station ST-HL-AE-4792 File No.: G02.04 Page 2

0

L. J. Callan Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011-8064

Lawrence E. Kokajko Project Manager U. S. Nuclear Regulatory Commission Washington, DC 20555 13H15

David P. Loveless Sr. Resident Inspector c/o U.S. Nuclear Regulatory Comm. P. O. Box 910 Bay City, TX 77404-910

J. R. Newman, Esquire Newman, Bouknight & Edgar, P.C., STE 1000, 1615 L Street, N.W. 1615 L Street, N.W. Washington, DC 20036

K. J. Fiedler/M. T. Hardt City Public Service P. O. Box 1771 San Antonio, TX 78296

J. C. Lanier/M. B. Lee City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704

G. E. Vaughn/C. A. Johnson Central Power and Light Company P. O. Box 2121 Corpus Christi, TX 78403 Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 61867 Houston, TX 77208

Institute of Nuclear Power Operations - Records Center 700 Galleria Parkway Atlanta, GA 30339-5957

Dr. Joseph M. Hendrie 50 Bellport Lane Bellport, NY 11713

D. K. Lacker Bureau of Radiation Control Texas Department of Health 1100 West 49th Street Austin, TX 78756-3189

U. S. Nuclear Regulatory Comm. Attn: Document Control Desk Washington, D.C. 20555

Reply to Notice of Violation 498/94009-02

I. Statement of Violation:

Solid State Protection System Actuation Train B Slave Relay Test

Technical Specification 6.5.3.1.a requires, in part, that changes to procedures that may involve a change to the intent of the original procedure shall be approved by the individual authorized to approve the procedure, prior to implementation of the change.

Contrary to the above, on February 25, 1994, licensed operators changed the intent of Plant Surveillance Procedure OPSP03-SP-0009B, Revision 1, "SSPS Actuation Train B Slave Relay Test," as directed in a night order, without the approval of the engineering programs manager, who was the individual authorized to approve the change. The procedure change was performed by marking steps as not applicable that were required to perform an adequate test of the slave relays associated with automatic repositioning of several safety injection valves.

This is a Severity Level IV violation. (Supplement I) (498/9409-02).

II. Houston Lighting & Power Position:

Houston Lighting & Power concurs that the violation occurred.

III. Reason for Violation:

The intent of procedure OPSP03-SP-0009B was inadvertently changed because the technical review was incorrect. In addition, the control room crew did not independently confirm that the procedure steps to be performed were correct because the shift Night Orders contained specific procedural direction concerning performance of the surveillance test.

Surveillance testing was scheduled for the automatic switchover to containment sump actuation logic, which is contained in procedure OPSP03-SP-0009B. Because the procedure tests several functions, only specific steps of the procedure are required to test an individual function, and a process is required for determining the steps that must be performed. Procedure OPGP03-ZA-0010, "Performing and Verifying Station Activities", provides this process by specifying that the Shift/Unit Supervisor can authorize performance or omission of specific procedure steps based on plant operating conditions.

In accordance with procedure OPGP03-ZA-0010, a technical review of OPSP03-SP-0009B was performed to determine which steps were required to test the desired logic circuit. However, the technical review did not identify all of the steps necessary to satisfactorily perform the surveillance test. The results of this technical review were reflected in the shift Night Orders in the form of specific procedural direction for performing the surveillance. The control room crew assumed that the evolution had been adequately evaluated and did not independently confirm that the correct steps of procedure OPSP03-SP-0009B were being performed. When the surveillance test was performed using the directions in the shift Night Orders, the desired test result was not achieved.

IV. Corrective Actions:

The following corrective actions have been taken:

- The surveillance test was performed using the correct steps with satisfactory results.
- 2. A shift briefing item on the lessons learned from this event was distributed to the Shift Supervisors to discuss with their crews. The item described the failure to adequately evaluate the effects of the steps being made "not applicable" and reminded the Shift/Unit Supervisors of their responsibilities/authority in this area.
- 3. This event and the requirements of OPGP03-ZO-0040, "Maintenance of the Operations Policies and Practices Manual" were discussed with personnel responsible for approving Night Orders to ensure proper use of and the responsibility for ensuring accurate information is contained in the Night Orders.

V. Date of Full Compliance:

Houston Lighting & Power is in full compliance