

50-329, 330



Midland Project: PO Box 1963, Midland, MI 48640 • (517) 631-8650

PRINCIPAL STAFF	
RA	ENF
D/RA	SCS ✓
A/RA	PAO
DPRP	SLO
DRMA	RC
DRMSP	
DE	
ML	
OL	FILE

orig+3

*[Handwritten signature]*

March 4, 1983

Mr. W. D. Shafer, Chief  
 Midland Project Section  
 US Nuclear Regulatory Commission  
 Region III  
 799 Roosevelt Road  
 Glen Ellyn, IL 60137

MIDLAND PROJECT GWO 7020  
 NON Q MATERIALS FOR UNDERPINNING  
 File: 0485.16 UFI: 42\*05\*22\*04 Serial: CSC-6593

This is to confirm a conversation on site between Glenn Murray of CCo-SMO and Ron Gardner of Region III on 3/3/83. The purpose of the conversation was to obtain concurrence on the purchase of "non-Q" materials for the underpinning instrumentation for the Service Water Pump Structure (C-194). The following will be purchased "non-Q":

- 1) Structural shapes for instrument covers
- 2) Plexiglass for covers
- 3) Fasteners for covers
- 4) Expanded metal for covers
- 5) EMT/Rigid raceway materials
- 6) Instrument covers for extensometers
- 7) Gasket material for covers
- 8) Dead and live end anchors for extensometers
- 9) Support brackets for instruments
- 10) PVC pipe for telltales
- 11) Centralizer material for telltales

The above items will be purchased "non-Q". However, CCo will invoke Quality Assurance Program Requirements upon receipt and installation.

*[Handwritten signature: D. B. Miller]*

D. B. Miller  
 Site Manager

DBM/GMM/dmh

MAR 14 1983

8303170385 830304  
 PDR ADOCK 05000329  
 A PDR

TED