NRC FOR (7,77)	U. S. NUCLEAR REGULATORY COMMISSION
	CONTROL BLOCK:
	$ \begin{array}{c c c c c c c c c c c c c c c c c c c $
CON'T	REPORT L 6 0 5 0 0 0 2 6 1 0 0 2 0 9 8 2 8 4 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9
02	On February 9, 1982, it was determined that the pressurization of the BIT header at
03	0030 hours on November 25, 1981, was reportable pursuant to T.S. 6.9.2.a.5. With the
04	Plant in cold shutdown, the BIT header pressure indicator PI-934 was observed reading
05	Labove scale on the 0-2000 psig indicator. Maximum pressure was determined to be 2125
06	psig. An evaluation determined that this pressurization did not degrade the integrity
0 7	of the system. Since the plant was in cold shutdown, there was no threat to the public
08	health and safety.
09 7 8	SYSTEM CAUSE CAUSE CAUSE COMPONENT CODE COMPONENT CODE SUBCODE
	Image: Number Num Number Number Number Number Number Number Number Num
	ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. 25 PRIME COMP. COMPONENT MANUFACTURER MANUFACTURER SUBPLIER COMPONENT MANUFACTURER MANUFACTURER COMPONENT MANUFACTURER ATTACHMENT SUBMITTED TO THE SUBPLIER SUBPLIER ATTACHMENT ATTACHMEN
[1]0]	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The pressurization was caused by the BIT strip heater pressurizing the tank, the
	operator not relieving the pressure, and the BIT safety valve SI-857A not relieving
112	at 1750 psig. The BIT header pressure annunciator procedure has been revised, and
13	the BIT safety value SI-857A reset to 1750 psig. An engineering review was initiated
14	and is currently in progress to determine if additional corrective action is required.
7 B	9 FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
1 5 7 8	G (28) O
16	AMOUNT OF ACTIVITY (35)
	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (3)
7 8	9 PERSONNEL INJURIES (1) 80
1 B	
19	LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION N/A
7 B	B TO BO PUBLICITY DESCRIPTION (15)
2 0	N (44) N/A 68 69 80 5
PDR	ADUCK 0500 PDR arson L. Wright PHONE (803) 383-4524

SUPPLEMENTAL INFORMATION FOR LICENSEE EVENT REPORT 82-003

1. Cause Description and Analysis

On November 25, 1981, at 0030 hours with the plant at cold shutdown the Boron Injection Tank (BIT) header pressure indicator (PI-934) was observed reading above scale on the 0-2000 psig indicator. Maximum header pressure was determined to be 2125 psig. The BIT header pressure annunciator (A2-19) alarms at 200 psig. However, because the BIT is a strip heated tank it was common for the annunciator to alarm and the operator to vent the BIT back to the Boric Acid (BA) tanks. With many of the annunciators normally lit during cold shutdown, the importance of this particular alarm was overlooked for the time it took the BIT header pressure to reach 2125 psig. This excessive pressure was caused by the BIT strip heaters heating the BIT, the operator not relieving the pressure, and the BIT safety valve SI-857A failing to relieve at its 1750 psig setpoint.

An evaluation of the pressurization concluded that the excessive pressure did not degrade the integrity of the system.

At the time of the event, it was determined that since the plant was in cold shutdown the event was not reportable. However, on February 9, 1982, this event was reviewed again, and it was determined that it should have been reported.

2. Immediate Corrective Action

The BIT header pressure was vented back to the BA tanks. The set pressure for safety valve SI-857A had apparently drifted upward as it was bench tested to left at \sim N2000 psig. SI-857A was reset to lift at 1750 psig and was re-installed.

3. Corrective Action To Prevent Recurrence

Annunciator Procedure A2-19 was revised. "BIT header activation" was added to the causes for the alarm, and "vent BIT as necessary through CVC-841A and B (to BA tanks)" was added to the action items. An engineering review has been initiated and is currently in progress to determine if additional corrective actions are required. If any additional actions are identified as a result of this review, a supplement to this LER will be submitted.