



Public Service of New Hampshire

SEABROOK STATION
Engineering Office:
1671 Worcester Road
Framingham, Massachusetts 01701
(617) - 872 - 8100

March 10, 1983

SBN- 490
T.F. B7.1.2

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

References: (a) Construction Permits CPPR-135 and CPPR-136, Docket
Nos. 50-443 and 50-444
(b) PSNH Letter, dated April 8, 1982, "Response to 460 Series
RAIs; (Effluent Treatment Systems Branch)," J. DeVincentis
to F. J. Miraglia

Subject: Open Item Response: (SRP 11.5; RAI 460.35; Meteorological and
Effluent Treatment Systems Branch)

Dear Sir:

In response to a Request for Additional Information [460.35(d)] from the
Effluent Treatment Systems Branch, it was indicated in Reference (b) that "the
exhaust from the turbine gland steam condenser will either be monitored
separately, or directed to the main plant vent." The following discussion
supercedes the above response to 460.35(d).

It has been determined that it is impractical at the existing stage of
construction, to direct the turbine gland steam condenser exhaust to the plant
vent. It is also our position, based on calculations that are discussed in
the enclosure to this letter, that there is no valid reason why a radiation
monitor need be installed in the turbine gland steam condenser vent.

If you disagree with our position on this item, please notify us promptly.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

J. DeVincentis
J. DeVincentis
Project Manager

Boo!

ALL/fc

cc: Atomic Safety and Licensing Board Service List

8303170441 830310
PDR ADOCK 05000443
A PDR

Revised
3/10/83

460.35 d)

We have reviewed the need for a monitor on the gland steam condenser vent and have concluded that there are valid reasons why it should not be required.

Preliminary calculations demonstrate that in the event of a steam generator tube rupture accident, less than one percent of the total activity released is released through the gland steam condenser vent. Based on these calculations and the worst case whole body doses given in Table 15.6.10 of the FSAR, the whole body dose due to releases from the gland steam condenser vent is less than 1 mrem at the exclusion area boundary. Main steam line monitors can be used to calculate a release rate from this vent.

During normal operation, the station could continue operating with a primary to secondary leak that remained within Technical Specification limits. The leak would produce a reading at the condenser air evacuation monitor and at the blowdown monitor of the affected steam generator. The addition of a monitor on the gland steam vent would not alert the operator sooner, nor would it alleviate the need for sampling to allow for full documentation of the radionuclides being released.

With a primary to secondary leak during routine operation, we will sample and analyze the condenser air evacuation gas stream. A calculation will then be made of the activity released to the gland steam condenser vent and this release accounted for as part of the station's total effluent releases.

We commit to providing the following additional information by May 27, 1983.

- o Final calculations of releases from gland steam condenser vent for a steam generator tube rupture accident.
- o Technical specification requirement for sampling frequency when primary to secondary leaks are within technical specification limits.
- o Air evacuator monitor alarm setpoint.

ASLB SERVICE LIST

Rep. Beverly Hollingworth
Coastal Chamber of Commerce
209 Winnacunnet Road
Hampton, NH 03842

William S. Jordan, III, Esquire
Harmon & Weiss
1725 I Street, N.W.
Suite 506
Washington, DC 20006

E. Tupper Kinder, Esquire
Assistant Attorney General
Office of the Attorney General
208 State House Annex
Concord, NH 03301

Roy P. Lessy, Jr., Esquire
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert A. Backus, Esquire
116 Lowell Street
P.O. Box 516
Manchester, NH 03105

Philip Ahrens, Esquire
Assistant Attorney General
Department of the Attorney General
Augusta, ME 04333

David L. Lewis
Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Rm. E/W-439
Washington, DC 20555

Mr. John B. Tanzer
Designated Representative of
the Town of Hampton
5 Morningside Drive
Hampton, NH 03842

Roberta C. Pevear
Designated Representative of
the Town of Hampton Falls
Drinkwater Road
Hampton Falls, NH 03844

Mrs. Sandra Gavutis
Designated Representative of
the Town of Kensington
RFD 1
East Kingston, NH 03827

Edward J. McDermott, Esquire
Sanders and McDermott
Professional Association
408 Lafayette Road
Hampton, NH 03842

Jo Ann Shotwell, Esquire
Assistant Attorney General
Environmental Protection Bureau
Department of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Olive L. Tash
Designated Representative of
the Town of Brentwood
R.F.D. 1, Dalton Road
Brentwood, NH 03833

Edward F. Meany
Designated Representative of
the Town of Rye
155 Washington Road
Rye, NH 03870

Calvin A. Canney
City Manager
City Hall
126 Daniel Street
Portsmouth, NH 03801