

SOUTH CAROLINA ELECTRIC & GAS COMPANY  
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY  
DOCKET NO. 50-395  
VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 12  
License No. NPF-12

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Virgil C. Summer Nuclear Station, Unit No. 1 (the facility) Facility Operating License No. NPF-12 filed by the South Carolina Electric & Gas Company acting for itself and South Carolina Public Service Authority (the licensees), dated December 17, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
  - E. The issuance of this license amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page change to the Technical Specifications as indicated in the attachments to this license amendment. Paragraph 2.C(2) of Facility Operating License No. NPF-12 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 12, are hereby incorporated into this license. South

OFFICE							
SURN	8303170611	830304					
	PDR ADOCK	05000395					
	P	PDR					

Carolina Electric & Gas Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

51

Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
Technical Specification  
Changes

Date of Issuance: March 4, 1983

*FLW # Andy Young*

OFFICE	LA:DL LB #4	DL:LB #4	OELD	DL:LB #4	AD:L:DL		
SURNAME	M Duncan/hmc	J Hopkins	M Adams	E Adensam	T Novak		
DATE	1/7/83	1/7/83	1/7/83	1/3/83	1/7/83		

ATTACHMENT TO LICENSE AMENDMENT NO. 12

FACILITY OPERATING LICENSE NO. NPF-12

DOCKET NO. 50-395

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Amended  
Page

3/4 8-58

OFFICE ▶	.....	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....	.....

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO.-SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
161) XVG 8095B-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DB2Y/23FJ	225 Amps	N/A
	BACKUP	XMC1DB2Y/23FJ	60 Amps	≤ 100 Sec.
162) XVG 8096A-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DA2X/7AE	225 Amps	N/A
	BACKUP	XMC1DA2X/7AE	60 Amps	≤ 100 Sec.
163) XVG 8096B-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DB2Y/12IM	225 Amps	N/A
	BACKUP	XMC1DB2Y/12IM	60 Amps	≤ 100 Sec.
164) XVG 7503-AC/CRDM COOLING WATER OUTLET VLV.	PRIMARY	XMC1DA2X/11IM	225 Amps	N/A
	BACKUP	XMC1DA2X/11IM	60 Amps	≤ 100 Sec.
165) XVG 7502-AC/CRDM COOLING WATER INLET VLV.	PRIMARY	XMC1DB2X/7IM	225 Amps	N/A
	BACKUP	XMC1DB2X/7IM	60 Amps	≤ 100 Sec.
166) WELDING RECEPTACLE FOR STEAM CLEANING MACHINE WE	PRIMARY	XMC1C3X/9KM	300 Amps	≤ 200 Sec.
	BACKUP	XMC1C3X/9KM	300 Amps	≤ 200 Sec.