

**ornl**

NUREG/CR-2968  
ORNL/TM-8509

OAK  
RIDGE  
NATIONAL  
LABORATORY

UNION  
CARBIDE

Experiment Data Report for  
Multirod Burst Test (MRBT)  
Bundle B-4

A. W. Longest  
R. H. Chapman  
J. L. Crowley

Prepared for the U.S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research  
Under Interagency Agreements DOE 40-551-75 and 40-552-75

OPERATED BY  
UNION CARBIDE CORPORATION  
FOR THE UNITED STATES  
DEPARTMENT OF ENERGY

8303170616 830131  
PDR NUREG  
CR-2968 R PDR

Printed in the United States of America. Available from  
National Technical Information Service  
U.S. Department of Commerce  
5285 Port Royal Road, Springfield, Virginia 22161

Available from  
GPO Sales Program  
Division of Technical Information and Document Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.



## CONTENTS

	<u>Page</u>
LIST OF FIGURES .....	v
LIST OF TABLES .....	xiii
FOREWORD .....	xv
ABSTRACT .....	1
1. INTRODUCTION .....	2
2. TEST DESCRIPTION .....	3
2.1 Assembly .....	3
2.2 Operations .....	4
3. SUMMARY OF TEST RESULTS .....	6
4. DETAILED TEST RESULTS .....	7
4.1 Transient Results .....	7
4.1.1 Bundle behavior .....	7
4.1.2 Fuel pin simulator pressure and temperature plots .....	11
4.2 Pretest and Posttest Results .....	11
4.2.1 Pretest bundle photographs .....	11
4.2.2 Posttest bundle photographs and general examina- tion results .....	12
4.2.3 Strain data and tube strain profiles .....	13
4.2.4 Coolant channel flow area restriction .....	14
ACKNOWLEDGMENTS .....	16
REFERENCES .....	17



## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Schematic of B-4 test assembly .....	28
2	Typical fuel pin simulator .....	29
3	As-built thermocouple locations and identifications in B-4 test (plan view) .....	30
4	As-built thermocouple locations in B-4 test (ele- vation) .....	31
5	Steam thermocouple identifications, locations, and tem- peratures measured 1 s before power-on .....	32
6	Temperatures measured at 84-cm elevation 1 s before power-on .....	32
7	Temperatures measured at 76-cm elevation 1 s before power-on .....	33
8	Temperatures measured at 66-cm (upper grid) elevation 1 s before power-on .....	33
9	Temperatures measured at 56-cm elevation 1 s before power-on .....	34
10	Temperatures measured at 47-cm elevation 1 s before power-on .....	34
11	Temperatures measured at 38-cm elevation 1 s before power-on .....	35
12	Temperatures measured at 29-cm elevation 1 s before power-on .....	35
13	Temperatures measured at 20-cm elevation 1 s before power-on .....	36
14	Temperatures measured at 10-cm (lower grid) elevation 1 s before power-on .....	36
15	Temperatures measured at 5-cm elevation 1 s before power-on .....	37
16	Average simulator temperatures measured 1 s before power-on .....	37

<u>Figure</u>		<u>Page</u>
17	Simulator pressures measured 1 s before power-on .....	38
18	Characteristic temperatures and pressures during powered portion of B-4 transient .....	39
19	Simulator pressures measured 0.2 s before power-off .....	40
20	Temperatures measured at 84-cm elevation 0.2 s before power-off .....	40
21	Temperatures measured at 76-cm elevation 0.2 s before power-off .....	41
22	Temperatures measured at 66-cm (upper grid) elevation 0.2 s before power-off .....	41
23	Temperatures measured at 56-cm elevation 0.2 s before power-off .....	42
24	Temperatures measured at 47-cm elevation 0.2 s before power-off .....	42
25	Temperatures measured at 38-cm elevation 0.2 s before power-off .....	43
26	Temperatures measured at 29-cm elevation 0.2 s before power-off .....	43
27	Temperatures measured at 20-cm elevation 0.2 s before power-off .....	44
28	Temperatures measured at 10-cm (lower grid) elevation 0.2 s before power-off .....	44
29	Temperatures measured at 5-cm elevation 0.2 s before power-off .....	45
30	Average simulator temperatures measured 0.2 s before power-off .....	45
31	Characteristic B-4 temperatures and pressures during transient .....	46
32	Simulator pressures measured 0.7 s before depressurization .....	47
33	Temperatures measured at 84-cm elevation 0.7 s before depressurization .....	47

<u>Figure</u>		<u>Page</u>
34	Temperatures measured at 76-cm elevation 0.7 s before depressurization .....	48
35	Temperatures measured at 66-cm (upper grid) elevation 0.7 s before depressurization .....	48
36	Temperatures measured at 56-cm elevation 0.7 s before depressurization .....	49
37	Temperatures measured at 47-cm elevation 0.7 s before depressurization .....	49
38	Temperatures measured at 38-cm elevation 0.7 s before depressurization .....	50
39	Temperatures measured at 29-cm elevation 0.7 s before depressurization .....	50
40	Temperatures measured at 20-cm elevation 0.7 s before depressurization .....	51
41	Temperatures measured at 10-cm (lower grid) elevation 0.7 s before depressurization .....	51
42	Temperatures measured at 5-cm elevation 0.7 s before depressurization .....	52
43	Average simulator temperatures measured 0.7 s before depressurization .....	52
44	B-4 shroud and simulator temperatures measured at 76-cm elevation during powered portion of transient .....	53
45	B-4 shroud and simulator temperatures measured at 76-cm elevation during transient .....	54
46	B-4 steam pressure and characteristic temperatures measured during transient .....	55
47	Temperature and pressure transients for B-4 rod No. 1 ...	56
48	Temperature and pressure transients for B-4 rod No. 2 ...	56
49	Temperature and pressure transients for B-4 rod No. 3 ...	57
50	Temperature and pressure transients for B-4 rod No. 4 ...	57
51	Temperature and pressure transients for B-4 rod No. 5 ...	58

<u>Figure</u>		<u>Page</u>
52	Temperature and pressure transients for B-4 rod No. 6 ...	58
53	Temperature and pressure transients for B-4 rod No. 7 ...	59
54	Temperature and pressure transients for B-4 rod No. 8 ...	59
55	Temperature and pressure transients for B-4 rod No. 9 ...	60
56	Temperature and pressure transients for B-4 rod No. 10 ..	60
57	Temperature and pressure transients for B-4 rod No. 11 ..	61
58	Temperature and pressure transients for B-4 rod No. 12 ..	61
59	Temperature and pressure transients for B-4 rod No. 13 ..	62
60	Temperature and pressure transients for B-4 rod No. 14 ..	62
61	Temperature and pressure transients for B-4 rod No. 15 ..	63
62	Temperature and pressure transients for B-4 rod No. 16 ..	63
63	Temperature and pressure transients for B-4 rod No. 17 ..	64
64	Temperature and pressure transients for B-4 rod No. 18 ..	64
65	Temperature and pressure transients for B-4 rod No. 19 ..	65
66	Temperature and pressure transients for B-4 rod No. 20 ..	65
67	Temperature and pressure transients for B-4 rod No. 21 ..	66
68	Temperature and pressure transients for B-4 rod No. 22 ..	66
69	Temperature and pressure transients for B-4 rod No. 23 ..	67
70	Temperature and pressure transients for B-4 rod No. 24 ..	67
71	Temperature and pressure transients for B-4 rod No. 25 ..	68
72	Temperature and pressure transients for B-4 rod No. 26 ..	68
73	Temperature and pressure transients for B-4 rod No. 27 ..	69
74	Temperature and pressure transients for B-4 rod No. 28 ..	69
75	Temperature and pressure transients for B-4 rod No. 29 ..	70
76	Temperature and pressure transients for B-4 rod No. 30 ..	70

<u>Figure</u>		<u>Page</u>
77	Temperature and pressure transients for B-4 rod No. 31 ..	71
78	Temperature and pressure transients for B-4 rod No. 32 ..	71
79	Temperature and pressure transients for B-4 rod No. 33 ..	72
80	Temperature and pressure transients for B-4 rod No. 34 ..	72
81	Temperature and pressure transients for B-4 rod No. 35 ..	73
82	Temperature and pressure transients for B-4 rod No. 36 ..	73
83	Partially assembled B-4 bundle .....	74
84	Bundle B-4 before installation of north panel of shroud box .....	75
85	Bundle B-4 shroud panels with reflector strip folded back on west panel to show insulating material .....	76
86	Completely assembled B-4 bundle .....	77
87	Shroud thermocouple attachment in B-4 test .....	78
88	Detail of shroud thermocouple installation on east face of B-4 shroud .....	79
89	Detail of outlet steam thermocouple installation in B-4 test .....	80
90	Posttest view of west face of bundle B-4 and shroud .....	81
91	Posttest views of (a) north, (b) east, (c) south, and (d) west faces of bundle B-4 .....	82
92	Close-up views of west face of bundle B-4 showing ballooned zone of No. 14 simulator .....	83
93	B-4 bundle viewed from south side as successive layers of rods were removed from bundle starting at bottom of photograph and progressing to top .....	84
94	Ballooned region in B-4 tube No. 14 .....	85
95	Simulator axial shrinkage in B-4 test .....	86
96	Deformation profile of tube 1 in B-4 test .....	87

<u>Figure</u>		<u>Page</u>
97	Deformation profile of tube 2 in B-4 test .....	87
98	Deformation profile of tube 3 in B-4 test .....	88
99	Deformation profile of tube 4 in B-4 test .....	88
100	Deformation profile of tube 5 in B-4 test .....	89
101	Deformation profile of tube 6 in B-4 test .....	89
102	Deformation profile of tube 7 in B-4 test .....	90
103	Deformation profile of tube 8 in B-4 test .....	90
104	Deformation profile of tube 9 in B-4 test .....	91
105	Deformation profile of tube 10 in B-4 test .....	91
106	Deformation profile of tube 11 in B-4 test .....	92
107	Deformation profile of tube 12 in B-4 test .....	92
108	Deformation profile of tube 13 in B-4 test .....	93
109	Deformation profile of tube 14 in B-4 test .....	93
110	Deformation profile of tube 15 in B-4 test .....	94
111	Deformation profile of tube 16 in B-4 test .....	94
112	Deformation profile of tube 17 in B-4 test .....	95
113	Deformation profile of tube 18 in B-4 test .....	95
114	Deformation profile of tube 19 in B-4 test .....	96
115	Deformation profile of tube 20 in B-4 test .....	96
116	Deformation profile of tube 21 in B-4 test .....	97
117	Deformation profile of tube 22 in B-4 test .....	97
118	Deformation profile of tube 23 in B-4 test .....	98
119	Deformation profile of tube 24 in B-4 test .....	98
120	Deformation profile of tube 25 in B-4 test .....	99

<u>Figure</u>		<u>Page</u>
121	Deformation profile of tube 26 in B-4 test .....	99
122	Deformation profile of tube 27 in B-4 test .....	100
123	Deformation profile of tube 28 in B-4 test .....	100
124	Deformation profile of tube 29 in B-4 test .....	101
125	Deformation profile of tube 30 in B-4 test .....	101
126	Deformation profile of tube 31 in B-4 test .....	102
127	Deformation profile of tube 32 in B-4 test .....	102
128	Deformation profile of tube 33 in B-4 test .....	103
129	Deformation profile of tube 34 in B-4 test .....	103
130	Deformation profile of tube 35 in B-4 test .....	104
131	Deformation profile of tube 36 in B-4 test .....	104
132	Coolant channel flow area restriction in B-4 test .....	105



## LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	As-built data for fuel pin simulators in B-4 test .....	18
2	Summary of B-4 initial conditions and conditions at time of maximum pressures .....	19
3	Summary of B-4 conditions 2.25 s after power-off .....	20
4	Summary of B-4 conditions at time of vent .....	21
5	Summary of B-4 test results related to volume changes ....	22
6	Strain in tubes of B-4 test .....	23
7	Deformed tube areas in B-4 test .....	25
8	Coolant channel flow area restriction in B-4 test .....	27



## FOREWORD

Examination, analysis, and interpretation of a bundle test take place over a long period of time, and our practice has been to report progress and results as they become available. Dissemination of the information in this manner results in its being disjointed and scattered throughout several publications. This presents some problems to the users in that one is never sure if the information at hand is the most recent. Our intention is to alleviate some of these problems by (1) publication of a data report on each bundle test and (2) publication of analytic and interpretative reports when sufficient information has been developed.

Consistent with this intention, the objective of this data report is to provide a reference source of information and results obtained during the B-4 test and from pretest and posttest examination of the test array. We believe the data presented herein, consisting of plots, tabulations, and photographs, are necessary for analysis and interpretation of the test. A decision was made that the data should be presented with a minimum of interpretation and that analysis or "second generation" data, such as comparative temperature vs time plots, should be excluded.

This report is derived from research performed by the Multirod Burst Test (MRBT) Program at Oak Ridge National Laboratory (ORNL). This research is sponsored by the Division of Accident Evaluation of the Nuclear Regulatory Commission, and the results are published routinely in a series of progress reports, topical reports and papers, quick-look reports, and data reports.

Progress reports published by the MRBT Program include:

<u>NUREG Report No.</u>	<u>ORNL Report No.</u>	<u>Period covered</u>
	ORNL/TM-4729	July-September 1974
	ORNL/TM-4805	October-December 1974
	ORNL/TM-4914	January-March 1975
	ORNL/TM-5021	April-June 1975
	ORNL/TM-5154	July-September 1975
	ORNL/NUREG/TM-10	October-December 1975
	ORNL/NUREG/TM-36	January-March 1976
	ORNL/NUREG/TM-74	April-June 1976
	ORNL/NUREG/TM-77	July-September 1976
	ORNL/NUREG/TM-95	October-December 1976
	ORNL/NUREG/TM-108	January-March 1977
	ORNL/NUREG/TM-135	April-June 1977
NUREG/CR-0103	ORNL/NUREG/TM-200	July-December 1977
NUREG/CR-0225	ORNL/NUREG/TM-217	January-March 1978
NUREG/CR-0398	ORNL/NUREG/TM-243	April-June 1978
NUREG/CR-0655	ORNL/NUREG/TM-297	July-December 1978
NUREG/CR-0817	ORNL/NUREG/TM-323	January-March 1979
NUREG/CR-1023	ORNL/NUREG/TM-351	April-June 1979
NUREG/CR-1450	ORNL/NUREG/TM-392	July-December 1979
NUREG/CR-1883	ORNL/NUREG/TM-426	January-June 1980
NUREG/CR-1919	ORNL/NUREG/TM-436	July-December 1980

NUREG/CR-2366, Vol. 1	ORNL/TM-8058	January-June 1981
NUREG/CR-2366, Vol. 2	ORNL/TM-8190	July-December 1981
NUREG/CR-2911	ORNL/TM-8485	January-June 1982

Topical reports and papers pertaining to research and development carried out by this program are:

1. R. H. Chapman (comp.), *Characterization of Zircaloy-4 Tubing Procured for Fuel Cladding Research Programs*, ORNL/NUREG/TM-29 (July 1976).
2. W. E. Baucum and R. E. Dial, *An Apparatus for Spot Welding Sheathed Thermocouples to the Inside of Small-Diameter Tubes at Precise Locations*, ORNL/NUREG/TM-33 (August 1976).
3. W. A. Simpson, Jr., et al., *Infrared Inspection and Characterization of Fuel-Pin Simulators*, ORNL/NUREG/TM-55 (November 1976).
4. R. H. Chapman et al., *Effect of Creep Time and Heating Rate on Deformation of Zircaloy-4 Tubes Tested in Steam with Internal Heaters*, NUREG/CR-0343 (ORNL/NUREG/TM-245) (October 1978).
5. J. F. Mincey, *Steady-State Axial Pressure Losses Along the Exterior of Deformed Fuel Cladding: Multirod Burst Test (MRBT) Bundles B-1 and B-2*, NUREG/CR-1011 (ORNL/NUREG/TM-350) (January 1980).
6. R. W. McCulloch, P. T. Jacobs, and D. L. Clark, *Development of a Fabrication Procedure for the MRBT Fuel Simulator Based on the Use of Cold-Pressed Boron Nitride Preforms*, NUREG/CR-1111 (ORNL/NUREG/TM-362) (March 1980).
7. R. H. Chapman, J. V. Cathcart, and D. O. Hobson, "Status of Zircaloy Deformation and Oxidation Research at Oak Ridge National Laboratory," in *Proceedings of Specialists Meeting on the Behavior of Water Reactor Fuel Elements Under Accident Conditions, Spatind, Norway, September 13-16, 1976*, CSNI Report No. 13 (1977).
8. R. H. Chapman et al., "Zircaloy Cladding Deformation in a Steam Environment with Transient Heating," in *Proceedings of Fourth International Conference on Zirconium in the Nuclear Industry, Stratford-on-Avon, England, June 26-29, 1978*, ASTM STP 681 (1979).
9. R. T. Bailey, *Steady-State Pressure Losses for Multirod Burst Test (MRBT) Bundle B-5*, NUREG/CR-2597 (ORNL/Sub/80-40441/1) (April 1982).
10. R. L. Anderson, K. R. Carr, and T. G. Kollie, *Thermometry in the Multirod Burst Test Program*, NUREG/CR-2470 (ORNL/TM-8024) (March 1982).
11. A. W. Longest, J. L. Crowley, and R. H. Chapman, *Variations in Zircaloy-4 Cladding Deformation in Replicate LOCA Simulation Tests*, NUREG/CR-2810 (ORNL/TM-8413) (September 1982).

12. A. W. Longest, R. H. Chapman, and J. L. Crowley, "Boundary Effects on Zircaloy-4 Cladding Deformation in LOCA Simulation Tests," *Trans. Am. Nucl. Soc.* 41, 383 (1982).
13. R. H. Chapman, J. L. Crowley, and A. W. Longest, "Effect of Bundle Size on Cladding Deformation in LOCA Simulation Tests," paper presented at Sixth International Conference on Zirconium in the Nuclear Industry, Vancouver (B.C.), Canada, June 28-July 1, 1982.

The following limited-distribution quick-look and data reports have been issued by this program:

1. R. H. Chapman (comp.), *Quick-look Report on MRBT No. 1 4 x 4 Bundle Burst Test*, Internal Report ORNL/MRBT-2 (September 1977).
2. R. H. Chapman (comp.), *Quick-look Report on MRBT No. 2 4 x 4 Bundle Burst Test*, Internal Report ORNL/MRBT-3 (November 1977).
3. R. H. Chapman, *Quick-look Report on MRBT No. 3 4 x 4 Bundle Burst Test*, Internal Report ORNL/MRBT-4 (August 1978).
4. R. H. Chapman, *Quick-look Report on MRBT B-4 (6 x 6) Bundle Test*, Internal Report ORNL/MRBT-6 (February 1981).
5. R. H. Chapman et al., *Quick-look Report on MRBT B-5 (8 x 8) Bundle Test*, Internal Report ORNL/MRBT-5 (July 1980).
6. R. H. Chapman et al., *Quick-look Report on MRBT B-6 (8 x 8) Bundle Test*, Internal Report ORNL/MRBT-7 (January 1982).
7. R. H. Chapman et al., *Bundle B-1 Test Data*, ORNL/NUREG/TM-322 (June 1979).
8. R. H. Chapman et al., *Bundle B-2 Test Data*, ORNL/NUREG/TM-337 (August 1979).
9. R. H. Chapman et al., *Bundle B-3 Test Data*, ORNL/NUREG/TM-360 (January 1980).

EXPERIMENT DATA REPORT FOR MULTIROD BURST  
TEST (MRBT) BUNDLE B-4

A. W. Longest      R. H. Chapman  
                    J. L. Crowley

ABSTRACT

A compilation of bundle B-4 test data is presented. These data were obtained during the test and from pretest and posttest examination of the test array. They are presented in considerable detail but with minimum interpretation.

The B-4 test is the only 6 x 6 array in a series of 4 x 4, 6 x 6, and 8 x 8 bundle tests performed by the Multirod Burst Test Program at Oak Ridge National Laboratory. This research is sponsored by the Nuclear Regulatory Commission and is designed to investigate Zircaloy cladding deformation behavior under simulated light-water reactor loss-of-coolant accident conditions.

The specific objectives of the B-4 test were to investigate axial propagation of cladding ballooning as the result of rod-to-rod contact and to determine the effect of a relatively cold fuel pin simulator on the deformation behavior of its hotter neighbors under test conditions known to produce large deformation. These objectives were not realized, however, because the temperature transient did not proceed to the planned failure conditions. Electrical power to the bundle was lost when the bundle average cladding temperature was  $\sim 675^{\circ}\text{C}$ . The bundle temperature slowly decreased ( $\sim 0.2$  K/s for  $\sim 380$  s), and the tubes deformed (by creep) until pressure was vented from the tubes to terminate the test.

Significant deformation occurred (up to 18% average strain over the heated length), but none of the tubes burst. The bundle was disassembled, and deformation profiles of the individual tubes were measured. Although objectives of the test were not met, the data appear useful for model development and verification.

A brief description of the experiment and a summary of the test results are included with the detailed results of the B-4 test. Both graphical and tabular formats are used to show temperature and pressure data as functions of test time and strain data for the cladding in each of the fuel rod simulators. Photographic documentation is provided for both the overall bundle, before and after testing, and the 36 tubes as they were removed from the tested bundle for strain measurements.

The purpose of this report is to provide a background document for interpretative reports published previously and to be published in the future.

---

## 1. INTRODUCTION

This report presents, in detail, the experimental data for the B-4 test (the only 6 x 6 multirod burst test) conducted within the framework of the Multirod Burst Test Program at Oak Ridge National Laboratory. This work is sponsored by the Division of Accident Evaluation of the Nuclear Regulatory Commission and is designed to investigate Zircaloy cladding deformation behavior under simulated loss-of-coolant accident (LOCA) conditions. The report is intended primarily as a source document for B-4 test results, with a minimum amount of interpretation of the data. Because of this, it should be read in conjunction with other published results and interpretations.<sup>1,2</sup>

The objectives of the B-4 test were to investigate axial propagation of cladding ballooning as the result of rod-to-rod contact and to determine the effect of a relatively cold fuel pin simulator on the deformation behavior of its hotter neighbors under test conditions known to produce large deformation. Consistent with these objectives, initial conditions were established to cause the tubes to burst at  $\sim 800^{\circ}\text{C}$  after  $\sim 90$  s of heating at a rate of  $\sim 5$  K/s, and the test was initiated. However, technical difficulties were encountered during the transient. After 60 s of heating and  $\sim 10$  s after the onset of deformation, electrical power was terminated by the automatic control system; the bundle average cladding temperature at the time was  $\sim 675^{\circ}\text{C}$ . While attempts were being made to restore power, the tubes continued to deform under near-isothermal creep conditions. These conditions continued for  $\sim 380$  s, at which time the tubes were depressurized, and the test was terminated. Although significant deformation occurred, none of the tubes burst.

The loss of power was caused by a 0- to 60-s backup timer that was inadequately bypassed after it was used to terminate a short (15-s) power-bump checkout transient. Although an electrical bypass circuit was installed around the timer contacts in the primary shutdown circuit, a redundant shutdown circuit was not bypassed, and this caused termination of the transient after 60 s.

Although primary objectives of the test were not realized, the data appear useful for model development and verification, particularly with respect to "flat-topped" transients.

Following the format of the previous reports in this series,<sup>3-5</sup> a brief description of the test design and procedure will be given, followed by the test results.



## 2. TEST DESCRIPTION

### 2.1 Assembly

Figure 1 shows a simplified drawing of the B-4 test assembly. As indicated in Sect. B-B of the figure, the shroud was constructed of thin (0.13-mm-thick) stainless steel, with a highly reflective gold plating, and was backed by insulating material and a strong structure to withstand radial forces during the test transient. The shroud was spaced one-half of a coolant channel distance (1.75 mm) from the outer rod surfaces. This permitted some deformation of these simulators before contact with the shroud but prevented gross outward movement of the simulators. This design concept was also used in the B-5 (8 x 8) test, which was conducted prior to the B-4 test. The inlet steam arrangement was modified from a single nozzle on the north side, as used in the B-5 test, to diametrically opposed nozzles on the east and west sides of the bundle (Sect. A-A in the figure) to obtain a more uniform inlet temperature distribution than existed in B-5. As will be discussed later, this and other improvements were effective.

Figure 2 gives pertinent details of a typical fuel pin simulator, and Table 1 lists as-built data for the B-4 simulators. The fuel simulators (internal heaters) used in B-4 included those used in the earlier B-2 and B-3 tests (16 heaters each) plus an additional four from the original lot of simulators purchased from SEMCO for the 4 x 4 tests. The axial heat generation profiles of the simulators were characterized by pretest infrared (IR) scans.<sup>6</sup> The highest quality simulators were selected for the bundle interior positions.

The Zircaloy-4 tubes (10.92-mm OD by 0.635-mm wall thickness) used to fabricate the test assemblies came from the master lot of tubing purchased for use in several NRC-sponsored cladding research programs.<sup>7</sup> Serial numbers of the tubes are given in Table 1, and fabrication of the simulators and test array is discussed in Ref. 2.

Each fuel pin simulator was instrumented with a fast-response, strain-gage-type pressure transducer and four Inconel-sheathed (0.71-mm-OD) type K thermocouples with ungrounded junctions. The thermocouples were spot-welded to the inside of the Zircaloy-4 tubes, using a device developed specifically for this purpose.<sup>8</sup> Their positions are shown in Fig. 3, which also gives thermocouple identifications for use in subsequent figures (the nomenclature TE 10-4 identifies the No. 4 thermocouple in the No. 10 simulator). The axial locations of the thermocouples are also shown in Fig. 4. One thermocouple (TE 26-3) read ~20°C low throughout the transient; its reading is suspect.

Eight, 0.13-mm-diam bare-wire, type S thermocouples were spot-welded on the outside surface of the thin shroud surrounding the rod array. Two thermocouples were attached to each side at positions shown in Fig. 3 in an attempt to obtain information on both the axial and circumferential temperature distributions. The shroud thermocouple identifications are also given in the figure for use in subsequent temperature plots.

Five thermocouples (TE-320 through TE-324) were located in the tube matrix at the 107-cm elevation (centerline elevation of the steam inlet

nozzles) to obtain inlet steam temperature measurements. Five thermocouples (TE-325 through TE-329) were similarly dispersed in the tube matrix near the bottom of the heated zone (at the 3-cm elevation) to obtain outlet steam temperature measurements in the bundle at this elevation. Figure 5 shows the identifications and locations. These thermocouples were 0.71-mm-diam, stainless steel-sheathed, type K with ungrounded junctions.

A detailed description of the temperature measurement systems and a comprehensive analysis of the errors and uncertainties associated with the measurements have been reported previously.<sup>9</sup>

Millivolt signals from the pressure transducers, thermocouples, and electrical power measuring instruments were recorded on magnetic tape by a computer-controlled data acquisition system (CCDAS) for subsequent analysis. Calibration corrections, programmed into the computer system, were automatically applied to the millivolt signals before printout of the data.

## 2.2 Operations

It was planned that the powered portion of the test would be terminated by any of three actions: (1) CCDAS action resulting from a signal that 32 of the 36 simulators had burst, (2) CCDAS action resulting when 75 simulator thermocouples had exceeded the upper temperature limit (50°C above the anticipated burst temperature) on each of three successive data scans, or (3) operator override. The powered phase of the test was terminated prematurely by a timer circuit that was not effectively bypassed as discussed earlier.

Heatup of the test assembly was initiated early in the afternoon of Jan. 14, 1981; the temperature was near 200°C at the end of the work shift. Power adjustments to the vessel heaters were made to maintain the temperature near this value during the next 12 h to avoid temperature cycling the test assembly. About 4:00 AM on January 15, power to the vessel heaters was increased, and superheated steam was admitted to the vessel in the approach to the initial test temperature. Throughout this phase of operation, periodic leak checks indicated the simulator seals were performing very well (i.e., <10 kPa pressure loss per min at 8600 kPa and ~330°C).

After thermal equilibration (~330°C) of the test assembly was attained, the simulators were pressurized to ~5300 kPa, and a short power run (~15-s transient) was conducted at 12:30 PM to ascertain that the data acquisition system (DAS) and all the instrumentation were functioning properly and that the performance of the test components was as expected. Simulator 27 was earmarked at this time to be the unheated one. Other than omitting the fuse from its electrical circuit and setting its initial pressure level at 500 kPa (to preclude deformation), this simulator was identical to the others. Examination and evaluation of the quick-look data from this short transient, which increased the temperature of the simulators to ~410°C, indicated voltage adjustments were not needed to achieve the desired heating rate of 5 to 6 K/s.

Simulator 16 developed a severe leak during the time (~5 h) between the pretest power-bump and the test. The magnitude of the leak was such

that for deformation to be comparable to the other simulators, it would be necessary to test the simulator at constant pressure by inflow of helium at a rate equal to the leak. Rather than degrade the quality of the deformation data by this expediency, a decision was made to select No. 16 (instead of No. 27) as the unpressurized (actual pressure of 560 kPa) and unheated simulator. All the remaining simulators were leak tight (leak rates of  $<10$  kPa/min at 9300 kPa and  $332^{\circ}\text{C}$ ) and were tested in the usual manner (i.e., with the individual isolation valves to the supply header closed to provide a constant gas inventory in each simulator during the transient).

Superheated steam entered the array on the east and west sides at the 107-cm elevation (Fig. 1) and flowed downward through the bundle during the test at a mass flux of  $\sim 279$  g/s $\cdot$ m $^2$ . Inlet steam conditions of  $\sim 327^{\circ}\text{C}$  and  $\sim 305$  kPa (absolute) resulted in a Reynolds number of  $\sim 132$  at the inlet end of the bundle. These inlet conditions remained essentially constant throughout the transient, although a small perturbation (lasting 10 to 15 s) occurred about 140 s after power-off, as will be discussed later.

Following stabilization of the bundle temperature at  $\sim 332^{\circ}\text{C}$ , all the fuel simulators except No. 16 were pressurized simultaneously to  $\sim 9100$  kPa (differential above the external coolant pressure) and isolated from the supply header. Pressure in the unheated simulator (No. 16) was set at  $\sim 560$  kPa (differential) to preclude deformation. With these initial conditions established, the test transient was initiated. The tubes were expected to burst at  $\sim 800^{\circ}\text{C}$  after  $\sim 90$  s of heating at a rate of  $\sim 5$  K/s. However, after 60 s of heating and about 10 s after the onset of deformation, electrical power to the bundle was terminated by the automatic control system; the bundle average cladding temperature at the time was  $\sim 675^{\circ}\text{C}$ . Hurried attempts to diagnose the cause of the outage and to restore power were unsuccessful. The bundle temperature slowly decreased ( $\sim 0.2$  K/s), and the tubes continued to deform under near-isothermal creep conditions during this time. After  $\sim 380$  s the tubes were depressurized to preclude further deformation.

With conditions stabilized after depressurization, quick-look evaluation of the recorded pressure data revealed that none of the tubes had burst, but appreciable deformation had occurred. Repressurizing the tubes and continuing the test to burst conditions would only render the data uninterpretable, because the initial conditions (i.e., the extent and distribution of the deformation in each tube at restart) would be unknown. Furthermore, this would prevent realization of a primary objective of the test (i.e., determination of the effect of a relatively cold rod on the deformation behavior of its neighbors). Consequently, a decision was made to terminate the test at this point so that it could be analyzed and interpreted in view of the reasonably well-defined test conditions.



### 3. SUMMARY OF TEST RESULTS

Tables 2-5 summarize pertinent data from the B-4 test. Initial pressure conditions (~9090 kPa) were selected to cause the tubes to burst at a temperature of ~800°C had the test been completed as planned. As indicated in Table 2, the initial temperature was ~332°C, and the temperature distribution in the bundle was very uniform (see Figs. 3 and 4 for thermocouple locations). The average temperature indicated by the eight shroud thermocouples was 335°C. Average indicated steam inlet temperature was 326°C, and the average outlet temperature was 335°C. The latter value indicates slight heating of the small steam flow (1.15 g/s) as it flowed downward through the test assembly.

Table 2 also lists the temperature indicated by each of the thermocouples at the time of maximum pressure for the respective simulators (5 to 10 s before power-off). The point of maximum simulator internal pressure occurs when the opposing effects of temperature increase and tube expansion are equal and indicates the onset of appreciable deformation. The spread in temperatures in a given simulator is not unusual, considering the location of the thermocouples and the power distribution of the fuel simulators as determined from the pretest IR characterization scans.

Simulator temperatures reached maximum values in the interval between 1 and 3 s after power-off (Table 3) and decreased steadily thereafter at ~0.2 K/s. The data of Tables 2 and 3 together indicate conditions were very uniform during the powered portion of the transient and to the point of maximum simulator temperatures.

Table 4 gives the simulator temperatures at the time of depressurization (vent) for the respective simulators (381-401 s after power-off). The indicated cladding temperature variations along each simulator and from simulator to simulator show the axial and radial temperature distributions were highly nonuniform near the end of the test.

Table 5 lists some of the volume-related data for the B-4 tubes. The initial gas volumes were quite uniform among the tubes - ranging from 47.8 to 51.7 cm<sup>3</sup>, about twice that of a full-length reactor fuel rod. Of the total initial volume (at room temperature), about 13% is in the heated portion of the annulus between the fuel simulator and the inside diameter of the Zircaloy tube, 10% is in the unheated portion of the annulus, 33% is in the pressure transducer and connecting tube, and 44% is distributed in the end regions (mostly at the upper end) of the fuel pin simulator. At any given time during the test, all these volumes have different temperatures (the major volumes remain at or near room temperature), ranging from room temperature to cladding temperature, and one cannot calculate accurately the fractional volume increase from the pressure decrease in a straightforward manner. Instead, we calculated the volume increase from the tube deformation profiles (assuming circular cross sections).

## 4. DETAILED TEST RESULTS

This section presents, in a number of subsections, the detailed results of the B-4 test. The purpose of this presentation is to provide a fairly complete reference source of uninterpreted data.

### 4.1 Transient Results

#### 4.1.1 Bundle behavior

The information contained in this section was obtained during the course of the B-4 test transient. The data were recorded by the DAS in the continuous scan mode (i.e., each sensor was sampled every 0.025 s) over a period of ~10 min. Each rod was instrumented with four thermocouples attached to the interior surface at various elevations (see Fig. 4) above the bottom of the heated zone. In addition, the heated shroud was monitored by eight thermocouples attached to its outer surface. These locations were shown previously in Fig. 3.

Superheated steam entered the array through two inlet nozzles located on the east and west sides of the bundle (Fig. 1) at the 107-cm elevation and flowed downward through the bundle at a mass flux of  $279 \text{ g/s}\cdot\text{m}^2$ , equivalent to an inlet Reynolds number of ~132 at the top of the heated zone (91.5-cm elevation). Apparently the nozzle arrangement and other modifications made after the preceding B-5 test, such as a steam distribution baffle just below the inlet (Fig. 1) to minimize flow channeling and additional heaters on the vessel closure flange to minimize heat losses from the flange via axial conduction along the simulators, were effective in producing a fairly uniform inlet steam temperature distribution in the matrix. This is illustrated in Fig. 5, which shows a schematic of the array with the locations, identifications, and temperature readings of the steam inlet and outlet thermocouples 1 s before power-on. The measurements indicate the temperature distribution was fairly uniform at the inlet and very uniform at the outlet. Also, the steam average temperature increased about  $9^\circ\text{C}$  while passing through the bundle.

Figures 6-15 present temperatures measured 1 s before power-on in the format of a schematic layout of the bundle at each of the instrumented sections. The layout represents the tube by eight dots, positioned at possible thermocouple azimuthal angles (Fig. 3), centered about the rod position number. An asterisk replaces a dot, indicating the azimuthal position of a thermocouple, if the junction is in the plane for which the particular map applies; the temperature measured by the thermocouple at the time is printed below the schematic representation of the tube. The respective row and column average temperatures are printed on the right and at the bottom of the layout. The cross section and bundle average temperatures, the elevation of the section, and other pertinent information are also included in the format. The thermocouples in simulator 16 (unheated) and those located at the grid elevations are excluded from the bundle average temperature. Also, if a particular thermocouple indicates a temperature  $25^\circ\text{C}$  greater or less than the section average, that reading is excluded (and noted in the format) from the averages.

The maps provide considerable data and greatly facilitate interpretation and evaluation of local and overall temperature distributions. As evident, the initial radial and axial temperature distributions were very uniform, indicating uniform distribution of the steam. Compare, for example, data in Fig. 6 for the 84-cm elevation with the inlet steam temperatures (at the 107-cm elevation) in Fig. 5. Also, compare Fig. 15 with Fig. 5 for the radial distributions at the lower end of the heated zone.

The overall radial temperature distribution may be visualized somewhat easier in the temperature map depicted in Fig. 16. The temperature given in the map for each simulator is the average of the thermocouple measurements for that simulator without regard to elevation, excluding measurements obtained from thermocouples at the grid elevations. Asterisk locations (and number) in the schematic representation of the simulators denote the azimuthal position of the thermocouples whose measurements comprise the average. Row and column averages are printed on the right side and at the bottom of the map, respectively, to facilitate visualization of uniformity.

Initial pressures are presented in a similar format in Fig. 17. Again the column of numbers on the right and the row of numbers at the bottom of the figure represent the row and column average pressures, respectively.

With these initial conditions established, the transient was initiated. A number of plots and data maps will be presented to illustrate the significant features of the test as it progressed and to provide an indication of the general conditions prevailing at the time of important events. A parameter TAV-10 will be plotted in a number of these figures to represent the bundle average temperature. This parameter is in reality the average of six thermocouples (TE 9-3, TE 14-2, TE 15-1, TE 21-3, TE 23-1, and TE 26-1) at the 38-cm elevation (see Fig. 3 for relative positions) that were electronically averaged and recorded during the test to facilitate visualization of the bundle temperature as a function of time. Because of the way this average temperature was derived, it differs slightly ( $<10^{\circ}\text{C}$ ) from the average calculated posttest from individual measurements. This small discrepancy is unimportant for quick-look characterization.

Figure 18 shows TAV-10 and the applied voltage during the powered portion of the transient; the average heating rate during this time was  $\sim 5.7$  K/s. The temperature measured by TE 16-3 on the unpressurized and unpowered simulator (at the same elevation as the thermocouples used to obtain TAV-10) is also shown for reference. Internal pressure (differential) measured on a corner (No. 1) and a central (No. 21) simulator are included to illustrate pressure behavior of exterior and interior simulators, respectively. Maximum pressure was encountered in all the pressurized simulators 5 to 10 s before power-off, indicating the onset of deformation had taken place. Pressure (Fig. 19) and temperature (Figs. 20-30) measurements made  $\sim 0.2$  s before power-off show conditions were very uniform at the time power was terminated; the effect of the unpowered simulator (No. 16) appears negligible up to this time.

Figure 31 shows the temperature behavior, as characterized by TAV-10 and TE 16-3, during the time attempts were being made to restore electrical power to the bundle. As evident, the temperature reached a maximum  $\sim 2$  s after power-off (Fig. 18) and decreased steadily thereafter ( $\sim 0.15$  K/s

based on TAV-10 and  $\sim 0.23$  K/s based on overall bundle average temperature, with the latter value reflecting development of axial and radial temperature gradients during this time). The temperature of the unpowered rod increased at a rate of  $\sim 1.7$  K/s during the first 100 s of unpowered operation and at a reduced rate thereafter until it reached essential equilibrium with TAV-10  $\sim 300$  s after power-off.

The figure also shows the pressure behavior of the first (No. 1) and last (No. 25) simulators to be depressurized and of the simulator (No. 14) that exhibited the greatest pressure decrease before depressurization. Because the temperature decrease before venting was moderate, the predominant cause of the observed pressure decrease was creep deformation.

The first simulator (No. 1) was vented to the supply header at  $\sim 441.5$  s from power-on and the last (No. 25) at  $\sim 461.5$  s, creating conditions that precluded further deformation. About 30 s after venting the simulators to the header and each other (at a common pressure of  $\sim 3620$  kPa), the header was vented to  $\sim 800$  kPa, and the bundle was allowed to continue cooling without disturbing the inlet steam conditions.

Discussion of the short temperature perturbation evident  $\sim 200$  s after power-on in Fig. 31 will be deferred to a later point.

Pressures measured  $\sim 0.7$  s before the first simulator was vented are shown in Fig. 32. Because the pressures changed very little from the time of these measurements to that of venting the individual simulators, the pressures are very good estimates of those existing at the time of venting (Table 4). Because the final pressure can be correlated with deformation, the map provides an indication of how the deformation is distributed with respect to simulator position. As would be expected, the exterior simulators have less deformation than the interior ones, with the corner simulators having the least deformation.

Also, deformation is greater in the lower left triangular half of the bundle formed by simulators at the No. 1, No. 31, and No. 36 positions than in the upper right half. This may be an effect of the unpowered simulator (No. 16) in the upper right half.

Temperature measurements made at the same time (i.e.,  $\sim 0.7$  s before venting of the No. 1 tube and  $\sim 380$  s after power-off) are shown in Figs. 33-42. The axial and radial temperature distributions were highly nonuniform as may be deduced by comparison of (1) the individual measurements and averages within a section, (2) the various section averages with the bundle average, and (3) the simulator averages in the radial temperature map given in Fig. 43.

Thermocouples were attached to the outside surface of the (electrically) unheated shroud to obtain information about shroud axial and azimuthal temperature variations. As indicated in Fig. 3, two thermocouples were located at each of four elevations, with one of the two thermocouples being positioned directly opposite a simulator and the other being positioned between two simulators. Because the shroud was very thin ( $\sim 0.13$  mm thick), significant variations might be expected from the thermocouple measurements. Figure 44, which compares shroud temperature measurements at the 76-cm elevation during the powered portion of the transient with cladding temperature measurements obtained from simulators in the vicinity of the shroud thermocouples (Fig. 3), confirms this expectation. The figure shows that the thermocouple (TE 91-2) located opposite the simulator



thermocouple (TE 32-3) indicated a much higher temperature than that indicated by the thermocouple midway between two simulators. In fact, ~33 s after power-on, the shroud thermocouple (TE 91-2) reading indicated an increased heating rate as if the simulator and shroud were in contact. The matched simulator thermocouple (TE 32-3) showed a decreased heating rate at the same time, as if local cooling conditions had changed. Post-test visual examination of the shroud panel showed significant temperature variations existed during the transient as revealed by the degree of oxidation evident on the unplated backside of the stainless steel surface.

The shroud thermocouples at three of the four instrumented elevations showed this general behavior. Although this may be interpreted as evidence that the simulators bowed outward to contact the closely spaced shroud during the test, the timing (well before the onset of deformation) and uniformity of deformation suggest that the thin shroud panel buckled (locally) inward and touched the simulators.

Figure 45 shows measurements obtained from the same sensors over a much longer time span. The perturbation ~200 s after power-on was very pronounced on the shroud and simulator thermocouples at this elevation. The perturbation was caused by partial opening of steam valves upstream and downstream of the test vessel by action of interlocks during an attempt to restore power to the bundle; Fig. 46 will facilitate explanation of the event.

The steam flow rate is controlled by a small valve downstream of the vessel, and the steam pressure in the vessel, indicated by PE 301 in the figure, is controlled by a pressure regulator upstream of the vessel. After the tubes burst (in a normal burst test), a large downstream valve opens to relieve the vessel pressure, and a large upstream valve opens simultaneously to admit a large flow of steam from the building supply to cool the bundle. Actuation of these valves is controlled through interlock circuits that require the proper sequence of events. In an attempt to reinitialize the sequence for start-up of the electrical power generator, the valves were opened partially as indicated in Fig. 46 by the sharp decrease in vessel pressure (PE 301) at ~195 s after power-on and closed 12 to 15 s later.

Measurements by the inlet and outlet steam thermocouples, of which an example of each (locations given in Fig. 5) is plotted in the figure, indicated significant temperature changes as a result of the sudden increase in steam flow. The first response was an increase in temperature caused by a reduction in residence time in the steam inlet line (i.e., less sensible heat loss from the highly superheated steam as it passed through the line). Shortly thereafter the superheated steam was displaced by a larger flow of saturated (or only slightly superheated) steam, causing the inlet steam temperature to decrease to ~125°C. This relatively cold steam provided good cooling conditions for a few seconds. Shortly thereafter, the vessel pressure, steam flow rate, and inlet temperatures returned to their original values and were maintained at these values until well after the test was terminated.

The short period of rapid cooling caused significant perturbation of the simulator pressures (differential) and cladding temperatures as shown by the plots presented in the next section.

#### 4.1.2 Fuel pin simulator pressure and temperature plots

Individual pressure (differential) and temperature curves for the simulators are shown in Figs. 47-82. An arrow is located on the abscissa in the figures to mark the time at which power was terminated. These curves were computer-plotted at 0.2-s intervals from the magnetic data storage tapes. Each of the figures is comprised of four temperature plots (corresponding to the four thermocouples attached to the individual simulator cladding ID) and one pressure curve. Thermocouple identification in the figures follows the numbering scheme shown in Figs. 3 and 4.

Except for unpressurized (actual pressure of ~560 kPa) and unheated simulator No. 16 (Fig. 62), the vent time for each simulator can be detected by the sudden drop in the pressure curve. The point of maximum pressure (see Table 2) is an indication that the onset of deformation has taken place. Subsequent plastic deformation caused a continuing decrease in pressure until venting occurred.

### 4.2 Pretest and Posttest Results

The information contained in this section was obtained from the pretest and posttest examinations of the B-4 test array. Some information, such as the simulator IR scans, resulted from quality assurance efforts made to characterize the test components. Other information, such as bundle disassembly photographs, were obtained as a step in the posttest examination of the bundle. The results are presented in considerable detail, because we believe the data are extremely important to the interpretation of the test in terms of deformation behavior and distribution.

#### 4.2.1 Pretest bundle photographs

Although not directly applicable to the interpretation of the B-4 test, selected photographs of the bundle assembly are included in this section for general interest. Various details of the construction and monitoring instrumentation may be seen.

A view of the B-4 array before installation of the shroud around the bundle is shown in Fig. 83. As described earlier the 6 x 6 bundle design is basically a scaled-down version of the preceding 8 x 8 bundle (B-5) design. A close-fitting shroud of the same design as the one used in B-5 was used to simulate the radial restraint in a nuclear fuel assembly. The shroud was spaced one-half of a coolant channel distance (1.75 mm) from the outer rod surfaces. A view with three sides of the shroud assembled around the bundle is shown in Fig. 84. Details of the shroud panels are shown in Fig. 85. The completely assembled bundle is shown in Fig. 86.

In scaling down the B-5 design, several changes were made in an attempt to improve performance. These included improving the steam distribution at the bundle inlet and outlet. Instead of one steam inlet on the north side of the shroud, the flow was directed to two sides (east and west), as can be seen in Fig. 86. Additionally, a flow distribution baffle (Fig. 83) with 12.3-mm-diam holes for the 10.92-mm-diam rods was positioned between the steam inlet and the uppermost grid. A steam deflector

(Fig. 83) was added to minimize impingement of hot steam on the lower seal glands of the fuel pin simulators.

Figure 87 shows a typical shroud thermocouple attachment. Each thermocouple was formed by making a ball junction (~0.4-mm diam) on the end of 0.13-mm-diam type S wires. The ball was then spot-welded to the back side of the thin shroud reflector strip. The mass of the thermocouple was kept small to minimize thermal shunting, this is, cooling of the reflector at the point of attachment by the thermocouple itself. An even smaller type S wire (0.076-mm diam) was used in B-5 but was found to be difficult to work with and too fragile for this particular application. The small thermocouple wires exited through an insulator at the center of a plug, as shown in Fig. 88. The wires were spliced (Fig. 88) to 0.25-mm-diam bare wires exiting a sheathed type S thermocouple having a glass end seal to prevent ingress of moisture. A protective cover was installed over the area where the thermocouple wires exited the shroud panel (Fig. 86).

A view of the lower end of the bundle showing the outlet steam thermocouples is shown in Fig. 89. All the steam thermocouples were 0.71-mm-diam stainless steel-sheathed Type K with insulated junctions. The junction end was centered within the flow channel with a ceramic spacer.

#### 4.2.2 Posttest bundle photographs and general examination results

Following cooldown, the assembly was removed from the test vessel and partially disassembled to facilitate photography and dimensional measurements for documentation.

Because none of the tubes burst, posttest leak checks were made on all the simulators; two had developed leaks. One of these (No. 16) developed a leak prior to the test. Posttest examination revealed the leak to be at the brazed seal joining the copper electrical lead to the stainless steel portion of the ceramic insulated seal gland at the lower end of the fuel pin simulator. (Figure 2 indicates a Swagelok ferrule and gland-type seal, but it has been our practice to make this seal by silver brazing.) The leak in the other simulator (No. 22) developed during posttest cooldown. Posttest examination showed the leak location to be at the multipin Teflon seal at the insulating gland at the upper end of the simulator (Fig. 2). Both of these simulators leaked at locations not previously identified as troublesome points.

Visual observations confirmed that deformation was moderate and uniformly distributed over the heated length as expected from the test conditions. Figure 90 shows an overall view of the west face of the test array after removal of the shroud and internal heaters. The west face of the shroud, shown below the bundle, is located in its correct axial position relative to the bundle. One of the steam inlet nozzles is visible in the shroud near the upper end of the bundle.

Posttest views of the four faces of the bundle are shown in Fig. 91; the meter scale is positioned so that the 0-cm mark is at the bottom and the 91.5-cm mark is at the top of the heated length. Deformation uniformity is evident in the photographs. However, localized ballooning of simulator No. 14 (an interior simulator) is obvious, particularly in the east



and west face views at the 49-cm mark. This is the simulator with the greatest volume increase (Table 5). Two close-up views of this region of the bundle are shown in Fig. 92 as viewed from the west face at slightly different camera angles. These views indicate the ballooned region is symmetrical and not in contact with the No. 8 simulator. However, one cannot see through the bundle from the north face in this region, indicating that the ballooned portion is perhaps in contact with the neighboring simulators (Nos. 13 and 15).

Because deformation was modest and uniformly distributed, a decision was made to forgo flow characterization of the test array and to disassemble the bundle to permit direct measurement of the strain profile of the individual tubes. Disassembly was accomplished by slitting the grids to facilitate removal of a layer of tubes as a unit. A photograph was taken of the remaining portion of the bundle each time a layer of tubes was removed. This operation started on the south side of the bundle (i.e., tubes 31-36 were removed first) and progressed northward. Figure 93 presents a composite of the photographs, showing the bundle as each layer of tubes was uncovered. Except for tube No. 14, deformation in all the tubes (No. 16 was not pressurized and, hence, undeformed) is uniformly distributed. Figure 94 shows an enlarged portion of the ballooned region of tube No. 14.

The tubes were freed from the tube layer subassemblies for strain profile measurements. The results are given in the next section.

Axial shrinkage occurs with circumferential strain in tests, such as this one, conducted in the alpha temperature region. Axial shrinkage data (Fig. 95) are reasonably consistent with the other data, indicating greater shrinkage (and greater circumferential strain) on the average on the interior simulators compared with the exterior ones.

#### 4.2.3 Strain data and tube strain profiles

Circumferential strain measurements were made on the individual B-4 tubes at 20-mm intervals, using a modified-planimeter-wheel mechanism developed for single rod tests. This mechanism, described previously,<sup>10</sup> is capable of resolving a circumference of 75 mm into 1000 parts to give a resolution of 0.075 mm. Table 6 tabulates the strains obtained in this way at each axial position for each tube; the values are given in percentage increase of original tube circumference. A measure of the accuracy is also evident by the data for tube No. 16, which did not deform. The maximum observed strain was 50% at the 48-cm elevation in simulator No. 14, which is also the elevation with the maximum total deformation (sum of all tubes).

The strain data were used to plot axial profiles of the individual tubes; these are presented in Figs. 96-131. The pretest IR characterization scans of the fuel simulators (internal heaters) and the pretest axial positions of the thermocouples are also shown for reference purposes.

All the deformation profiles have certain characteristics, more or less independent of the characteristics of the individual fuel simulators. These include strains of 2 to 6% in the region of the grids (centered about the 10- and 66-cm pretest elevations) and maximum strains of 2 to 7% in the region between the bottom of the heated zone and the lower grid.



Most tubes exhibited maximum strains of 5 to 15% in the region between the upper grid and the top of the heated zone. Strain in this region is strongly influenced by the cooling effect of the inlet steam.

Strains in the region between grids are rather uniform as expected from the test conditions, except for tube No. 14. As mentioned earlier, tube No. 14 exhibited the greatest volume increase (Table 5) and was the only tube with a large localized balloon (Fig. 109). Tube No. 16 (unpressurized and unpowered) showed no significant strain (Fig. 111) as expected.

The deformation profiles correlate reasonably well with the pretest IR characterization scans, considering that (1) the grids have a strong restraining effect over 10 to 15 cm of length, (2) the characterization scans are for a single angular orientation but circumferential temperature gradients are known to exist in the SEMCO fuel simulators, and (3) the characterization scans are for a heating rate of ~40 K/s whereas the test was conducted at a heating rate of ~5.7 K/s (powered portion) with most of the deformation occurring under near-isothermal conditions after power was terminated. The large localized balloon on tube No. 14 (Fig. 109) corresponds to a high peak in the IR scan; power was off while most of the deformation was occurring, as indicated by the pressure trace in Fig. 60.

Excessive ballooning over an extended length is a concern in LOCA analyses. For the tubes and spacing (10.92-mm OD on a 14.43-mm-square pitch; 1.32 pitch-to-diameter ratio) used in our tests, adjacent tubes will touch with 32% uniform expansion. As evident from the deformation profiles, only tube No. 14 experienced strains greater than this value and those strains exceeding 32% are over a length of only approximately eight (original) tube diameters (Fig. 109).

Another important characterization of tube deformation is the volume increase over the heated length. This parameter is closely related to flow resistance, because the volume increase takes into account deformation along the length of the tube. The volume increase was calculated for each of the tubes from the strain data given in Table 6 by using the equation for the volume of a cone frustum to estimate the subvolume for each length interval between strain measurements, summing these subvolumes over the heated length, and subtracting the original volume from the sum. The results of this analysis are included with other characteristics of the test presented earlier in Table 5.

#### 4.2.4 Coolant channel flow area restriction

As evident from the deformation profiles for the individual tubes, overall bundle deformation was moderate. The total expansion for all tubes at each axial position is normally of interest because it determines the coolant channel flow area restriction. This parameter was calculated on the basis of a rod-centered unit cell, using the equation

$$B = 100 \times \frac{\sum_{n=1}^{n=N} (A_{d,n} - A_o)}{N (p^2 - A_o)},$$

where

- $B$  = percentage restriction in coolant channel flow area,  
 $A_{d,n}$  = outside area of deformed tube ( $\text{mm}^2$ ),  
 $A_o$  = outside area of original tube ( $\text{mm}^2$ ),  
 $p$  = tube-to-tube pitch in square array (mm),  
 $N$  = number of tubes in square array.

With this definition,  $B$  is 0% for no deformation and 100% if all the tubes deform into a square whose sides are of length  $p$  (completely filling the open area). For the case of uniform ballooning such that the tubes just come into contact (i.e., 32% strain for the dimensions appropriate to this test),  $B$  is 61%.

The deformed tube areas were calculated from the strain data given in Table 5, assuming the tube cross sections are circular. Table 7 gives the deformed tube areas  $A_{d,n}$  for each tube at each axial position. The areas were used in the above equation to calculate the coolant channel flow area restriction at each position.

Flow area restriction calculations were performed for the entire 6 x 6 array and for the inner 4 x 4 array. These results are tabulated in Table 8 and plotted in Fig. 132. The cross-sectional area occupied by the grids ( $\sim 100 \text{ mm}^2$ ) was not included in the calculation; including this area would slightly increase the restriction at the grid locations centered about elevations 10.3 and 65.4 cm. The pretest elevation of the upper grid was 66.0 cm; axial shrinkage during the test accounts for the difference in pretest and posttest locations.

The maximum loss in flow area occurred at the 48-cm elevation and amounted to 21.2% for the entire 6 x 6 array and 30.7% for the inner 4 x 4 array. These data agree with the previous observations that the deformation was moderate and uniformly distributed in the region between the two interior grids and that the interior simulators deformed more than the exterior ones.

## ACKNOWLEDGMENTS

Data presented in this report reflect the combined effort of a number of people over an extended period of time, spanning fabrication, testing, and pretest and posttest examination of the test array.

We wish to acknowledge the contribution of W. A. Bird for his careful attention to all the instrumentation and control aspects of the test; E. L. Biddle, J. N. Money, and C. Cross for assembly of the test array and for the many other necessary support tasks; F. R. Gibson for programming and operating the CCDAS and for processing the strain data; the Fuel Pin Simulator Development Group, under the leadership of R. W. McCulloch, for development and procurement of the fuel simulators; and the many other groups and individuals who had a part in the test.

## REFERENCES

1. A. W. Longest, *Multirod Burst Test Program Prog. Rep. January-June 1981*, NUREG/CR-2366, Vol. 1 (ORNL/TM-8058).
2. R. H. Chapman, *Multirod Burst Test Program Prog. Rep. July-December 1980*, NUREG/CR-1919 (ORNL/NUREG/TM-436).
3. R. H. Chapman et al., *Bundle B-1 Test Data*, ORNL/NUREG/TM-322 (June 1979).
4. R. H. Chapman et al., *Bundle B-2 Test Data*, ORNL/NUREG/TM-337 (August 1979).
5. R. H. Chapman et al., *Bundle B-3 Test Data*, ORNL/NUREG/TM-360 (January 1980).
6. W. A. Simpson, Jr., et al., *Infrared Inspection and Characterization of Fuel-Pin Simulators*, ORNL/NUREG/TM-55 (November 1976).
7. R. H. Chapman, *Characterization of Zircaloy-4 Tubing Procured for Fuel Cladding Research Programs*, ORNL/NUREG/TM-29 (July 1976).
8. W. E. Baucum and R. E. Dial, *An Apparatus for Spot Welding Sheathed Thermocouples to the Inside of Small Diameter Tubes at Precise Locations*, ORNL/NUREG/TM-33 (August 1976).
9. R. L. Anderson, K. R. Carr, and T. G. Kollie, *Thermometry in the Multirod Burst Test Program*, NUREG/CR-2470 (ORNL/TM-8024) (March 1982).
10. R. H. Chapman, *Multirod Burst Test Program Prog. Rep. April-June 1976*, ORNL/NUREG/TM-74.

Table 1. As-built data for fuel pin simulators in B-4 test

Bundle position No.	Zircaloy tube serial No.	Internal fuel simulator <sup>a</sup>		Fuel pin simulator <sup>b</sup> gas volume (cm <sup>3</sup> )
		Serial No.	Element resistance ( $\Omega$ )	
1	0725	2828052	4.13	48.5
2	0173	2828072	4.08	49.5
3	0839	2828068	4.07	48.3
4	0099	2828057	4.15	50.6
5	0825	2828083	4.04	47.8
6	0180	2828070	4.02	49.0
7	0181	2828056	4.02	50.3
8	0826	2828067	4.10	48.5
9	0182	2828044	4.08	49.8
10	0734	2828050	4.17	49.6
11	0100	2828046	4.06	51.5
12	0729	2828058	4.01	49.9
13	0736	2828051	4.18	50.4
14	0096	2828060	4.09	51.7
15	0827	2828081	4.09	48.1
16	0090	2828047	4.07	50.5
17	0730	2828049	4.18	49.1
18	0183	2828082	4.07	50.2
19	0184	2828080	4.04	49.2
20	0831	2828048	4.15	50.3
21	0185	2828071	4.04	50.3
22	0735	2828035	4.03	51.0
23	0198	2828078	4.15	49.9
24	0728	2828045	4.07	50.1
25	0832	2828076	4.12	47.9
26	0098	2828055	4.04	51.2
27	0833	2828086	4.18	47.9
28	0199	2828069	4.15	51.0
29	0834	2828064A	4.05	48.6
30	0089	2828061	4.08	50.8
31	0097	2828062	4.01	49.8
32	0835	2828039	4.05	48.3
33	0206	2828073	4.12	49.6
34	0836	2828084	4.04	49.0
35	0201	2828079	4.05	49.8
36	0844	2828085	4.10	48.0

<sup>a</sup>All 64 fuel simulators were fabricated by SEMCO.

<sup>b</sup>Fuel pin simulator gas volume measured at room temperature before installation into bundle; the volume measured includes a pressure transducer and connecting tube identical to the facility hookup for each simulator.

Table 2. Summary of B-4 initial conditions and conditions at time of maximum pressures

RCD NO.	INITIAL CONDITIONS						CONDITIONS AT TIME OF MAXIMUM PRESSURES						TIME <sup>a</sup> (SEC)
	DIFFERENTIAL PRESSURE (KPA)	TEMPERATURES (DEG C)					DIFFERENTIAL PRESSURE (KPA)	TEMPERATURES (DEG C)					
		TE-1	TE-2	TE-3	TE-4	AVG		TE-1	TE-2	TE-3	TE-4	AVG	
1	9095	332	332	331	330	331	9528	669	669	662	663	666	60.70
2	9077	330	329	330	335	331	9467	645	652	653	658	652	56.95
3	9091	329	328	331	330	330	9480	627	635	635	635	633	54.15
4	9091	330	332	330	330	331	9497	653	654	648	655	652	58.50
5	9099	334	332	334	332	333	9499	663	674	675	670	670	60.70
6	9076	333	335	335	336	335	9456	637	642	645	650	643	55.50
7	9105	335	333	335	334	334	9474	636	634	634	640	636	52.70
8	9088	335	333	332	334	333	9506	647	646	645	645	645	53.65
9	9079	334	335	333	329	333	9445	647	641	641	637	641	54.15
10	9078	330	326	331	331	329	9468	624	640	644	642	637	55.65
11	9064	330	331	330	331	331	9463	635	631	629	632	632	52.50
12	9064	330	331	330	332	331	9462	641	656	651	618	642	56.15
13	9091	331	330	330	332	331	9462	652	647	651	633	646	57.50
14	9095	331	331	331	331	331	9502	653	653	648	641	649	55.10
15	9094	334	331	334	331	333	9473	635	636	634	627	633	53.00
16 <sup>b</sup>	562	331	331	331	331	331							
17	9067	328	329	332	331	330	9456	641	644	649	653	647	57.10
18	9056	330	332	331	331	331	9441	647	650	645	645	647	56.95
19	9106	332	332	331	331	331	9475	636	645	641	644	642	55.60
20	9120	335	334	335	331	334	9518	645	644	640	642	643	53.75
21	9110	331	329	332	332	331	9482	644	643	649	639	644	54.10
22	9101	328	332	332	332	331	9478	639	647	650	628	641	55.50
23	9064	331	330	332	332	331	9448	636	642	638	629	636	53.75
24	9052	332	332	331	331	332	9444	635	644	640	642	640	55.05
25	9111	334	335	335	337	335	9475	657	654	654	634	650	57.80
26	9116	332	332	315	332	328	9516	644	641	607	644	634	53.45
27	9112	331	331	329	328	330	9484	641	630	635	632	634	53.80
28	9113	329	330	332	331	331	9506	649	656	641	653	650	56.25
29	9098	331	331	330	329	330	9489	634	634	631	629	632	52.45
30	9063	332	331	332	330	331	9435	659	643	644	647	648	56.75
31	9098	333	331	329	332	331	9473	633	641	644	647	641	56.65
32	9084	335	333	334	333	334	9469	630	653	624	658	641	56.30
33	9107	333	334	334	333	334	9472	649	653	651	644	649	56.85
34	9118	333	330	331	331	331	9477	653	642	650	654	650	56.70
35	9117	331	332	330	331	331	9464	649	641	648	650	647	57.50
36	9093	336	331	333	329	332	9450	638	641	647	634	640	57.40

<sup>a</sup> Time from power-on.

<sup>b</sup> Simulator No. 16 was unpressurized (~560 kPa) and unheated (electrically) during the test.



Table 3. Summary of B-4 conditions 2.25 s after power-off

DIFFERENTIAL		TEMPERATURE (DEG C)					DIFFERENTIAL		TEMPERATURE (DEG C)				
ROD NO.	PRESSURE (KPA)	TE-1	TE-2	TE-3	TE-4	AVG	ROD NO.	PRESSURE (KPA)	TE-1	TE-2	TE-3	TE-4	AVG
1	9444	672	672	666	666	669	2	9403	666	675	675	681	674
3	9410	665	672	674	673	671	4	9453	667	669	663	669	667
5	9397	665	677	679	673	674	5	9399	667	672	675	678	673
7	9380	682	681	676	686	681	8	9398	639	635	687	636	687
9	9347	686	679	681	676	681	10	9388	652	670	673	672	667
11	9378	682	679	678	681	680	12	9385	668	634	677	646	669
13	9396	673	666	672	650	665	14	9395	688	633	683	672	683
15	9386	679	682	680	669	677	16 <sup>a</sup>	550	403	415	407	411	409
17	9396	664	667	672	677	670	18	9382	668	674	667	668	669
19	9411	667	677	671	676	672	20	9408	690	683	678	686	686
21	9378	684	683	689	680	684	22	9380	669	678	680	655	673
23	9362	676	683	679	665	676	24	9374	667	678	674	674	673
25	9417	677	673	671	652	668	26	9403	687	636	656	589	679
27	9386	683	668	676	674	675	28	9425	673	634	668	681	673
29	9385	685	684	681	678	682	30	9376	683	669	664	669	671
31	9407	657	664	668	670	665	32	9393	654	680	651	635	668
33	9405	673	675	672	665	671	34	9403	676	665	675	676	673
35	9406	669	660	666	672	667	36	9398	655	662	666	652	659

<sup>a</sup> Simulator No. 16 was unpressurized (~560 kPa) and unheated (electrically) during the test.

Table 4. Summary of B-4 conditions at time of vent

\*\*\*\*\*

-----APPROXIMATE VENT CONDITIONS-----

ROD NO.	DIFFERENTIAL PRESSURE (KPA)	TEMPERATURES (DEG C)					VENT <sup>a</sup> TIME (SEC)
		TE-1	TE-2	TE-3	TE-4	AVG	
1	8824	508	548	570	572	550	441.46
2	8514	590	513	594	587	571	443.15
3	8513	595	513	599	599	576	444.40
4	8573	560	591	596	597	586	446.05
5	8610	547	592	590	507	559	447.20
6	8798	575	544	569	540	557	448.45
7	8303	586	597	550	565	574	449.94
8	7739	607	617	578	618	605	451.79
9	7808	617	585	621	516	585	453.34
10	8268	591	509	613	617	582	455.34
11	8189	564	598	604	608	593	453.99
12	8491	504	587	591	576	564	452.99
13	8295	602	522	605	581	577	451.64
14	7142	610	625	625	570	607	448.45
15	7991	631	586	618	630	616	446.40
16 <sup>b</sup>							
17	8393	510	568	610	614	576	448.65
18	8514	596	596	509	593	574	450.54
19	8375	600	594	567	604	591	452.34
20	7727	628	619	575	524	587	453.64
21	7434	618	580	631	631	615	455.04
22	7945	517	624	629	613	595	457.03
23	7998	617	573	605	568	591	458.98
24	8516	511	560	597	591	565	460.68
25	8472	596	594	515	588	573	461.48
26	7707	608	609	544	605	592	459.78
27	7630	624	570	616	520	582	459.68
28	7866	575	622	568	609	594	457.38
29	7954	612	607	608	514	585	457.33
30	8607	555	586	578	587	577	458.03
31	8820	534	563	570	575	561	456.93
32	8528	575	587	554	600	579	455.93
33	9476	601	604	606	564	594	455.83
34	8462	604	513	603	595	579	457.33
35	8618	582	588	588	553	578	459.28
36	8925	525	499	557	559	535	460.83

\*\*\*\*\*

<sup>a</sup>Time from power-on.

<sup>b</sup>Simulator No. 16 was unpressurized (~560 kPa) and unheated (electrically) during the test.



Table 5. Summary of B-4 test results related to volume changes

Rod No.	Initial gas volume <sup>a</sup> (cm <sup>3</sup> )	Approximate vent conditions			Initial-to-vent pressure ratio	Vent-to-initial gas volume <sup>b</sup> ratio	Volume increase of tube over heated length <sup>c</sup> (%)	Average strain <sup>d</sup> (%)
		Pressure (kPa)	Maximum measured temperature (°C)	Maximum strain (%)				
1	48.5	882.5	572	6.3	1.031	1.14	7.9	3.9
2	49.5	851.5	594	10.5	1.066	1.21	12.4	6.0
3	48.3	851.5	599	9.8	1.068	1.22	12.5	6.1
4	50.6	857.5	597	9.4	1.060	1.20	11.9	5.8
5	47.8	861.0	592	7.8	1.057	1.19	10.6	5.2
6	49.0	880.0	575	6.3	1.032	1.14	7.9	3.9
7	50.3	830.5	597	13.3	1.097	1.27	16.0	7.7
8	48.5	774.0	618	19.8	1.174	1.42	24.0	11.3
9	49.8	781.0	621	19.0	1.163	1.41	24.2	11.4
10	49.6	827.0	617	11.8	1.098	1.28	16.4	7.9
11	51.5	819.0	608	12.2	1.107	1.29	17.8	8.5
12	49.9	849.0	591	9.8	1.067	1.21	12.2	5.9
13	50.4	829.5	605	13.1	1.096	1.27	15.8	7.6
14	51.7	714.0	625	50.1	1.273	1.65	39.2	18.0
15	48.1	799.0	631	15.3	1.138	1.36	20.5	9.8
16	50.5	e	e	0	e	1.0	0	0
17	49.1	839.5	614	11.3	1.080	1.25	14.6	7.0
18	50.2	851.5	596	9.8	1.064	1.22	13.1	6.3
19	49.2	837.5	604	12.0	1.087	1.25	14.7	7.1
20	50.3	772.5	628	19.8	1.180	1.44	26.0	12.2
21	50.3	743.5	631	30.3	1.225	1.54	31.6	14.7
22	51.0	794.5	629	19.0	1.146	1.38	22.5	10.7
23	49.9	800.0	617	14.4	1.133	1.35	20.6	9.8
24	50.1	851.5	597	8.7	1.063	1.20	11.9	5.8
25	47.9	847.0	596	9.8	1.075	1.24	13.2	6.4
26	51.2	770.5	609	19.8	1.183	1.44	26.4	12.4
27	47.9	763.0	624	20.9	1.194	1.47	26.4	12.4
28	51.0	786.5	622	19.4	1.159	1.40	23.8	11.3
29	48.6	795.5	608	15.7	1.144	1.38	21.4	10.2
30	50.8	860.5	586	8.5	1.053	1.19	11.3	5.5
31	49.8	882.0	575	6.3	1.032	1.14	8.3	4.1
32	48.3	853.0	600	10.9	1.065	1.23	12.9	6.2
33	49.6	847.5	606	12.4	1.074	1.24	13.9	6.7
34	49.0	846.0	604	12.6	1.078	1.25	14.3	6.9
35	49.8	862.0	588	8.9	1.058	1.21	12.2	5.9
36	48.0	892.5	559	5.2	1.019	1.11	6.3	3.1

<sup>a</sup> Measured at room temperature; includes fuel pin simulator, pressure transducer, and connecting tube.

<sup>b</sup> Includes fuel pin simulator, pressure transducer, and connecting tube; calculated from volume increase of tube over heated length (91 cm) and measured initial gas volume.

<sup>c</sup> Calculated from the circumferential strain measurements by using the equation for the volume of a cone frustum to estimate the subvolume for each length interval between strain measurements, summing these subvolumes over the heated length, and subtracting the original volume from the sum.

<sup>d</sup> Average (or equivalent) strain over heated length ( $\bar{\epsilon}$ ) was calculated from the volume increase over the heated length ( $\Delta V$ ) using the equation  $\bar{\epsilon} = \sqrt{1 + \Delta V/V_0} - 1$ , where  $V_0$  is the original heated-length volume.

<sup>e</sup> Simulator No. 16 was unpressurized (~560 kPa) and unheated (electrically) during the test.

Table 6. Strain in tubes of B-4 test

ELEVATION <sup>a</sup> (CM)	Circumferential strain (%) of tube No.																	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
0.0	0.0	0.9	0.0	0.0	0.0	0.2	0.0	3.7	0.4	0.2	0.2	0.2	0.7	0.0	0.2	0.2	0.2	0.2
2.0	0.7	0.7	0.4	0.4	1.1	0.7	1.3	1.3	1.1	1.3	1.3	0.9	1.5	1.3	1.3	0.0	1.1	0.9
4.0	1.7	2.0	1.7	2.4	2.4	2.2	2.3	3.9	3.7	3.3	3.9	2.6	3.1	5.1	3.5	0.0	2.8	2.4
6.0	2.4	3.7	3.1	3.7	3.7	2.8	4.5	5.4	5.7	4.6	5.4	3.9	5.0	5.9	6.1	0.2	4.1	3.9
8.0	2.6	3.5	3.3	3.7	3.5	2.5	4.4	5.4	5.7	4.4	5.2	3.7	4.6	5.9	5.2	0.2	4.4	4.1
10.0	2.4	2.8	2.4	2.5	2.4	2.0	4.4	5.2	5.4	4.4	4.8	3.3	4.4	5.7	5.2	0.2	4.1	3.7
12.0	3.3	4.4	3.9	4.1	4.1	3.3	5.7	7.0	6.5	5.7	5.7	4.1	5.4	7.2	6.1	0.2	5.2	5.0
14.0	4.4	5.7	5.0	5.2	5.0	3.7	10.0	13.5	9.8	7.8	8.3	5.4	9.6	13.7	9.6	0.2	7.4	5.9
16.0	4.6	6.5	6.1	6.1	5.4	3.9	12.9	12.9	12.6	9.4	9.8	6.8	12.0	18.1	11.8	0.0	6.9	7.8
18.0	5.0	7.6	7.0	7.6	6.5	4.1	12.9	14.2	13.9	10.7	10.5	7.6	11.5	19.2	13.3	0.0	10.2	8.9
20.0	3.5	7.3	7.6	8.3	6.5	3.7	9.9	10.4	15.5	11.1	11.1	7.2	8.5	19.0	13.9	0.0	10.7	7.8
22.0	3.9	6.5	6.8	7.0	6.1	3.7	9.5	14.4	15.7	11.3	11.3	6.5	8.3	19.6	14.4	0.0	10.9	7.4
24.0	3.9	7.4	7.6	7.6	6.3	3.5	11.5	15.5	17.0	11.3	11.8	7.8	10.2	23.7	14.8	0.0	11.1	8.5
26.0	5.0	8.9	8.9	8.5	7.0	3.5	13.3	15.3	16.8	11.8	12.0	8.1	12.9	26.8	15.3	0.0	11.3	8.5
28.0	4.8	7.8	7.4	7.6	6.8	4.4	12.9	15.9	17.0	11.1	11.8	7.2	13.1	27.0	15.3	0.0	10.9	7.6
30.0	4.1	6.5	6.8	7.4	6.3	3.5	9.9	14.8	15.7	10.5	11.5	8.1	11.1	24.6	15.3	0.2	10.2	8.3
32.0	3.3	6.1	7.0	6.5	6.5	3.9	8.1	13.9	15.0	13.2	11.5	7.8	9.4	23.7	15.0	0.2	9.8	7.8
34.0	3.9	7.2	7.6	7.2	5.9	3.7	9.4	14.4	15.3	10.2	11.1	7.2	11.1	25.5	15.0	0.0	9.4	6.8
36.0	3.9	7.8	7.6	7.2	6.3	4.1	10.7	14.4	14.6	10.2	11.1	7.2	11.5	24.4	13.9	0.0	9.6	7.6
38.0	4.1	6.5	5.9	5.9	5.9	4.1	10.0	14.4	15.3	10.5	10.9	7.8	10.9	23.5	14.6	0.0	9.4	8.3
40.0	4.1	7.4	6.3	5.9	5.9	4.5	8.3	14.4	15.5	10.7	11.3	8.1	9.2	23.3	14.8	-0.2	9.6	8.5
42.0	4.4	8.5	7.8	7.2	7.2	4.5	8.5	15.9	17.6	11.3	11.5	8.3	11.8	25.7	14.8	0.0	9.4	7.8
44.0	4.6	8.7	8.1	7.6	6.8	5.2	10.2	18.1	19.3	11.3	11.5	8.5	12.4	31.2	13.9	0.4	9.6	7.8
46.0	5.2	8.1	7.4	6.8	6.8	5.2	10.9	19.6	17.9	11.8	12.0	9.4	12.4	40.1	13.9	0.0	9.8	9.4
48.0	4.1	8.3	8.1	8.5	7.4	5.9	12.0	19.8	18.7	11.5	12.2	8.7	11.1	50.1	13.9	0.2	9.8	9.4
50.0	4.6	10.5	9.4	9.4	7.8	5.3	10.7	18.7	19.0	11.3	12.2	9.2	11.1	44.0	14.2	0.0	9.6	9.6
52.0	5.2	9.6	8.9	7.9	6.8	6.1	10.0	17.2	17.2	11.1	12.2	9.8	10.9	32.7	13.3	-0.2	9.4	9.8
54.0	5.2	8.3	7.0	6.8	6.8	5.9	11.1	15.3	15.7	10.5	11.8	8.9	9.2	24.4	13.9	-0.2	9.2	8.5
56.0	5.4	9.2	8.5	8.1	7.0	5.7	8.5	15.0	14.4	10.0	10.9	8.3	6.8	19.0	10.7	0.0	8.3	8.1
58.0	3.9	7.6	7.2	7.4	7.2	5.2	6.9	12.9	12.4	9.2	10.2	8.1	7.0	14.6	9.6	0.0	7.0	7.6
60.0	4.1	6.1	5.7	5.7	5.9	5.4	6.3	13.5	10.0	7.8	8.5	6.1	5.0	11.3	7.8	-0.2	6.5	5.7
62.0	3.7	5.4	5.4	5.2	5.0	4.1	5.2	7.6	7.6	6.3	6.3	5.2	4.1	6.7	6.3	0.0	5.9	5.4
64.0	1.5	3.5	4.1	3.9	4.1	2.4	4.1	5.7	5.7	4.6	4.8	3.7	3.7	5.2	4.8	-0.2	3.7	3.7
66.0	2.4	3.7	3.9	3.7	3.7	2.8	3.9	6.5	5.7	5.0	4.8	3.5	5.9	6.1	5.0	0.2	4.1	3.3
68.0	4.1	4.4	4.8	4.9	5.0	3.3	6.5	3.9	7.6	6.3	6.3	5.0	6.5	8.9	6.8	0.0	5.2	5.0
70.0	5.0	6.8	6.3	6.3	6.3	3.7	8.1	12.2	10.2	7.6	8.3	5.7	6.8	13.5	8.5	0.2	6.5	5.7
72.0	5.9	7.5	7.2	7.2	6.1	5.0	11.1	13.5	11.5	8.7	9.2	6.3	7.4	15.7	9.4	0.2	7.2	6.8
74.0	6.3	6.3	7.0	6.1	6.5	4.8	10.5	13.7	12.0	8.7	9.4	7.4	7.2	15.5	9.6	-0.2	7.2	7.8
76.0	5.7	7.0	7.0	5.2	6.5	4.9	8.3	13.5	11.1	8.5	9.4	6.8	7.0	15.9	9.4	0.2	7.0	6.5
78.0	6.1	8.1	7.8	7.0	6.1	3.9	9.2	14.2	10.2	7.8	8.5	5.0	7.4	15.9	8.5	0.0	6.3	4.1
80.0	6.1	7.8	6.8	7.0	5.4	4.1	8.7	10.5	9.2	7.2	8.1	5.2	7.2	13.3	7.4	-0.2	5.7	4.6
82.0	5.9	6.1	6.5	5.9	5.0	3.1	7.5	9.5	7.4	6.1	6.8	4.6	5.4	10.2	6.1	-0.2	5.2	4.4
84.0	4.6	4.1	3.7	3.9	4.1	3.1	6.5	6.3	5.2	4.4	5.4	3.5	5.2	6.8	4.8	-0.2	3.9	3.3
86.0	3.7	2.8	2.8	2.5	2.0	2.2	4.1	3.9	2.6	2.8	3.5	3.3	3.3	3.9	3.1	0.0	2.4	2.4
88.0	2.4	0.9	1.5	1.5	1.3	1.3	1.5	1.7	1.7	1.5	1.5	1.5	1.3	1.1	1.7	-0.2	1.5	0.9
90.0	0.9	0.2	0.2	0.4	0.4	0.0	0.4	3.7	0.0	0.2	0.2	0.2	0.4	0.2	0.4	-0.2	0.4	-0.2
92.0	0.2	-0.2	-0.2	0.0	0.0	0.0	0.2	3.2	-0.2	0.2	0.0	0.0	0.2	-0.4	0.0	0.0	0.2	-0.4

<sup>a</sup>Above bottom of heated zone.

Table 6 (continued)

ELEVATION <sup>a</sup> (CM)	Circumferential strain (%) of tube No.																	
	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	
0.0	0.2	0.2	0.4	0.2	0.2	0.4	0.2	3.4	0.4	0.2	0.2	0.2	0.2	0.7	0.2	0.2	0.0	0.4
2.0	0.2	1.1	1.5	1.3	0.9	0.9	0.9	1.7	1.5	1.3	1.3	0.9	0.9	1.3	0.7	0.9	0.4	0.7
4.0	2.4	4.1	4.4	3.3	3.3	2.2	2.4	5.0	4.4	3.7	3.7	2.0	2.2	3.5	2.4	2.6	2.0	1.7
6.0	4.1	5.7	6.5	5.0	4.8	3.5	3.7	7.2	6.3	5.4	5.2	3.1	2.4	4.1	2.6	3.1	2.4	2.4
8.0	4.1	5.7	6.3	5.2	5.0	3.9	3.9	5.5	6.3	5.7	5.0	3.3	2.4	3.9	3.3	3.3	2.8	2.2
10.0	3.1	5.4	5.9	5.2	4.8	3.5	4.4	5.9	6.1	5.4	4.8	3.1	2.2	3.3	2.8	3.3	2.4	2.0
12.0	5.2	7.2	7.4	6.5	5.9	4.8	4.9	7.8	7.2	6.8	5.9	3.9	3.1	4.4	3.9	4.1	3.1	2.5
14.0	7.4	12.0	12.2	10.7	9.2	5.4	9.1	14.2	11.5	10.7	9.6	4.8	5.2	7.2	6.5	6.1	4.9	3.3
16.0	10.5	16.1	16.6	14.2	11.5	7.0	9.5	17.0	15.3	14.4	12.6	6.3	6.3	9.2	9.2	8.9	6.5	3.5
18.0	10.7	17.9	19.2	17.0	12.9	8.1	9.8	19.8	17.0	16.1	14.6	7.0	5.2	8.1	8.7	8.5	6.8	3.9
20.0	8.5	17.9	20.0	18.3	13.1	7.2	4.3	19.0	17.0	17.2	15.5	6.8	4.8	8.3	9.2	8.5	6.8	3.5
22.0	4.1	18.1	21.1	19.0	13.1	7.4	7.6	18.5	17.4	18.5	15.7	7.0	4.4	9.4	12.0	11.1	8.1	3.9
24.0	10.0	18.5	22.4	19.0	13.5	8.3	8.7	19.3	18.3	18.7	15.7	7.4	4.8	9.8	12.4	11.8	8.3	3.9
26.0	12.0	19.7	23.3	18.5	13.5	7.8	9.5	17.6	19.0	19.5	14.8	7.4	4.8	8.9	10.2	10.0	7.6	3.5
28.0	11.4	19.8	23.5	17.9	13.5	7.4	9.3	17.0	19.8	19.2	13.9	7.4	5.4	10.0	11.3	11.5	8.3	3.7
30.0	9.8	18.7	23.7	16.3	13.5	7.8	8.3	17.2	20.5	19.4	13.3	7.4	5.4	10.9	12.0	12.4	8.9	3.7
32.0	4.7	17.6	24.8	15.9	13.7	7.2	8.7	17.2	20.0	19.3	12.4	7.0	5.0	8.9	9.8	12.6	8.3	4.1
34.0	10.0	17.0	27.5	15.5	13.5	6.3	8.7	17.6	20.3	16.8	12.0	6.3	5.4	8.7	9.2	9.6	7.2	3.9
36.0	10.5	17.9	30.3	15.9	13.7	7.2	9.9	17.2	20.9	16.3	12.6	7.0	5.0	9.8	10.2	10.9	8.1	3.3
38.0	8.5	17.4	28.3	15.9	13.9	7.4	7.9	15.8	20.3	16.1	13.1	7.2	5.0	8.9	10.0	10.7	7.6	3.5
40.0	7.4	16.8	25.1	15.5	13.9	8.1	7.2	15.9	19.7	15.9	13.5	7.2	5.0	7.4	8.3	8.9	7.2	3.5
42.0	8.7	17.2	23.7	15.0	13.5	7.2	7.9	15.1	18.1	16.3	13.5	6.8	5.4	8.9	10.0	10.5	8.1	3.7
44.0	9.4	17.0	23.1	15.0	13.7	7.7	8.9	17.2	17.4	15.7	13.7	7.2	5.4	9.2	10.9	11.3	8.9	4.1
46.0	10.7	18.3	22.7	13.9	13.9	8.7	8.9	17.6	16.6	15.0	13.7	7.8	5.0	8.3	8.7	9.2	7.8	3.9
48.0	11.3	18.7	22.7	14.5	13.9	8.5	9.4	17.9	15.6	15.0	13.7	8.1	5.0	7.4	7.8	8.5	7.0	3.7
50.0	9.4	18.1	22.2	14.5	14.4	9.5	7.4	17.6	17.6	15.5	14.4	7.4	5.0	8.9	9.2	10.0	8.3	3.3
52.0	10.0	17.6	21.1	14.2	13.9	8.7	8.7	17.9	17.9	15.5	14.8	8.5	5.4	9.2	9.8	10.7	8.9	4.4
54.0	10.7	16.3	19.0	12.9	13.1	7.8	9.2	17.6	17.6	14.6	13.7	7.8	5.7	7.4	8.3	8.7	8.7	4.1
56.0	4.2	14.2	16.6	12.0	12.0	7.4	7.8	15.7	17.0	13.9	13.1	7.0	5.7	8.1	8.5	9.4	7.6	4.1
58.0	7.0	11.5	13.5	10.2	10.2	7.4	7.2	13.1	14.8	12.2	11.3	7.2	5.4	7.6	8.7	9.4	8.3	5.0
60.0	6.5	7.4	10.5	8.1	8.7	5.9	6.5	10.5	11.3	9.6	9.6	5.7	5.2	5.5	6.5	6.5	6.1	4.1
62.0	4.4	7.2	7.6	5.9	6.5	4.8	5.0	7.6	8.1	7.4	7.0	4.4	4.1	4.8	4.6	5.0	4.1	3.5
64.0	3.5	5.0	5.7	4.5	5.0	3.5	3.7	5.9	5.9	5.2	5.4	2.4	3.1	3.7	3.5	3.7	3.3	3.1
66.0	3.5	5.7	6.1	5.0	5.9	3.7	3.5	5.3	5.9	5.7	6.1	3.5	2.8	3.7	3.3	3.7	2.8	2.0
68.0	5.2	7.5	8.3	6.8	7.6	3.2	5.0	3.3	7.8	5.2	8.1	5.4	3.7	4.8	4.6	5.0	4.4	3.7
70.0	6.3	10.5	11.1	8.5	10.2	5.9	5.7	10.0	10.5	9.4	10.9	6.5	4.4	4.8	4.8	5.2	4.8	3.9
72.0	8.1	11.5	12.9	9.5	11.1	5.8	6.5	11.1	11.3	10.5	12.6	7.6	4.4	6.1	6.1	5.7	6.8	4.6
74.0	5.9	11.1	12.9	9.4	11.1	7.4	5.4	11.3	11.3	10.5	12.0	8.5	4.4	5.2	5.2	5.0	5.2	5.2
76.0	6.3	11.1	12.4	9.2	10.7	6.1	5.9	11.1	11.3	10.2	10.9	6.8	3.9	5.2	5.0	5.0	5.2	4.4
78.0	6.5	10.2	10.9	8.5	8.9	4.8	5.7	10.7	11.1	9.6	10.0	6.3	3.7	5.7	5.4	5.2	5.9	4.8
80.0	5.0	9.8	9.2	7.6	7.8	4.9	5.0	10.0	10.0	8.7	8.9	5.2	4.1	5.0	5.0	4.6	5.0	3.7
82.0	4.1	8.1	7.8	6.5	6.5	4.1	4.4	3.9	8.1	7.6	7.8	4.4	3.7	5.0	4.1	4.1	4.8	3.5
84.0	4.4	6.1	5.7	5.3	5.0	3.3	4.4	7.0	5.9	5.7	6.1	3.9	3.5	3.3	3.1	3.3	3.1	3.3
86.0	2.4	3.7	3.5	3.5	3.3	2.5	2.9	4.1	3.9	3.9	4.1	2.6	2.8	3.1	2.4	2.6	2.2	2.5
88.0	1.1	1.5	1.7	2.0	1.1	1.5	1.5	2.0	1.7	2.2	2.0	1.7	1.5	1.5	1.1	1.3	1.1	1.7
90.0	0.0	0.2	0.2	0.0	0.2	0.2	0.2	3.4	0.4	0.4	0.4	0.4	0.2	0.4	0.2	0.2	-0.2	0.7
92.0	0.0	0.2	0.2	0.2	0.0	0.0	-0.2	-3.2	0.0	7.2	0.0	0.2	-0.2	0.4	-0.2	0.0	-0.2	0.2

<sup>a</sup> Above bottom of heated zone.

Table 7. Deformed tube areas in B-4 test

ELEVATION <sup>a</sup> (CM)	Outside area (mm <sup>2</sup> ) of tube No.																	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
0.0	93	95	93	93	93	94	33	94	94	94	94	94	94	93	94	93	94	94
2.0	94	94	94	94	95	94	76	96	95	96	96	95	96	96	96	96	95	95
4.0	96	97	96	94	98	97	93	101	100	99	101	98	99	101	100	93	99	98
6.0	98	100	99	103	100	99	132	104	104	102	104	101	103	105	94	101	101	101
8.0	98	100	99	103	100	98	132	104	104	102	103	100	102	105	103	94	102	101
10.0	98	99	98	93	98	97	132	103	104	102	102	99	102	104	103	94	101	100
12.0	99	102	101	101	101	97	134	107	106	104	104	101	104	107	105	94	103	103
14.0	107	104	103	103	103	100	113	114	112	108	109	104	112	121	112	94	118	105
16.0	102	105	105	105	104	101	119	118	112	112	112	106	117	130	117	93	111	108
18.0	103	108	107	109	106	101	119	122	121	114	114	108	116	133	120	93	113	111
20.0	100	108	109	109	106	103	112	122	124	115	115	107	110	132	121	93	114	108
22.0	131	106	106	107	105	103	112	122	124	115	115	106	109	134	122	93	115	108
24.0	101	104	108	108	105	103	115	124	128	116	117	108	113	143	123	93	115	110
26.0	103	111	111	110	107	100	120	126	127	117	117	109	119	150	124	93	116	110
28.0	102	108	108	103	106	102	119	125	128	115	117	107	119	151	124	93	115	108
30.0	101	106	106	103	105	100	112	123	125	114	116	109	115	145	124	94	113	109
32.0	99	104	107	105	106	101	109	121	123	113	116	108	112	143	123	94	112	108
34.0	101	107	108	107	105	102	112	122	124	113	115	107	115	147	123	93	112	106
36.0	101	108	104	107	105	101	114	122	123	113	115	107	116	144	121	93	112	108
38.0	101	105	105	105	105	101	113	122	124	114	115	108	115	142	123	93	112	109
40.0	101	103	105	105	105	102	122	124	124	114	116	109	111	142	123	93	112	110
42.0	102	110	104	107	107	102	110	125	129	116	116	109	117	148	123	93	112	108
44.0	102	110	109	108	106	103	113	130	131	116	116	110	118	161	121	94	112	108
46.0	103	109	108	106	106	103	115	134	130	117	117	112	118	183	121	93	112	112
48.0	101	109	109	113	108	105	117	134	132	116	117	110	115	211	121	94	112	112
50.0	102	114	112	112	108	105	114	132	132	116	117	111	115	194	122	93	112	112
52.0	103	112	111	108	106	105	113	128	129	115	117	112	115	164	120	93	112	112
54.0	103	109	107	105	106	105	115	126	125	114	117	111	111	144	121	93	111	110
56.0	104	111	110	109	107	104	110	123	122	113	115	109	106	132	114	93	109	109
58.0	101	104	107	108	107	103	105	119	118	111	113	109	107	123	112	93	107	108
60.0	101	105	104	104	104	104	135	114	113	108	110	105	103	115	108	93	106	104
62.0	100	104	104	103	103	101	133	109	109	105	105	103	101	110	105	93	105	104
64.0	96	100	101	101	101	94	131	104	104	102	102	100	100	103	102	93	100	100
66.0	98	100	101	109	100	99	131	106	104	103	102	100	105	105	103	94	101	99
68.0	101	102	102	102	103	99	135	111	108	105	105	103	106	111	106	93	103	103
70.0	103	105	105	105	105	100	139	117	113	108	109	104	106	120	110	94	106	104
72.0	105	108	107	107	105	107	137	115	120	116	110	111	105	125	112	94	107	106
74.0	105	105	107	105	106	102	114	121	117	110	112	108	107	124	112	93	107	108
76.0	104	107	107	103	105	102	139	120	115	110	112	106	107	125	112	94	107	106
78.0	105	109	108	105	107	105	141	122	113	108	110	103	108	125	110	93	105	101
80.0	105	108	106	106	104	101	142	114	111	108	109	103	107	120	108	93	104	102
82.0	105	105	106	105	103	99	134	110	108	105	106	102	104	113	105	93	103	102
84.0	102	101	100	101	101	99	131	105	103	102	100	100	103	106	102	93	101	99
86.0	100	99	99	99	97	97	101	101	98	99	100	99	99	101	99	93	98	98
88.0	98	95	96	95	96	95	95	95	95	95	96	96	96	95	96	93	96	95
90.0	95	94	94	94	94	94	94	93	94	94	94	94	94	94	94	93	94	93
92.0	94	93	93	93	93	93	94	93	93	94	93	93	94	92	93	93	94	92

<sup>a</sup> Above bottom of heated zone.

Table 7 (continued)

ELEVATION <sup>a</sup> (CM)	Outside area (mm <sup>2</sup> ) of tube No.																																			
	19	20	21	22	23	24	25	25	27	28	29	30	31	32	33	34	35	36																		
0.0	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94																		
2.0	95	95	96	95	95	95	95	96	96	96	96	96	95	95	95	94	93	94																		
4.0	98	101	102	99	99	97	98	103	102	100	100	100	97	97	103	98	97	96																		
6.0	101	104	106	103	102	100	100	107	105	104	103	99	98	101	98	98	98	98																		
8.0	101	104	105	103	103	101	101	105	105	104	103	99	98	101	99	99	99	97																		
10.0	99	104	105	103	102	100	102	105	105	104	102	99	97	99	99	99	98	97																		
12.0	103	107	109	105	105	102	102	108	107	105	105	101	99	102	101	101	99	98																		
14.0	109	117	117	114	111	108	107	122	116	114	112	102	103	107	106	105	102	99																		
16.0	114	126	127	122	116	107	112	132	124	122	118	105	105	111	111	111	106	100																		
18.0	114	130	133	123	119	109	112	134	128	128	123	107	103	109	110	110	106	100																		
20.0	110	130	135	131	119	107	109	132	128	128	124	106	102	109	111	110	106	100																		
22.0	109	130	137	132	119	109	109	131	129	131	125	107	102	112	117	115	109	101																		
24.0	113	131	140	132	120	109	110	131	131	132	125	108	102	112	118	117	109	101																		
26.0	117	133	142	131	120	108	112	129	132	131	123	108	102	111	113	113	108	100																		
28.0	117	134	142	132	120	108	112	126	134	133	121	108	104	113	116	116	109	100																		
30.0	112	132	143	127	120	108	109	128	135	133	120	108	104	115	117	118	111	100																		
32.0	110	129	146	125	121	107	113	128	135	131	118	107	103	111	112	118	109	101																		
34.0	113	128	152	124	120	105	113	129	135	127	117	105	104	110	111	112	107	101																		
36.0	114	130	159	125	121	107	111	124	136	126	118	107	103	112	113	115	109	99																		
38.0	110	129	154	125	121	108	109	127	135	126	119	107	103	111	113	114	108	100																		
40.0	109	127	146	124	121	109	107	125	132	125	120	107	103	108	109	111	107	99																		
42.0	110	128	143	123	120	107	109	126	130	125	120	106	104	111	113	114	109	100																		
44.0	112	130	141	123	121	107	111	128	129	125	121	107	104	111	115	116	111	101																		
46.0	114	131	140	121	121	110	111	129	127	123	121	108	103	109	110	111	108	101																		
48.0	115	132	140	123	121	113	112	130	127	123	121	109	103	109	108	110	107	100																		
50.0	112	130	139	123	122	110	108	129	129	124	122	108	103	111	111	113	109	99																		
52.0	113	129	137	122	121	110	110	130	130	124	123	110	104	111	112	114	111	102																		
54.0	114	126	132	119	119	109	111	129	129	123	121	108	104	108	109	110	110	101																		
56.0	111	122	127	117	117	108	108	125	124	121	119	107	104	109	110	112	108	101																		
58.0	107	116	120	113	113	108	107	119	123	117	117	107	104	109	110	112	109	103																		
60.0	106	112	114	109	110	105	105	114	116	112	112	104	103	106	106	106	105	101																		
62.0	102	107	109	105	106	102	103	108	109	109	107	102	101	102	102	103	101	100																		
64.0	100	103	104	102	103	103	103	105	105	103	104	98	99	99	100	100	99	99																		
66.0	100	104	105	103	105	100	103	105	105	104	105	100	99	100	99	100	99	97																		
68.0	103	108	109	105	108	103	103	109	108	103	109	104	100	102	102	103	102	100																		
70.0	105	114	115	113	113	105	104	113	114	112	115	106	102	102	102	103	102	101																		
72.0	109	115	119	112	115	105	105	115	116	114	118	108	102	105	105	104	106	102																		
74.0	105	115	119	112	115	108	104	116	116	114	117	110	102	103	103	103	103	102																		
76.0	105	115	118	111	114	105	105	115	116	113	115	106	101	103	103	103	103	102																		
78.0	106	113	115	110	111	102	104	114	115	112	113	105	100	104	104	103	105	102																		
80.0	103	112	111	109	108	102	103	113	113	110	111	103	101	103	103	102	103	100																		
82.0	101	109	108	105	106	101	102	111	109	108	108	102	100	103	103	101	102	100																		
84.0	102	105	104	103	103	99	102	107	105	104	105	101	100	99	99	99	99	99																		
86.0	99	100	100	100	99	93	93	101	101	101	101	98	99	99	98	98	97	98																		
88.0	95	95	96	97	95	95	95	97	96	97	97	96	96	95	95	96	95	96																		
90.0	93	94	94	94	93	94	94	94	94	94	94	94	94	94	94	94	94	94																		
92.0	93	94	94	94	93	93	93	93	93	93	94	94	94	94	93	93	93	94																		

<sup>a</sup>Above bottom of heated zone.



Table 8. Coolant channel flow area restriction in B-4 test

ELEVATION <sup>a</sup> (CM)	6X6 ARRAY (%)	4X4 ARRAY (%)
0.0	0.4	0.4
2.0	1.7	2.0
4.0	4.9	6.0
6.0	7.1	8.8
8.0	7.0	8.6
10.0	6.4	8.3
12.0	8.5	10.4
14.0	13.1	17.0
16.0	16.9	22.3
18.0	18.5	25.0
20.0	18.2	25.8
22.0	18.6	26.5
24.0	19.9	27.8
26.0	20.5	28.4
28.0	20.5	28.3
30.0	19.7	27.4
32.0	19.8	26.6
34.0	18.8	26.8
36.0	19.4	27.1
38.0	18.8	26.7
40.0	18.1	26.0
42.0	19.1	26.6
44.0	20.0	27.7
46.0	20.5	28.9
48.0	21.2	30.7
50.0	21.1	29.8
52.0	20.2	27.4
54.0	18.5	25.0
56.0	17.0	22.2
58.0	15.0	18.8
60.0	12.1	15.0
62.0	9.4	11.2
64.0	6.7	8.1
66.0	7.1	8.8
68.0	9.7	11.7
70.0	12.4	15.9
72.0	14.2	19.0
74.0	13.9	17.9
76.0	13.3	17.5
78.0	12.8	16.3
80.0	11.5	14.2
82.0	9.8	11.9
84.0	7.5	8.7
86.0	5.0	5.4
88.0	2.4	2.6
90.0	0.4	0.4
92.0	0.0	0.1

<sup>a</sup> Above bottom of heated zone.




Fig. 1. Schematic of B-4 test assembly.




Fig. 2. Typical fuel pin simulator.




Fig. 3. As-built thermocouple locations and identifications in B-4 test (plan view).





Fig. 4. As-built thermocouple locations in B-4





test (elevation).

ORNL-DWG 81-16403 ETD

TEMPERATURE MAP  
MRBT BUNDLE 4

RECORD NUMBER 289                      TIME FROM START OF SCAN 28.9 SEC  
ELEVATION 76 CM                      CROSS SECTION AVERAGE 331.3                      BUNDLE AVERAGE 332.1

1	2	3	4	5	6	333.4
333			331		336	
7	8	9	10	11	12	332.5
335	333			330		
13	14	15	16	17	18	331.1
		332		330		
19	20	21	22	23	24	331.1
331		329		330	333	
25	26	27	28	29	30	325.9
	316		329		332	
31	32	33	34	35	36	333.8
	336	335		331		
332.9	328.1	332.1	330.2	330.4	334.0	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 7. Temperatures measured at 76-cm elevation 1 s before power-on.

TEMPERATURE MAP  
MRBT BUNDLE 4

RECORD NUMBER 289                      TIME FROM START OF SCAN 28.9 SEC  
ELEVATION 66 CM                      CROSS SECTION AVERAGE 332.0                      BUNDLE AVERAGE 332.1

1	2	3	4	5	6	
7	8	9	10	11	12	330.5
			330			
13	14	15	16	17	18	332.3
332						
19	20	21	22	23	24	
25	26	27	28	29	30	
31	32	33	34	35	36	334.5
	336					
332.3	335.5		330.5			

ALL TEMPERATURES ARE IN DEGREES C  
TEMPERATURES IN THIS CROSS SECTION NOT INCLUDED IN BUNDLE AVERAGE TEMPERATURE

Fig. 8. Temperatures measured at 66-cm (upper grid) elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 56 CM CROSS SECTION AVERAGE 333.1 BUNDLE AVERAGE 332.1

1	2	3	4	5	6	334.5
	336		332		336	
7	8	9	10	11	12	334.2
336	335			332		
13	14	15	16	17	18	333.2
	332	335	(331)			
19	20	21	22	23	24	332.1
332		332		332		
25	26	27	28	29	30	332.2
	333		331		332	
31	32	33	34	35	36	332.6
333				332	333	
333.5	333.8	333.2	331.8	332.8	333.7	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 9. Temperatures measured at 56-cm elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 47 CM CROSS SECTION AVERAGE 332.4 BUNDLE AVERAGE 332.1

1	2	3	4	5	6	332.3
331		331		334		
7	8	9	10	11	12	332.5
		335	331		331	
13	14	15	16	17	18	331.9
331				332	332	
19	20	21	22	23	24	332.9
	335		332		332	
25	26	27	28	29	30	332.1
335		329		332		
31	32	33	34	35	36	332.5
	334	333	331			
332.5	334.1	332.8	331.6	332.8	331.9	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 10. Temperatures measured at 47-cm elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 38 CM CROSS SECTION AVERAGE 331.7 BUNDLE AVERAGE 332.1

1	2	3	4	5	6	331.5
	330		330		334	
7	8	9	10	11	12	332.8
334		334		331		
13	14	15	16	17	18	333.8
	331	335	( 331)			
19	20	21	22	23	24	331.7
331		332		332		
25	26	27	28	29	30	331.7
	332	332			331	
31	32	33	34	35	36	329.8
329			331		329	
331.2	331.2	333.1	330.7	331.4	331.5	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 11. Temperatures measured at 38-cm elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 29 CM CROSS SECTION AVERAGE 332.2 BUNDLE AVERAGE 332.1

1	2	3	4	5	6	331.5
330		331		334		
7	8	9	10	11	12	332.2
	334		331		331	
13	14	15	16	17	18	331.4
331				332	331	
19	20	21	22	23	24	333.1
	336		332		332	
25	26	27	28	29	30	332.3
335			330	331		
31	32	33	34	35	36	332.6
	333	334		331		
332.0	334.1	332.3	331.2	332.2	331.2	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 12. Temperatures measured at 29-cm elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 20 CM CROSS SECTION AVERAGE 332.0 BUNDLE AVERAGE 332.1

1	2	3*	4*	5	6	330.6
	331	330	331			
7	8*	9	10	11*	12	332.8
	334			331		
13	14*	15*	16*	17	18*	331.5
	331	332	(331)		331	
19	20	21*	22	23	24	332.5
333		332				
25	26	27	28	29*	30	332.2
	333			332	331	
31*	32	33*	34*	35	36	332.8
331		335	333	332		
332.1	332.3	332.2	332.1	331.8	331.4	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 13. Temperatures measured at 20-cm elevation 1 s before power-on.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 10 CM CROSS SECTION AVERAGE 333.9 BUNDLE AVERAGE 332.1

1	2	3	4	5	6	
7	8	9	10	11	12*	332.3
					332	
13	14	15	16	17	18	
19	20	21	22*	23	24	332.3
			332			
25*	26	27	28	29	30	336.9
337						
31	32	33	34	35	36	
336.9		332.3			332.3	

ALL TEMPERATURES ARE IN DEGREES C  
 TEMPERATURES IN THIS CROSS SECTION NOT INCLUDED IN BUNDLE AVERAGE TEMPERATURE

Fig. 14. Temperatures measured at 10-cm (lower grid) elevation 1 s before power-on.



TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 ELEVATION 5 CM CROSS SECTION AVERAGE 334.3 BUNDLE AVERAGE 332.1

. 1 .	. 2 .	. 3 .	. 4 .	. 5 .	. 6 .	335.5
				335	336	
. 7 .	. 8 .	* 9 .	. 10 .	. 11 .	. 12 .	335.5
336		335				
. 13 .	. 14 .	. 15 .	* 16 .	. 17 .	. 18 .	331.9
	332		( 332 )			
. 19 .	. 20 .	. 21 .	. 22 .	* 23 .	. 24 .	334.1
	336			333		
. 25 .	. 26 .	* 27 .	. 28 .	. 29 .	. 30 .	332.3
		332	333			
* 31 .	. 32 .	. 33 .	. 34 .	. 35 .	* 36 .	335.3
334					337	
334.9	333.7	333.4	332.7	333.9	336.5	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 15. Temperatures measured at 5-cm elevation 1 s before power-on.

ROD AVERAGE TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 289 TIME FROM START OF SCAN 28.9 SEC  
 BUNDLE AVERAGE 332.1 DEGREES C

* 1 *	. 2 .	* 3 *	. 4 .	* 5 *	* 6 *	332.3
332	332	330	331	334	325	
* 7 .	* 8 *	* 9 *	* 10 *	. 11 .	* 12 .	332.6
335	334	333	330	331	331	
* 13 .	* 14 .	* 15 *	* 16 .	* 17 .	* 18 .	331.7
331	332	333	( 332 )	331	331	
* 19 .	* 20 *	* 21 *	* 22 .	. 23 .	* 24 *	332.1
332	334	331	331	332	332	
* 25 .	* 26 .	* 27 *	* 28 .	* 29 *	* 30 .	331.2
335	328	331	331	331	332	
* 31 .	* 32 *	* 33 *	* 34 *	. 35 .	* 36 *	332.5
332	334	334	332	332	333	
332.7	332.3	332.1	331.8	331.7	332.6	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING ROW & COLUMN AVERAGES

Fig. 16. Average simulator temperatures measured 1 s before power-on.

ORNL-DWG 81-16413 ETD

P R E S S U R E M A P

HRBT BUNDLE 4

RECORD NUMBER	289	TIME FROM START OF SCAN 28.9 SEC					
		AVERAGE PRESSURE 9091 KPA (DIFFERENTIAL)			STEAM PRESSURE 206 KPA (GAGE)		
1	2	3	4	5	6	9090	
9101	9078	9093	9091	9099	9079		
7	8	9	10	11	12	9081	
9105	9089	9080	9082	9064	9067		
13	14	15	16	17	18	9083	
9092	9096	9095 ( 559)	9069	9063			
19	20	21	22	23	24	9093	
9111	9120	9103	9096	9066	9059		
25	26	27	28	29	30	9100	
9111	9110	9100	9107	9103	9070		
31	32	33	34	35	36	9101	
9094	9084	9105	9113	9116	9093		
9102	9096	9096	9098	9086	9072		

ALL SIMULATOR PRESSURES ARE DIFFERENTIAL AND ARE IN KPA  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 17. Simulator pressures measured 1 s before power-on.

ORNL-DWG 81-8146A ETC




Fig. 18. Characteristic temperatures and pressures during powered portion of B-4 transient.

PRESSURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

AVERAGE PRESSURE 9437 KPA (DIFFERENTIAL)  
STEAM PRESSURE 287 KPA (GAGE)

1	2	3	4	5	6	9453
9472	9446	9452	9483	9436	9428	
7	8	9	10	11	12	9424
9424	9448	9398	9432	9421	9427	
13	14	15	16	17	18	9434
9433	9453	9439	( 551 )	9434	9419	
19	20	21	22	23	24	9432
9447	9467	9423	9433	9482	9417	
25	26	27	28	29	30	9441
9446	9456	9432	9478	9437	9486	
31	32	33	34	35	36	9448
9444	9431	9443	9448	9443	9435	
9445	9458	9428	9452	9429	9422	

ALL SIMULATOR PRESSURES ARE DIFFERENTIAL AND ARE IN KPA  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 19. Simulator pressures measured 0.2 s before power-off.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

ELEVATION 84 CM CROSS SECTION AVERAGE 666.9 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	669.5
669	671	668		678		
7	8	9	10	11	12	667.1
		671	666		664	
13	14	15	16	17	18	662.3
664				659	664	
19	20	21	22	23	24	669.7
	688		665		664	
25	26	27	28	29	30	678.2
669		678		672		
31	32	33	34	35	36	659.2
			662		667	
667.2	675.5	669.7	664.2	666.8	661.3	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 20. Temperatures measured at 84-cm elevation 0.2 s before power-off.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 90.3 SEC  
 ELEVATION 76 CM CROSS SECTION AVERAGE 678.4 BUNDLE AVERAGE 678.7

* 1	2	3	* 4	5	6 *	669.4
669			663		677	
7 *	8	9	10	* 11	12	681.8
683	684			679		
13	14	* 15	16	* 17	18	669.6
		677		662		
19	20	* 21	22	23	* 24	675.8
668 *		679		679	674	
25	26	27	* 28	29	* 30	666.3
	647 *		673		679	
31	32	33 *	34	35 *	36	658.4
	646 *	663		666		
673.8	658.9	672.9	660.2	671.8	676.3	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 21. Temperatures measured at 76-cm elevation 0.2 s before power-off.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 90.3 SEC  
 ELEVATION 66 CM CROSS SECTION AVERAGE 649.8 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	
7	8	9	* 10	11	12	648.2
			648			
13 *	14	15	16	17	18	649.2
649						
19	20	21	22	23	24	
25	26	27	28	29	30	
31	* 32	33	34	35	36	652.1
	652					
649.2	652.1		648.2			

ALL TEMPERATURES ARE IN DEGREES C  
 TEMPERATURES IN THIS CROSS SECTION NOT INCLUDED IN BUNDLE AVERAGE TEMPERATURE

Fig. 22. Temperatures measured at 66-cm (upper grid) elevation 0.2 s before power-off.



## TEMPERATURE MAP

## MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

ELEVATION 56 CM CROSS SECTION AVERAGE 673.5 BUNDLE AVERAGE 678.7

1	2*	3	4	5	6	671.5
	678		* 665		671*	
* 7	* 8	9	10	11	12	679.5
679	686			* 674		
13	* 14	15	16	17	18	679.1
	683	* 675	(489)			
19	20	* 21	22	23	24	675.4
* 672		679		675*		
25	* 26	27	* 28	29	30	674.6
	684		677*		663*	
31	32	33	34	* 35	36	662.7
* 661				664	663	
678.6	683.8	677.1	671.8	678.9	665.6	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 23. Temperatures measured at 56-cm elevation 0.2 s before power-off.

## TEMPERATURE MAP

## MRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

ELEVATION 47 CM CROSS SECTION AVERAGE 673.1 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	668.2
* 662		* 668		* 675		
7	8	* 9	10	11	* 12	677.6
		682	678		681	
* 13	14	15	16	17	* 18	668.5
669				667*	669	
19	* 20	21	* 22	23	24*	675.7
	682		674		672	
* 25	26	27	28	* 29	30	675.3
672		* 675		679		
31	* 32	* 33	34*	35	36	673.5
	677	678	674			
667.9	679.2	673.6	672.6	673.6	673.7	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 24. Temperatures measured at 47-cm elevation 0.2 s before power-off.

TEMPERATURE MAP

TRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

ELEVATION 38 CM CROSS SECTION AVERAGE 671.5 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	662.1
	664		668		662	
7	8	9	10	11	12	675.3
677		677		672		
13	14	15	16	17	18	688.7
	685	676	(481)			
19	20	21	22	23	24	676.5
671		686		672		
25	26	27	28	29	30	676.3
	683	678			667	
31	32	33	34	35	36	661.1
663			678		658	
678.4	677.6	679.4	664.9	672.4	659.8	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 25. Temperatures measured at 38-cm elevation 0.2 s before power-off.

TEMPERATURE MAP

TRBT BUNDLE 4

RECORD NUMBER 983 TIME FROM START OF SCAN 98.3 SEC

ELEVATION 29 CM CROSS SECTION AVERAGE 672.4 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	668.7
663		669		674		
7	8	9	10	11	12	675.8
	683		669		673	
13	14	15	16	17	18	668.3
668				672	665	
19	20	21	22	23	24	676.7
	684		677		669	
25	26	27	28	29	30	674.6
669			698	675		
31	32	33	34	35	36	671.4
	688	671		663		
666.6	682.2	678.2	675.3	678.9	669.2	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 26. Temperatures measured at 29-cm elevation 0.2 s before power-off.

## TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983

TIME FROM START OF SCAN 98.3 SEC

ELEVATION 20 CM

CROSS SECTION AVERAGE 678.4 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	666.7
	673	661	666			
7	8	9	10	11	12	678.9
	682			676		
13	14	15	16	17	18	669.5
	679	666	(485)		664	
19	20	21	22	23	24	669.0
663		675				
25	26	27	28	29	30	674.0
	688			679	663	
31	32	33	34	35	36	667.7
668		672	673	658		
665.2	678.4	660.5	669.5	671.2	663.7	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 27. Temperatures measured at 20-cm elevation 0.2 s before power-off.

## TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 983

TIME FROM START OF SCAN 98.3 SEC

ELEVATION 10 CM

CROSS SECTION AVERAGE 647.7 BUNDLE AVERAGE 678.7

1	2	3	4	5	6	
7	8	9	10	11	12	641.8
					642	
13	14	15	16	17	18	
19	20	21	22	23	24	653.3
			653			
25	26	27	28	29	30	648.0
648						
31	32	33	34	35	36	
648.0		653.3		641.8		

ALL TEMPERATURES ARE IN DEGREES C  
TEMPERATURES IN THIS CROSS SECTION NOT INCLUDED IN BUNDLE AVERAGE TEMPERATURE

Fig. 28. Temperatures measured at 10-cm (lower grid) elevation 0.2 s before power-off.

TEMPERATURE MAP

ROD AVERAGE TEMPERATURE MAP

MRBT BUNDLE 4

MRBT BUNDLE 4

RECORD NUMBER 983

TIME FROM START OF SCAN 98.3 SEC

RECORD NUMBER 983

TIME FROM START OF SCAN 98.3 SEC

ELEVATION 5 CM

CROSS SECTION AVERAGE 665.4 BUNDLE AVERAGE 670.7

BUNDLE AVERAGE 670.7 DEGREES C

1	2	3	4	5	6	665.3
				663	667	
7	8	9	10	11	12	674.1
674		674				
13	14	15	16	17	18	669.5
	669		(398)			
19	20	21	22	23	24	659.8
	675			663		
25	26	27	28	29	30	664.4
		666	663			
31	32	33	34	35	36	652.3
692					653	
662.9	672.4	670.2	662.8	663.8	660.8	

* 1 *	2	* 3 *	4	* 5 *	6	667.9
666	672	667	663	678	669	
* 7 *	* 8 *	* 9 *	* 10 *	* 11 *	* 12 *	676.1
678	683	676	668	675	673	
* 13 *	14	* 15 *	16	17	* 18 *	678.2
667	679	673	(483)	665	665	
* 19 *	* 20 *	* 21 *	22	* 23 *	* 24 *	673.8
668	680	680	672	672	679	
* 25 *	26	* 27 *	28	* 29 *	30	672.3
678	674	672	673	676	668	
* 31 *	* 32 *	* 33 *	* 34 *	* 35 *	* 36 *	664.1
661	668	669	678	663	655	
668.3	676.3	672.9	669.2	670.4	666.5	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING ROW & COLUMN AVERAGES

Fig. 29. Temperatures measured at 5-cm elevation 0.2 s before power-off.

Fig. 30. Average simulator temperatures measured 0.2 s before power-off.

ORNL-DWG 81-8143A ETD




Fig. 31. Characteristic B-4 temperatures and pressures during transient.



P R E S S U R E M A P

NRBT BUNDLE 4

RECORD NUMBER 4718

TIME FROM START OF SCAN 471.8 SEC

AVERAGE PRESSURE 8266 KPA (DIFFERENTIAL)  
STEAM PRESSURE 281 KPA (GAGE)

1	2	3	4	5	6	
8825	8515	8528	8581	8611	8799	8642
7	8	9	10	11	12	8149
8311	7769	7823	8283	8197	8513	
13	14	15	16	17	18	8884
8325	7164	8014	( 488)	8482	8515	
19	20	21	22	23	24	8816
8383	7743	7457	7976	8087	8531	
25	26	27	28	29	30	8859
8583	7738	7646	7882	7963	8622	
31	32	33	34	35	36	8645
8821	8536	8484	8478	8634	8927	
8528	7911	7991	8233	8382	8651	

ALL SIMULATOR PRESSURES ARE DIFFERENTIAL AND ARE IN KPA  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 32. Simulator pressures measured 0.7 s before depressurization.

T E M P E R A T U R E M A P

NRBT BUNDLE 4

RECORD NUMBER 4718

TIME FROM START OF SCAN 471.8 SEC

ELEVATION 84 CM CROSS SECTION AVERAGE 515.5 BUNDLE AVERAGE 583.5

1	2	3	4	5	6	
508	514	514		509		511.4
7	8	9	10	11	12	8149
		528	513		507	513.3
13	14	15	16	17	18	8884
524				512	512	516.1
19	20	21	22	23	24	8816
	527		521		515	521.1
25	26	27	28	29	30	8859
528		526		517		528.9
31	32	33	34	35	36	8645
			517		502	589.4
517.4	528.7	528.8	516.9	512.8	588.8	

ALL TEMPERATURES ARE IN DEGREES C

Fig. 33. Temperatures measured at 84-cm elevation 0.7 s before depressurization.



TEMPERATURE MAP

NRBT BUNDLE 4

RECORD NUMBER 4710 TIME FROM START OF SCAN 471.0 SEC  
 ELEVATION 56 CM CROSS SECTION AVERAGE 600.8 BUNDLE AVERAGE 583.5

1	2	3	4	5	6	589.7
	500		592		(570)	
7	8	9	10	11	12	590.6
500	600			599		
13	14	15	16	17	18	615.2
	611	619	(611)			
19	20	21	22	23	24	607.3
596		619		607		
25	26	27	28	29	30	599.7
	600		611		500	
31	32	33	34	35	36	585.0
(565)				505	(559)	
591.7	603.8	619.4	601.2	597.2	500.3	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 36. Temperatures measured at 56-cm elevation 0.7 s before depressurization.

TEMPERATURE MAP

NRBT BUNDLE 4

RECORD NUMBER 4710 TIME FROM START OF SCAN 471.0 SEC  
 ELEVATION 47 CM CROSS SECTION AVERAGE 604.9 BUNDLE AVERAGE 593.5

1	2	3	4	5	6	595.8
(570)		600		592		
7	8	9	10	11	12	607.2
		619	614		500	
13	14	15	16	17	18	604.3
604				611	590	
19	20	21	22	23	24	613.5
	622		626		590	
25	26	27	28	29	30	609.3
599		620		609		
31	32	33	34	35	36	596.3
	589	602	590			
601.2	605.2	610.4	612.5	604.1	593.1	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 37. Temperatures measured at 47-cm elevation 0.7 s before depressurization.

TEMPERATURE MAP

MPBT BUNDLE 4

RECORD NUMBER 4718 TIME FROM START OF SCAN 471.8 SEC  
 ELEVATION 38 CM CROSS SECTION AVERAGE 611.5 BUNDLE AVERAGE 583.5

1	2	3	4	5	6	593.6
	591		597		(577)	
7	8	9	10	11	12	609.3
598		623		606		
13	14	15	16	17	18	629.8
	626	632	(627)			
19	20	21	22	23	24	619.1
606		633		619		
25	26	27	28	29	30	600.8
	611	626		509		
31	32	33	34	35	36	603.6
(572)			604		(561)	
602.8	609.2	628.4	609.2	612.7	599.4	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 38. Temperatures measured at 38-cm elevation 0.7 s before depressurization.

TEMPERATURE MAP

MPBT BUNDLE 4

RECORD NUMBER 4718 TIME FROM START OF SCAN 471.8 SEC  
 ELEVATION 29 CM CROSS SECTION AVERAGE 600.2 BUNDLE AVERAGE 583.5

1	2	3	4	5	6	596.0
(573)		600		594		
7	8	9	10	11	12	610.6
	620		618		593	
13	14	15	16	17	18	607.1
607				616	598	
19	20	21	22	23	24	620.1
	630		630		599	
25	26	27	28	29	30	610.7
596			624	612		
31	32	33	34	35	36	600.3
	600	600		593		
601.7	616.8	604.3	624.4	603.4	597.0	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 39. Temperatures measured at 29-cm elevation 0.7 s before depressurization.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 4718 TIME FROM START OF SCAN 471.8 SEC  
 ELEVATION 20 CM CROSS SECTION AVERAGE 603.9 BUNDLE AVERAGE 583.5

1	2	3*	4*	5	6	596.3
	595	596	598			
7	8*	9	10	11*	12	614.1
	619			618		
13	14	15*	16*	17	18*	618.4
	627	(631)	(625)		594	
19*	20	21*	22	23	24	602.8
	602	(633)				
25	26	27	28	29*	30	604.6
	611			614	588	
31*	32	33*	34*	35	36	600.5
(577)		606	605	591		
602.8	612.9	608.6	601.8	604.8	591.1	

ALL TEMPERATURES ARE IN DEGREES C  
 VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 40. Temperatures measured at 20-cm elevation 0.7 s before depressurization.

TEMPERATURE MAP

MRBT BUNDLE 4

RECORD NUMBER 4718 TIME FROM START OF SCAN 471.8 SEC  
 ELEVATION 10 CM CROSS SECTION AVERAGE 594.1 BUNDLE AVERAGE 583.5

1	2	3	4	5	6	
7	8	9	10	11	12*	577.5
					578	
13	14	15	16	17	18	
19	20	21	22*	23	24	614.2
			614			
25*	26	27	28	29	30	598.5
	591					
31	32	33	34	35	36	
598.5			614.2		577.5	

ALL TEMPERATURES ARE IN DEGREES C  
 TEMPERATURES IN THIS CROSS SECTION NOT INCLUDED IN BUNDLE AVERAGE TEMPERATURE

Fig. 41. Temperatures measured at 10-cm (lower grid) elevation 0.7 s before depressurization.



TEMPERATURE MAP

IRBT BUNDLE 4

RECORD NUMBER 4710

TIME FROM START OF SCAN 471.0 SEC

ELEVATION 5 CM

CROSS SECTION AVERAGE

565.5

BUNDLE AVERAGE

583.5

1	2	3	4	5	6	546.6
				548	545	
7	8	9	10	11	12	568.6
551		586				
13	14	15	16	17	18	578.6
	571		(575)			
19	20	21	22	23	24	573.4
	577			578		
25	26	27	28	29	30	578.8
		571	578			
31	32	33	34	35	36	
(535)					(528)	
551.2	573.7	578.6	578.4	588.9	540.2	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING AVERAGES

Fig. 42. Temperatures measured at 5-cm elevation 0.7 s before depressurization.

ROD AVERAGE TEMPERATURE MAP

IRBT BUNDLE 4

RECORD NUMBER 4710

TIME FROM START OF SCAN 471.0 SEC

BUNDLE AVERAGE 583.5 DEGREES C

* 1 *	* 2 *	* 3 *	* 4 *	* 5 *	* 6 *	567.6
558	572	577	587	561	556	
* 7 *	* 8 *	* 9 *	* 10 *	* 11 *	* 12 *	586.3
576	607	587	582	596	563	
* 13 *	* 14 *	* 15 *	* 16 *	* 17 *	* 18 *	592.1
578	609	617	(609)	577	576	
* 19 *	* 20 *	* 21 *	* 22 *	* 23 *	* 24 *	592.1
593	589	617	592	593	568	
* 25 *	* 26 *	* 27 *	* 28 *	* 29 *	* 30 *	586.6
571	595	586	596	588	576	
* 31 *	* 32 *	* 33 *	* 34 *	* 35 *	* 36 *	572.9
562	582	596	591	581	537	
571.7	592.8	596.8	587.7	582.6	563.6	

ALL TEMPERATURES ARE IN DEGREES C  
VALUES IN PARENTHESES ARE NOT USED IN DETERMINING ROW & COLUMN AVERAGES

Fig. 43. Average simulator temperatures measured 0.7 s before depressurization.

ORNL-DWG 81-16438 ETD




Fig. 44. B-4 shroud and simulator temperatures measured at 76-cm elevation during powered portion of transient.

ORNL-DWG 81-16439 ETD




Fig. 45. B-4 shroud and simulator temperatures measured at 76-cm elevation during transient.

ORNL-DWG 81-16440 ETD




Fig. 46. B-4 steam pressure and characteristic temperatures measured during transient.








Fig. 49. Temperature and pressure transients for B-4 rod No. 3.




Fig. 50. Temperature and pressure transients for B-4 rod No. 4.




Fig. 51. Temperature and pressure transients for B-4 rod No. 5.




Fig. 52. Temperature and pressure transients for B-4 rod No. 6.




Fig. 53. Temperature and pressure transients for B-4 rod No. 7.




Fig. 54. Temperature and pressure transients for B-4 rod No. 8.




Fig. 55. Temperature and pressure transients for B-4 rod No. 9.




Fig. 56. Temperature and pressure transients for B-4 rod No. 10.




Fig. 57. Temperature and pressure transients for B-4 rod No. 11.




Fig. 58. Temperature and pressure transients for B-4 rod No. 12.






Fig. 59. Temperature and pressure transients for B-4 rod No. 13.




Fig. 60. Temperature and pressure transients for B-4 rod No. 14.




Fig. 61. Temperature and pressure transients for B-4 rod No. 15.




Fig. 62. Temperature and pressure transients for B-4 rod No. 16.




Fig. 63. Temperature and pressure transients for B-4 rod No. 17.




Fig. 64. Temperature and pressure transients for B-4 rod No. 18.




Fig. 65. Temperature and pressure transients for B-4 rod No. 19.




Fig. 66. Temperature and pressure transients for B-4 rod No. 20.




Fig. 67. Temperature and pressure transients for B-4 rod No. 21.




Fig. 68. Temperature and pressure transients for B-4 rod No. 22.




Fig. 69. Temperature and pressure transients for B-4 rod No. 23.




Fig. 70. Temperature and pressure transients for B-4 rod No. 24.






Fig. 71. Temperature and pressure transients for B-4 rod No. 25.




Fig. 72. Temperature and pressure transients for B-4 rod No. 26.




Fig. 73. Temperature and pressure transients for B-4 rod No. 27.




Fig. 74. Temperature and pressure transients for B-4 rod No. 28.




Fig. 75. Temperature and pressure transients for B-4 rod No. 29.




Fig. 76. Temperature and pressure transients for B-4 rod No. 30.




Fig. 77. Temperature and pressure transients for B-4 rod No. 31.




Fig. 78. Temperature and pressure transients for B-4 rod No. 32.




Fig. 79. Temperature and pressure transients for B-4 rod No. 33.




Fig. 80. Temperature and pressure transients for B-4 rod No. 34.




Fig. 81. Temperature and pressure transients for B-4 rod No. 35.




Fig. 82. Temperature and pressure transients for B-4 rod No. 36.






Fig. 83. Partially assembled B-4 bundle.




Fig. 84. Bundle B-4 before installation of north panel of shroud box.




Fig. 85. Bundle B-4 shroud panels with reflector strip folded back on west panel to show insulating material.




Fig. 86. Completely assembled B-4 bundle.




Fig. 87. Shroud thermocouple attachment in B-4 cest.






Fig. 88. Detail of shroud thermocouple installation on east face of B-4 shroud.



ORNL PHOTO 7465-80A




Fig. 89. Detail of outlet steam thermocouple installation in B-4 test.

ORNL PHOTO 7169-81




Fig. 90. Posttest view of west face of bundle B-4 and shroud.




Fig. 91. 91 Posttest views of (a) north, (b) east, (c) south, and (d) west faces of bundle B-4.




Fig. 92. Close-up views of west face of bundle B-4 showing ballooned zone of No. 14 simulator.



ORNL PHOTO 6016-81




Fig. 93. B-4 bundle viewed from south side as successive layers of rods were removed from bundle starting at bottom of photograph and progressing to top. Rod 16 was unpressurized and unheated (electrically) during test.




Fig. 94. Ballooned region in B-4 tube No. 14.






Fig. 95. Simulator axial shrinkage in B-4 test.




Fig. 96. Deformation profile of tube 1 in B-4 test.




Fig. 97. Deformation profile of tube 2 in B-4 test.




Fig. 98. Deformation profile of tube 3 in B-4 test.




Fig. 99. Deformation profile of tube 4 in B-4 test.




Fig. 100. Deformation profile of tube 5 in B-4 test.




Fig. 101. Deformation profile of tube 6 in B-4 test.




Fig. 102. Deformation profile of tube 7 in B-4 test.




Fig. 103. Deformation profile of tube 8 in B-4 test.




Fig. 104. Deformation profile of tube 9 in B-4 test.




Fig. 105. Deformation profile of tube 10 in B-4 test.






Fig. 106. Deformation profile of tube 11 in B-4 test.




Fig. 107. Deformation profile of tube 12 in B-4 test.




Fig. 108. Deformation profile of tube 13 in B-4 test.




Fig. 109. Deformation profile of tube 14 in B-4 test.




Fig. 110. Deformation profile of tube 15 in B-4 test.




Fig. 111. Deformation profile of tube 16 in B-4 test. Rod 16 was unpressurized and unheated (electrically) during test.




Fig. 112. Deformation profile of tube 17 in B-4 test.




Fig. 113. Deformation profile of tube 18 in B-4 test.




Fig. 114. Deformation profile of tube 19 in B-4 test.




Fig. 115. Deformation profile of tube 20 in B-4 test.




Fig. 116. Deformation profile of tube 21 in B-4 test.




Fig. 117. Deformation profile of tube 22 in B-4 test.






Fig. 118. Deformation profile of tube 23 in B-4 test.




Fig. 119. Deformation profile of tube 24 in B-4 test.




Fig. 120. Deformation profile of tube 25 in B-4 test.




Fig. 121. Deformation profile of tube 26 in B-4 test.




Fig. 122. Deformation profile of tube 27 in B-4 test.




Fig. 123. Deformation profile of tube 28 in B-4 test.




Fig. 124. Deformation profile of tube 29 in B-4 test.




Fig. 125. Deformation profile of tube 30 in B-4 test.




Fig. 126. Deformation profile of tube 31 in B-4 test.




Fig. 127. Deformation profile of tube 32 in B-4 test.




Fig. 128. Deformation profile of tube 33 in B-4 test.




Fig. 129. Deformation profile of tube 34 in B-4 test.






Fig. 130. Deformation profile of tube 35 in B-4 test.




Fig. 131. Deformation profile of tube 36 in B-4 test.




Fig. 132. Coolant channel flow area restriction in B-4 test.

NUREG/CR-2968  
 ORNL/TM-8509  
 Dist. Category R3

Internal Distribution

- |       |                |        |                                   |
|-------|----------------|--------|-----------------------------------|
| 1-5.  | R. H. Chapman  | 16.    | Patent Office                     |
| 6.    | J. L. Crowley  | 17.    | Nuclear Safety Information Center |
| 7.    | D. S. Griffith | 18.    | Central Research Library          |
| 8.    | D. O. Hobson   | 19.    | Document Reference Section        |
| 9-13. | A. W. Longest  | 20-21. | Laboratory Records Department     |
| 14.   | A. L. Lotts    | 22.    | Laboratory Records (RC)           |
| 15.   | H. E. Trammell |        |                                   |

External Distribution

23. Office of Assistant Manager for Energy Research and Development, DOE, ORO, Oak Ridge, TN 37830
24. Chief, Fuel Behavior Branch, Office of Nuclear Regulatory Research, Nuclear Regulatory Commission, Washington, DC 20555
25. Chief, Core Performance Branch, Office of Nuclear Reactor Regulation, Nuclear Regulatory Commission, Washington, DC 20555
26. R. Van Houten, Fuel Behavior Branch, Office of Nuclear Regulatory Research, Nuclear Regulatory Commission, Washington, DC 20555
27. G. P. Marino, Fuel Behavior Branch, Office of Nuclear Regulatory Research, Nuclear Regulatory Commission, Washington, DC 20555
28. R. A. Adamson, Mail Code V-03, General Electric Company, Vallecitos Atomic Laboratory, P.O. Box 846, Pleasanton, CA 94566
29. D. L. Burman, Westinghouse Nuclear Fuel Division, P.O. Box 355, Pittsburgh, PA 15230
30. C. E. Crouthamel, Exxon Nuclear, Inc., 2955 George Washington Way, Richland, WA 99352
31. F. J. Erbacher, Project Nukleare Sicherheit, Kernforschungszentrum Karlsruhe, Postfach 3640, 75 Karlsruhe, Federal Republic of Germany
32. J. Gittus, UKAEA Atomic Energy Research Establishment, Harwell, Didcot, Oxfordshire, OX11 0RA, England
33. D. L. Hagrman, EG&G Idaho, Inc., INEL, Idaho Falls, ID 83401
34. T. Healey, GEGB Berkeley Nuclear Laboratories, Berkeley, Gloucestershire, GL13 9PB, England
35. T. Hoshi, Japan Atomic Energy Research Institute, Tokai-Mura, Naga-Gun, Ibaraki-Ken, Japan
36. T. Howe, EG&G Idaho, Inc., INEL, Idaho Falls, ID 83401
37. E. T. Laats, EG&G Idaho, Inc., INEL, Idaho Falls, ID 83401
- 38-39. W. Lowenstein, Electric Power Research Institute, 3412 Hillview Avenue, P.O. Box 10412, Palo Alto, CA 94304
40. A. L. Lowe, Babcock and Wilcox Company, P.O. Box 1260, Lynchburg, VA 24505

41. C. L. Mohr, Pacific Northwest Laboratories, P.O. Box 999, Richland, WA 99352
42. M. Murillo, Electric Power Research Institute, 3412 Hillview Avenue, P.O. Box 10412, Palo Alto, CA 94304
43. H. Rininsland, Projekt Nukleare Sicherheit, Kernforschungszentrum Karlsruhe, Postfach 3640, 75 Karlsruhe, Federal Republic of Germany
44. P. A. Smerd, Combustion Engineering, Inc., 1000 Prospect Hill Road, Windsor, CT 06093
45. W. Spencer, EG&G Idaho, Inc., INEL, Idaho Falls, ID 83401
- 46-47. Technical Information Center, DOE, Oak Ridge, TN 37830
- 48-362. Distribution as shown for NRC category R3 (NTIS-10)

120555078877 1 ANR3  
US NRC  
ADM DIV OF TIDC  
PDR NUREG COPY  
POLICY & PUBLICATNS MGT BR  
LA 212  
WASHINGTON DC 20555