



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 11, 1983 MAR 15 AIO: 43

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Control Room Air Conditioning
System 'B' Train Declared
Inoperable
LER 83-047/03 L-0
AECM-83/0167

On February 10, 1983, with the plant in cold shutdown, the Control Room Air Conditioning System 'B' train was declared inoperable due to a Freon leak. Technical Specification 3.7.2 action statement b.2 was entered. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-047/03 L-0.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, JR.

JPM:sap
Attachment

- cc: Mr. J. B. Richard (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

IC 22

8303180027 830311
PDR ADOCK OS0G0416
S PDR