NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

[redacted]NTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Licensee Code (9–14)	(2)	License Number (15–25)	(3)	License Type (26–30)	(4)	CAT (57–58)	(5)
0 1	N C B E P 2		0 0 - 0 0 0 0 0 - 0 0		4 1 1 1 1			

CON'T

Line	Report Source (60)	(6)	Docket Number (61–68)	(7)	Event Date (69–74)	(8)	Report Date (75–80)	(9)
0 1	L		0 5 0 - 0 3 2 4		0 3 0 1 8 3		0 3 1 1 8 3	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Routine surveillance during plant operation revealed HPCI system steamline flow high
0 3 instrument, 2-E41-dPIS-N005, was showing a negative indication while redundant
0 4 instrument, 2-E41-dPIS-N004, was showing an expected zero indication. In accordance
0 5 with technical specifications, the N005 instrument was placed in the tripped condition
0 6 and the HPCI system was declared inoperable. At the time of this event, the RCIC
0 7 system was operable. This event did not affect the health and safety of the public.
0 8 Technical Specifications 3.3.2, 3.5.1, 6.9.1.9b

Line	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
0 9	S D	E	E	I N S T R U	S	Z

(17) LER/RO Report Number	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 3	—	0 2 1	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
E	F	Z	Z	0 0 0 0	N	Y	N	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The N005 was found operating out of calibration tolerances attributed to instrument
1 1 drift. The N005 instrument, Model No. 288, was calibrated and returned to service.
1 2 This particular instrument will be replaced with analog type instrumentation in
1 3 accordance with an approved plant modification during a future unit outage.
1 4

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
1 5	E	1 0 0	NA	A	Operator Surveillance

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
1 6	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
1 7	0 0 0	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
1 8	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
1 9	Z	

8303180232 830311
PDR ADOCK 05000324
S PDR

PUBLICITY

Line	Issued (44)	Description (45)	NRC USE ONLY
2 0	N	NA	

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926