

May 26, 1994

Docket No. 50-341

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION:

Docket File ACRS (10)
NRC & Local PDRs M. Phillips, RIII
PD31 Rdg. File KJabbour, 14H25
JRoe JWermiel, 8H3
JZwolinski SRhow, 8H3
LBMarsh
TColburn
CJamerson
OGC

Dear Mr. Gipson:

cc: Plant Service list

SUBJECT: TRANSMITTAL OF THE NRC SAFETY EVALUATION REPORT FOR THE BWR OWNERS' GROUP RESPONSE TO GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," AND THE CLOSEOUT OF THIS ISSUE - FERMI 2 (TAC NO. M74942)

Enclosed is the NRC Safety Evaluation Report (SER) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted.

Furthermore, your letter, dated March 19, 1990, provided your plant-specific response to the Generic Letter (GL) for your facility. The April 2, 1990, report and your plant-specific response confirm that your plant already provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1341.

Sincerely,

Original Signed By Timothy G. Colburn:

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

9406020221 940526
PDR ADOCK 05000341
P PDR

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFFICE	LA:PD31	PM:PD31	BC:HICB	PD:PD31
NAME	CJamerson	TColburn:gll	JWermiel	LBMarsh
DATE	05/25/94	05/25/94	05/26/94	05/24/94

OFFICIAL RECORD COPY FILENAME: G:\WPDOCS\FERMI\FE74942.BWR

810157

DFE1

May 26, 1994

DISTRIBUTION:

Docket No. 50-341

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Docket File ACRS (10)
NRC & Local PDRs M. Phillips, RIII
PD31 Rdg. File KJabbour, 14H25
JRoe JWermiel, 8H3
JZwoinski SRhow, 8H3
LBMarsh
TColburn
CJamerson
UGC

Dear Mr. Gipson:

cc: Plant Service list

SUBJECT: TRANSMITTAL OF THE NRC SAFETY EVALUATION REPORT FOR THE BWR OWNERS' GROUP RESPONSE TO GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," AND THE CLOSEOUT OF THIS ISSUE - FERMI 2 (TAC NO. M74942)

Enclosed is the NRC Safety Evaluation Report (SER) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted.

Furthermore, your letter, dated March 19, 1990, provided your plant-specific response to the Generic Letter (GL) for your facility. The April 2, 1990, report and your plant-specific response confirm that your plant already provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1341.

Sincerely,

Original Signed By Timothy G. Colburn:

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

9406020221 940526
PDR ADOCK 05000341
P PDR

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFFICE	LA:PD31	PM:PD31	BC:HICB	PD:PD31
NAME	CJamerson	TColburn:gll	JWermiel	LBMarsh
DATE	05/25/94	05/25/94	05/26/94	05/24/94

OFFICIAL RECORD COPY FILENAME: G:\WPDOCS\FERMI\FE74942.BWR

010157

DFU



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 26, 1994

Docket No. 50-341

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Gipson:

SUBJECT: TRANSMITTAL OF THE NRC SAFETY EVALUATION REPORT FOR THE BWR OWNERS' GROUP RESPONSE TO GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," AND THE CLOSEOUT OF THIS ISSUE - FERMI 2 (TAC NO. M74942)

Enclosed is the NRC Safety Evaluation Report (SER) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted.

Furthermore, your letter, dated March 19, 1990, provided your plant-specific response to the Generic Letter (GL) for your facility. The April 2, 1990, report and your plant-specific response confirm that your plant already provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1341.

Sincerely,

Handwritten signature of Timothy G. Colburn in cursive script.

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. Douglas R. Gipson
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Robert Newkirk
Director - Nuclear Licensing
Detroit Edison Company
Fermi-2
6400 North Dixie Highway
Newport, Michigan 48166