

CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ] [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S | C | V | C | S | I | 02 | 0 | 0 - 0 | 0 | 0 | 0 | 0 | 0 - 0 | 0 | 0 | 03 | 4 | 1 | 0 | 0 | 0 | 04 | | | 05

CON'T 01 | REPORT SOURCE | L | 06 | 0 | 5 | P | 0 | 0 | 0 | 0 | 8 | 9 | 5 | 07 | 0 | 2 | 1 | 0 | 8 | 3 | 08 | 0 | 3 | 1 | 0 | 8 | 3 | 09

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On February 10, 1983, with the Plant in Mode 1, the flow indicator for Steam  
03 | Generator "A" Feedwater Flow (FI-477) failed low as compared to redundant channels.  
04 | The channel was declared inoperable, and the bistables placed in the tripped  
05 | condition. There were no adverse consequences as the instrument failed in the safe  
06 | direction, and a reactor trip would still have occurred upon setpoint actuation.

09 | SYSTEM COL: | I | A | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | G | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | P | 15 | VALVE SUBCODE | Z | 16  
17 | LER/RO REPORT NUMBER | 8 | 3 | SEQUENTIAL REPORT NO. | 0 | 1 | 2 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0  
ACTION TAKEN | C | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | Y | 23 | NPRO-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | W | 1 | 2 | 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause of this occurrence is attributed to the failure of power supply FQY-477.  
11 | The circuit board was replaced and the channel returned to operable status on  
12 | February 11, 1983. The licensee plans no additional action in regards to this  
13 | event other than the normal surveillance testing.  
14 |

15 | FACILITY STATUS | B | 28 | % POWER | 0 | 5 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | AMOUNT OF ACTIVITY | Z | 34 | LOCATION OF RELEASE | N/A | 36

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43

20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45

NAME OF PREPARER: C.J. McKinney PHONE: (803) 345-5209