



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 7, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

83 MAR 15 A10:42

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Radiological
Environmental Sampling at
Insufficient Frequency
LER 82-043/03 X-1
AECM-83/0134

This letter submits an update to a previous report submitted on September 13, 1982. The event for which the report was submitted occurred on July 22, 1982, when it was determined that discharge basin samples were not being taken hourly as required by Technical Specification 3.12.1. The event was reported pursuant to Technical Specification 6.9.1.13.b.

Design Change Package 82-434 has implemented an automatic sampling station which obtains a composite of hourly samples. The system began operation on February 7, 1983. The DCP has been held open to allow completion of enhancement modifications. Attached is final LER 82-043/03 X-1, which is a final report.

Yours truly,

J.P. McGaughey
for J.P. McGaughey

JPM:sap
Attachment

cc: (See Next Page)

OFFICIAL COPY

8303180248 830307
PDR ADOCK 05000416
S PDR

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0134

Page 2

cc: Mr. N. L. Stampley (v/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555