



Carolina Power & Light Company

Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461-0429

March 11, 1983

FILE: B09-13510C  
SERIAL: BSEP/83-797

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street N.W.  
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-324/  
LICENSE NO. DPR-62  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During a Unit No. 1 refueling outage concurrent with power operation on Unit No. 2, 15 Unit No. 1 and 5 Unit No. 2 fire barrier LCOs with respective issuance dates of February 13, 19, and 21, 1983, were generated to permit the performance of work in the Control and Service Water Buildings required for the installation of five plant modifications. Due to the complexity of the work involved with these modifications, the seven-day specified time frame of each subject LCO has been exceeded. Until the completion of the involved modification work and cancellation of the subject LCOs, appropriate stationed fire watches will remain in effect.

Very truly yours,

C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

MJPjr/dj/LETDJ4

cc: Mr. R. C. DeYoung  
NRC Document Control Desk

OFFICIAL COPY

8303180274 830311  
PDR ADOCK 05000324  
S PDR

*LE 22*