



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 11, 1983

83 MAR 15 410:40

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Auxiliary Building Isolation
Valve Indicating Both Open
and Closed Positions
LER 83-055/03 L-0
AECM-83/0163

On February 9, 1983, with the reactor mode switch in the refuel position and core alterations underway, it was discovered that Auxiliary Building Isolation Valve Q1P45-F159 in the Floor and Equipment Drain System indicated both open and closed positions. The valve was declared inoperable and a Limiting Condition for Operation was entered in accordance with Technical Specification 3.6.6.2. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-055/03 L-0.

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

- cc: Mr. J. B. Richard (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY