

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5	
7	8	9	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT 58	

CON'T

0	1	L	0	5	0	-	0	3	2	4	7	1	2	0	6	8	2	8	0	3	1	1	8	3	9
7	8	REPORT SOURCE				60	61	DOCKET NUMBER				68	69	EVENT DATE				74	75	REPORT DATE				80	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation, a one-half automatic reactor scram signal was received due

0 3 | to an instrument downscale signal from main steamline radiation monitor D,

0 4 | 2-D12-RM-K603D. In accordance with technical specifications, the RPS and PCIS

0 5 | channels fed by this instrument were manually placed in the tripped condition. This

0 6 | event did not affect the health and safety of the public.

0 7 | _____

Technical Specifications 3.3.1., 3.3.2, 6.9.1.9b

0	9	S	D	11	X	12	X	13	I	N	S	T	R	U	14	P	15	Z	16
7	8	SYSTEM CODE		9	CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE			
17	8	2	-	1	3	1	/	0	3	L	-	1							
7	8	LER/RO REPORT NUMBER		21	EVENT YEAR		22	SHUTDOWN METHOD		HOURS		OCCURRENCE CODE		REPORT TYPE		REVISION NO.			
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32					
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SEQUENT REPORT NO.		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER					
X	X	Z	Z	0	0	0	0	N	Y	N	G	0	8	0					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event occurred due to a loss of a high voltage input to the K603D relay, resulting

1 1 | from a disconnection of the instrument high voltage cable. The cable was reconnected

1 2 | and the K603D, Model No. 238X660G1-G2, was calibrated and returned to service. The

1 3 | reason for the disconnected high voltage input cable to K603D could not be determined.

1 4 | _____

1	5	E	0	5	0	NA	A	Operational Event	
7	8	FACILITY STATUS		% POWER		OTHER STATUS		DISCOVERY DESCRIPTION	
1	6	Z	Z	NA	NA	NA	NA	NA	
7	8	ACTIVITY CONTENT RELEASED		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	7	0	0	0	Z	NA	NA	NA	
7	8	PERSONNEL EXPOSURES		PERSONNEL INJURIES		LOSS OF OR DAMAGE TO FACILITY			
1	8	0	0	0	0	0	0	0	
7	8	PERSONNEL EXPOSURES		PERSONNEL INJURIES		LOSS OF OR DAMAGE TO FACILITY			
1	9	Z	NA	NA	NA	NA	NA	NA	
7	8	PERSONNEL EXPOSURES		PERSONNEL INJURIES		LOSS OF OR DAMAGE TO FACILITY			

2	0	N	S	8303180367	830311	PDR	ADOCK	05000324	PDR	NRC USE ONLY	
7	8	ISSUED DESCRIPTION		PDR		PDR					
NAME OF PREPARER		M. J. Pastva, Jr.					PHONE: (919) 457-9521				