

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	G	A	E	I	H	2	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5								
7	8	9	LICENSEE CODE										14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58	80

0	1	L	6	0	5	0	0	0	3	6	6	7	0	2	0	7	8	3	8	0	3	0	3	8	3	9												
7	8	REPORT SOURCE										60	61	DOCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With Unit 2 in steady-state operation, the "2A" reactor coolant recircu-
 0 3 | lation pump tripped due to a trip of the "2A" 4160 volt bus. This is
 0 4 | contrary to the requirements of the Unit 2 Tech. Specs. section 3.4.1.1.
 0 5 | As required per Tech. Specs. section 3.4.1.1, ACTION a, the Unit was
 0 6 | placed in a 12-hour LCO as a result of this event. The "2B" reactor
 0 7 | coolant recirculation pump was operable. The health and safety of the
 0 8 | public were not affected by this non-repetitive event.

0	9	L	B	11	E	12	A	13	P	U	M	P	X	X	14	B	15	Z	16	8	3	0	0	8	0	3	L	0
7	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO			
33	34	Z	18	Z	19	B	20	Z	21	0	0	0	0	N	23	N	24	N	25	B	5	8	0	26				
33	34	ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER										

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this event has been attributed to the spurious trip of "2A"
 1 1 | 4160 volt bus (an in-depth investigation conducted by plant personnel
 1 2 | revealed no apparent reason for the trip). The "2A" 4160 volt bus was
 1 3 | reenergized and the "2A" reactor coolant recirculation pump was restart-
 1 4 | ed and returned to operable status within one hour.

1	5	E	28	0	6	9	29	NA	A	31	Operator Observation	32
7	8	FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
1	6	Z	33	Z	34	NA	NA	NA	NA	NA		
7	8	ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE						
1	7	0	0	0	37	Z	38	NA	39			
7	8	PERSONNEL EXPOSURES		DESCRIPTION								
1	8	0	0	0	40	NA	41					
7	8	PERSONNEL INJURIES		DESCRIPTION								
1	9	Z	42	NA	43							
7	8	LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION								

2	0	N	44	NA	8303180370	830303	PDR	ADOCK	05000366	S	PDR	7	8	9	10	80
7	8	ISSUED DESCRIPTION		PUBLICATION		NRC USE ONLY		NAME OF PREPARER		PHONE						
2	0	S. B. Tipps		(912) 367-7851												