


VOGTLE ELECTRIC GENERATING PLANT  
EXERCISE MANUAL




9406060042 930804  
PDR ADDOCK 05000424  
F PDR



# VOGTLE ELECTRIC GENERATING PLANT EXERCISE MANUAL



9406060042 930804  
FDR ADOCK 05000424  
FDR



**1993 NRC GRADED EXERCISE**  
**August 4, 1993**

**SCHEDULE OF EVENTS**

1. **Players Briefing**  
Time and Date 1300 July 29, 1993  
Location Admin. Bldg. Auditorium
  
2. **Controller Briefing**  
Time and Date 0900 August 3, 1993  
Location EOF - Training Center  
Rooms 506 & 508
  
3. **NRC Graded Exercise**  
Date August 4, 1993
  
4. **GPC Self Critique**  
Time and Date 1500 August 4, 1993  
Location EOF - Training Center  
Rooms 506 & 508
  
5. **Preliminary Exercise Critique  
for Managers** 0930 August 6, 1993  
Admin. Bldg. Conference  
Room
  
6. **NRC Exit** Time TBD August 6, 1993  
Admin. Bldg. Conference  
Room
  
7. **Public Critique** Time TBD August 6, 1993  
Burke County Office Park

1993 NRC GRADED EXERCISE

August 4, 1993

CONTROLLERS

Roving

Rob Dorman (B-035)

Lead Exercise

J. N. Roberts (B-435)

Simulator:

Ext. 3907/3911

Lead Simulator

Perry Tucker

Lead Operations

Tom Petrak

Gary Moore (B-478)

Communications:

Ext. 3911/4449

Simulator/ EOF

Cynthia Brady

Control Room Page Operator

Extra RO (unit 1)

Simulator Page Operator

Michelle Gentry

TSC:

Ext. 4511

Lead

Robert Moye (B-133)

Plant System Engineering

Ricky Bryant (B-476)

Chemistry

Lewis Rouse

HP

John Digby

PEO's (Ext. 3004)

Greg Lee

Brain Whittemore

OSC:

Ext. 3898

Lead

Darrel Barnett (B-287)

I&C

Tim Ruckman (B-228)

Electrical

Floyd Fields (B-059)

Electrical

Mike Silva (B-274)

Mechanical

David Seckinger (B-238)

Mechanical

Gene Anderson

Medical

Teanna Greiner (B-193)

1993 NRC GRADED EXERCISE

August 4, 1993

CONTROLLERS

HP Control Point:

HP Lead  
HP  
HP  
HP

Ext. 4016 or 4018

Mike Kurtzman (B-475)  
Darlene Diaz (B-474)  
Bob Anderson (B-476)  
Art Belge (B-477)

Security:

PESB

Ext. 3737

Tom McQuillen (B-311)  
Terri McCafferty (B-004)  
Lawrence Mayo (B-147)

EOF:

Lead  
  
Dose Assessment  
Communications  
  
Field Monitoring Teams (Lead)

Ext. 4449

Jim Roberts (B-435)  
Paul Herrmann  
Rachelle Reddick  
Cynthia Brady

Russell Brown  
Merrill Maddox  
Dan Hill  
Gene Henry

Assembly Area (Admin. Building):

Terri McCafferty (B-004)

**1993 NRC GRADED EXERCISE**  
**August 4, 1993**

**PARTICIPATING AGENCIES**

**I. GEORGIA POWER COMPANY**

- A. Plant Vogtle
  - 1. EOF
  - 2. TSC
  - 3. OSC
  - 4. Simulator
- B. General Office Operations Center
- C. Emergency News Center (ENC)

**II. OFFSITE**

- A. Savannah River Site - Communications only
- B. South Carolina EPD - Communications only
- C. Aiken County - Communications only
- D. Barnwell County - Communications only
- E. Allendale County - Communications only
- F. South Carolina Dept. of Health and Environmental Control (DHEC) - Communications only
- G. Georgia Emergency Management Agency (GEMA) - Partial from FEOC
- H. Burke County EMA - partial from EOC
- I. Burke County Ambulance
- J. Burke County Hospital

**1993 NRC GRADED EXERCISE**

**August 4, 1993**

**OBJECTIVES**

The Vogtle Electric Generating Plant (VEGP) emergency preparedness exercise objectives are based on Nuclear Regulatory Commission (NRC) requirements provided in 10CFR50.47, "Emergency Plans," and 10CFR50, Appendix E, "Emergency Planning and Preparedness for Production and Utilization Facilities." Additional guidance provided in NUREG-0654, FEMA-REP-1, Revision 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans" was utilized in developing the objectives.

**A. Accident Assessment and Classification**

1. Demonstrate the ability to identify initiating conditions, determine emergency action levels (EAL) parameters and correctly classify the emergency throughout the exercise.
2. Demonstrate the ability to provide core damage assessments.

**B. Notifications**

1. Demonstrate the ability to alert, notify and mobilize site emergency response personnel.
2. Demonstrate the ability to expeditiously notify state, local and federal authorities (NRC).
3. Demonstrate the ability to warn or advise onsite individuals of emergency conditions.

**C. Emergency Response**

1. Demonstrate the capability to direct and control emergency operations.
2. Demonstrate the ability to transfer emergency direction from Control Room (simulator) to the Technical Support Center (TSC) and from the TSC to the Emergency Operations Facility (EOF) in a timely manner.
3. Demonstrate the ability to prepare for around the clock staffing requirements.
4. Demonstrate the ability to perform assembly and accountability in a timely manner.

1993 NRC GRADED EXERCISE

August 4, 1993

OBJECTIVES

D. Emergency Response Facilities

1. Demonstrate timely activation of the TSC, Operations Support Center (OSC), and EOF.
2. Demonstrate the adequacy of equipment, security provisions, and habitability precautions for the TSC, OSC, and EOF, and Emergency News Center (ENC).
3. Demonstrate the adequacy of communications for all emergency support resources.

E. Radiological Assessment and Control

1. Demonstrate the ability to obtain onsite radiological surveys and samples.
2. Demonstrate the ability to utilize the post accident sampling system to collect and analyze samples to determine the extent of core damage.
3. Demonstrate the ability to continuously monitor and control radiation exposure to emergency workers.
4. Demonstrate the ability to assemble and deploy field monitoring teams in a timely fashion.
5. Demonstrate the ability to satisfactorily collect and disseminate field team data.
6. Demonstrate the ability to develop dose projections and determine appropriate protective actions.

F. Medical

1. Demonstrate the ability to respond to and treat an injured individual.



1993 NRC GRADED EXERCISE

August 4, 1993

OBJECTIVES

G. Public Information

1. Demonstrate the capability to coordinate the development and dissemination of clear, accurate and timely information to the news media.
2. Demonstrate the ability to brief the media in a clear, accurate, and timely manner.
3. Demonstrate the capability to establish and operate rumor control in a coordinated fashion.

H. Recovery

1. Demonstrate the ability to start planning for recovery by conducting an initial briefing on recovery procedures and by the establishment of a tentative organization.

I. Evaluation

1. Demonstrate the ability to conduct a post-exercise critique to determine areas requiring improvement and corrective action.

**1993 NRC GRADED EXERCISE**

August 4, 1993

**INITIAL CONDITIONS**

**Unit 2 is in a refueling outage.**

- The reactor is de-fueled.

**Unit 1 is in Mode 1 at MOL in Cycle 5, operating at 100% power.**

- The unit has been on line for 135 days.
- Containment mini-purge is in service (release permit # 930099-G) in preparation for a containment entry to repair the transmitter for 1LT-461.
- All control systems are in automatic.

**Key Unit 1 Parameters:**

- Reactor Power = 100%
- RCS at NOTP
- RCS boron concentration = 1003 ppm (BAST = 7100 ppm)
- Pressurizer level and Steam Generator levels at program
- Core burnup = 9000 MWD/MTU

**Unit 1 Systems / Equipment Out Of Service**

- ① Pressurizer level channel "461" due to a faulty transmitter. I&C preparing for containment entry to replace the transmitter.
- ② RHR "A" train out of service (72 hour LCO bearing replacement) scheduled to return to service 1600 August 5.

**Meteorological Data:**

- Wind Direction 90° (from)
- Wind Speed 2.3 mph
- Temperature 80°
- Stability Class B
- Precipitation 0" in the past 24 hours

LCO STATUS SHEET

SECTION I: INITIATION

Applicable Modes 1, 2, 3, 4, 5, 6 LCO Number 1-93-304

Tech. Spec. 3.0.4 Applicable  YES  NO  
(circle one)

LCO Initiated: Date \_\_\_\_\_ Time \_\_\_\_\_

Tech. Spec. References 3.5.2, 3.5.3.1, 3.4.1.3, 3.4.1.4.1, 3.4.1.4.2, 3.4.8.1, 3.9.8.2

Condition Initiating LCO Action 1-1205-P6-001-M01 RHR PUMP "A" TRAIN MOTOR LOWER BEARING NEEDS REPLACEMENT

REQUIRED ACTIONS	Completion USS Init/Date/Time
------------------	----------------------------------

WITH ONE ECCS SUBSYSTEM INOPERABLE, RESTORE THE INOPERABLE SUBSYSTEM TO OPERABLE STATUS WITHIN 72 HOURS OR BE IN AT LEAST HOT STANDBY WITHIN THE NEXT SIX HOURS AND IN HOT SHUTDOWN WITHIN THE FOLLOWING SIX HOURS.

Document repeating actions on Figure 3.

Remarks \_\_\_\_\_

USS \_\_\_\_\_ SS \_\_\_\_\_

Figure 1

LCO NUMBER \_\_\_\_\_

SECTION II: RESTORATION

Date	DC, MWO, WRT Procedure, Clearance Number	Work Being Performed	Completion Date	USS Init
	19300179 CLR	REPLACE MOTOR LOWER BEARING		
	19201349 MWO	REPLACE MOTOR LOWER BEARING		
	19300616	CALIBRATE IFI 0618 A/B		

Continue on Page 3 of 3 if required.

Continuation Sheet 3 of 3 attached? Yes [ ] No [ ]

Operability Determined: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Chemistry/HP Person Notified (Rad Monitors Only)

Name \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

LCO No Longer Active: Date \_\_\_\_\_ Time \_\_\_\_\_

USS \_\_\_\_\_ SS \_\_\_\_\_

REV. C  
03/01/93

UNIT 1 RHR 2

11205P6501

SCHEDULED START DATE

DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
Aug 3, 1993	06:00	Aug 4, 1993	12:00	Aug 5, 1993	06:00	Aug 5, 1993	12:00
	24:00		12:00		18:00		18:00
			12:00		18:00		18:00

LCD FOR RHR PUMP 1-1205-P6-001-R01 3A HRS

NEW BEARING DAMAGED DURING  
INSTALLATION. REPLACEMENT TO  
ARRIVE BY FEDERAL EXPRESS 1600,

DPS HANS  
CLR 19300179  
ENTER LCD  
0-0

REDF  
CHANGE BEARING &  
11205P601M01  
0-0

1921349

11CPP  
CALIBRATE  
11F1018878  
0-0

1930016

11CPN 1CPN  
CALIBRATE CALIBRATE  
11M1000A/B 11E612  
0-0  
19300753 1930079  
0-0

11B1 PERFORM WELD INSPECTIONS  
0-0

DPS RELEASE  
CLR 19300179  
END SSP1-CLCOP  
0-0

DPS PUP PUMP  
11/2 HP  
ENTER LCD  
0-0

APPROVALS

ORIGINAL FRAGMENT  
PREVIOUSLY  
SIGNED  
AND PLACED  
ON FILE  
IN WFB

SSP1 TIME FOR RHR IA 1-1205-P6-001

PART I: PRE-RELEASE DATA

Release Point ( 25): UNIT 1 CONTAINMENT PURGE/VENT  
Discharge Point ( 5): UNIT ONE PLANT VENT

Permit Issued: 28-apr-1993 19:06:12 Release Type: Batch

Rad Monitor: (25) 1RE2565C  
Rad Monitor Bckgrnd: 0.0000E+00 CPM

Estim. Waste Flow: 1.8000E+04 CFM  
Estim. Waste Volume: 1.3932E+08 CF  
Estim. Release Start: 28-apr-1993 14:59:00  
Estim. Release End: 03-may-1993 23:59:00  
Estim. Duration: 7740.0000 MIN

PART II: PRE-RELEASE CALCULATIONS

Sample Entry # : 129  
Gas sample time: 28-apr-1993 14:59:00 Sampled by: MKJ

Gas Monitor Response: 1.63E+01 CPM  
Total Body Dose Rate: 4.05E-03 mrem/yr % Limit = 0.0%  
Skin Dose Rate: 5.93E-03 mrem/yr % Limit = 0.0%  
Max Organ Dose Rate: 6.41E-04 mrem/yr % Limit = 0.0%  
Max Monitor Setpoint: 1.61E-03 uCi/cc Flag:  
2.01E+05 CPM

Flags: A-Release Curies > Local Limit N-Noble Gas Dose Rate > Limit  
S-Release Curies > Site Limit O-Organ Dose Rate > Limit

	Analysis Date	Measured Concen.	Est. Curies
Noble Gases	28-apr-1993 15:16:54	1.30E-07 uCi/cc	5.13E-01
Particulates	28-apr-1993 15:26:17	1.82E-12 uCi/cc	7.19E-06
Radioiodines	28-apr-1993 16:40:25	7.26E-12 uCi/cc	2.87E-05

LAB FOREMAN  
TECHNICAL REVIEW:

ISOTOPIC IDENTIFICATION - Unit 1  
 -----

Isotope		: Pre-Disp. : Measured : uCi/cc	: Pre-Disp. : Measured : Conc/MPC	: Pre-Disp. : Measured : Conc/Total:	: Conc/Total: : by : Type	: Release : Rate : uCi/sec	: Estimated : Curies : Released
H-3	O:	4.04E-08	2.02E-01	2.37E-01	1.00E+00	3.43E-01	1.59E-01
I-131	R:	7.26E-12	7.26E-02	4.26E-05	1.00E+00	6.17E-05	2.87E-05
AR-41	N:	1.16E-07	2.90E+00	6.81E-01	8.93E-01	9.87E-01	4.58E-01
XE-133	N:	1.40E-08	4.66E-02	8.20E-02	1.07E-01	1.19E-01	5.52E-02
BR-82	P:	1.82E-12	3.04E-04	1.07E-05	1.00E+00	1.55E-05	7.19E-06
Totals :		1.71E-07	3.22E+00	:	:	1.45E+00	6.73E-01

-----

-----  
Georgia Power Company  
Vogtle Electric Generating Plant U-1  
Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

page 4 of 6

930099-G

-----  
Report Category : Calculated Dose Rate to Man (mrem/year) from this  
Type of Activity : Release at Site Boundary.  
Age Group & Pathway(s) : Radioiodines and Particulates  
Controlling Sector : Child . ; Inhalation  
Unit number : NE  
: 1

-----  
:Bone :Liver :Tot-body :Thyroid :Kidney :Lung :GI-LLI  
-----  
NE : 1.37E-06 : 1.80E-04 : 1.79E-04 : 6.41E-04 : 1.81E-04 : 1.78E-04 : 1.78E-04  
-----



-----  
Georgia Power Company  
Vogtle Electric Generating Plant U-1  
Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data  
-----

page 3 of 6

930099-G

-----  
Report Category : Calculated Doses at Site Boundary.  
: Gamma and Beta Air Doses, Tot-body and Skin  
: Doses and Dose Rates.  
Type of Activity : Noble Gases  
Controlling Sector : NE  
Unit number : 1  
-----

:Site	:Tot-body	:Skin Dose	:Gamma Air	:Beta Air	:Tot-body	:Skin
:Boundary	:Dose	:mrem	:mrad	:mrad	:Dose Rate	:Dose Rate
:Dist (km)	:mrem	:	:	:	:mrem/year	:mrem/year
NE	: 1.13E+00	: 5.96E-05	: 8.73E-05	: 6.27E-05	: 2.29E-05	: 4.05E-03 : 5.93E-03

-----

Report Category : Cumulative Dose at Site Boundary  
 Type of Activity : Noble Gases  
 Location : NE at 1.127 km.  
 Unit number : 1

	:Tot-body :mrem	:Skin :mrem	:Gamma Air :mrad	:Beta Air :mrad	:
This Release :	5.96E-05	8.73E-05	6.27E-05	2.29E-05	:
31D Prior: Do Rel :	2.83E-05	6.69E-05	3.40E-05	1.01E-04	:
31D After: Release :	8.43E-05	1.49E-04	9.29E-05	1.23E-04	:
31 Day Limit :	0.00E+00	0.00E+00	2.00E-01	4.00E-01	:
31 Day Limit :	0.00%	0.00%	0.05%	0.03%	:
Qtr Prior: Do Rel :	3.02E-05	7.12E-05	3.62E-05	1.08E-04	:
Qtr After: Release :	8.97E-05	1.59E-04	9.89E-05	1.31E-04	:
Quarterly: Limit :	0.00E+00	0.00E+00	5.00E+00	1.00E+01	:
Quarter: Limit :	0.00%	0.00%	0.00%	0.00%	:
Ann Prior: Do Rel :	1.29E-03	3.03E-03	1.54E-03	4.46E-03	:
Ann After: Release :	1.34E-03	3.12E-03	1.60E-03	4.48E-03	:
Annual Limit :	0.00E+00	0.00E+00	1.00E+01	2.00E+01	:
Annual Limit :	0.00%	0.00%	0.02%	0.02%	:



Georgia Power Company  
 Vogtle Electric Generating Plant U-1  
 BATCH GASEOUS EFFLUENT PERMIT

No. 930099-G  
 Unit # 1

I. REQUEST

X NORMAL RELEASE POINT ESTIMATED START:  
 UNPLANNED UNIT 1 CONTAINMENT PURGE/VENT 28-apr-1993 14:59:00

RELEASE VOLUME (ESTIM.) DISCHARGE POINT ESTIMATED STOP:  
 1.3932E+08 CF UNIT ONE PLANT VENT 03-may-1993 23:59:00

II. SAMPLE IDENTIFICATION

NUMBER COLLECTION DATE/TIME ANALYSIS DATE/TIME  
 129 28-apr-1993 14:59:00 28-apr-1993 15:16:54

III. RADIOANALYSIS - GASEOUS

T-BODY DOSE RATE < 500 CUM. AIR DOSE-GAMMA(Q) < 5 CUM. ORGAN DOSE(Q) < 7.5  
 4.05E-03 9.89E-05 1.03E-04

SKIN DOSE RATE < 3000 CUM. AIR DOSE-GAMMA(A) < 10 CUM. ORGAN DOSE(A) < 15  
 5.93E-03 1.60E-03 1.32E-04

ORGAN DOSE RATE < 1500 CUM. AIR DOSE-BETA(Q) < 10  
 6.41E-04 1.31E-04

CUM. AIR DOSE-BETA(A) < 20  
 4.48E-03

IV. RADIATION MONITOR(S)

NUMBER	SETPOINT	EFFECTIVE GAIN	EXPECTED RESPONSE	ACTUAL RESPONSE
1RE2565C	1.61E-03 uCi/cc	7.99E-09 uCi/cc/cpm	1.30E-07 uCi/cc	_____ uCi/cc
1RE12442C	3.06E-04 uCi/cc	1.60E-08 uCi/cc/cpm	1.14E-08 uCi/cc	_____ uCi/cc
1B&12444C	3.06E-04 uCi/cc	1.60E-08 uCi/cc/cpm	1.14E-08 uCi/cc	_____ uCi/cc

V. AUTHORIZATION

MAX. VOLUME MAX. EFFLUENT FLOW RATE  
 2.7500E+06 CF 1.8000E+04 CFM

The above-named source has been sampled and analyzed and is in compliance with applicable Technical Specifications. Release is authorized for the volume and flow rates specified. (DDCM)

LAB FOREMAN  
 TECHNICAL REVIEW: [Signature]  
 DATE 4/28/93  
 GSOS SS/USJ  
 AUTHORIZATION: \_\_\_\_\_

Purge Required for (check 1) :

- Containment Pressure Control
- Purge Valve Surveillance Tests
- ALARA (personnel entry)
- Respirable Air Quality (personnel entry)

VI. RELEASE DATA

	TIME	DATE	TANK PRESSURE	EFFLUENT FLOW RATE	OPERATOR'S INITIALS
START					
STOP				XXXXXXXXXXXXXXXXXX	

PART I: PRE-RELEASE DATA

Release Point ( 25): UNIT 1 CONTAINMENT PURGE/VENT  
Discharge Point ( 5): UNIT ONE PLANT VENT

Permit Issued: 28-apr-1993 19:06:12 Release Type: Batch

Rad Monitor: (25) 1RE2565C  
Rad Monitor Bckgrnd: 0.0000E+00 CPM

Estim. Waste Flow: 1.8000E+04 CFM  
Estim. Waste Volume: 1.3932E+08 CF  
Estim. Release Start: 28-apr-1993 14:59:00 ✓  
Estim. Release End: 03-may-1993 23:59:00 ✓  
Estim. Duration: 7740.0000 MIN


PART II: PRE-RELEASE CALCULATIONS

Sample Entry # : 129  
Gas sample time: 28-apr-1993 14:59:00 Sampled by: MKJ ✓

Gas Monitor Response: 1.63E+01 CPM  
Total Body Dose Rate: 4.05E-03 mrem/yr % Limit = 0.0%  
Skin Dose Rate: 5.93E-03 mrem/yr % Limit = 0.0%  
Max Organ Dose Rate: 6.41E-04 mrem/yr % Limit = 0.0%  
Max Monitor Setpoint: 1.61E-03 uCi/cc Flag: ✓  
2.01E+05 CPM

Flags: A-Release Curies > Local Limit N-Noble Gas Dose Rate > Limit  
S-Release Curies > Site Limit O-Organ Dose Rate > Limit

	Analysis Date	Measured Concen.	Est. Curies
Noble Gases	28-apr-1993 15:16:54	1.30E-07 uCi/cc ✓	5.13E-01
Particulates	28-apr-1993 15:26:17	1.82E-12 uCi/cc	7.19E-06
Radioiodines	28-apr-1993 16:40:25	7.26E-12 uCi/cc	2.87E-05

LAB FOREMAN  
TECHNICAL REVIEW: 

ISOTOPIC IDENTIFICATION - Unit 1

Isotope		Pre-Disp. : Measured : uCi/cc	Pre-Disp. : Measured : Conc/MPC	Pre-Disp. : Measured : Conc/Total:	Conc/Total : by : Type	Release : Rate : uCi/sec	Estimated : Curies : Released
H-3	O:	4.04E-08 ✓	2.02E-01	2.37E-01	1.00E+00	3.43E-01	1.59E-01
I-131	R:	7.26E-12 ✓	7.26E-02	4.26E-05	1.00E+00	6.17E-05	2.87E-05
AR-41	N:	1.16E-07 ✓	2.90E+00	6.81E-01	8.93E-01	9.87E-01	4.58E-01
XE-133	N:	1.40E-08 ✓	4.66E-02	8.20E-02	1.07E-01	1.19E-01	5.52E-02
BR-82	P:	1.82E-12 ✓	3.04E-04	1.07E-05	1.00E+00	1.55E-05	7.19E-06
Totals :		1.71E-07	3.22E+00	:	:	1.45E+00	6.73E-01

Report Category : Calculated Doses at Site Boundary.  
: Gamma and Beta Air Doses, Tot-body and Skin  
: Doses and Dose Rates.  
Type of Activity : Noble Gases  
Controlling Sector : NE  
Unit number : 1

:Site	:Tot-body	:Skin Dose	:Gamma Air	:Beta Air	:Tot-body	:Skin	
:Boundary	:Dose	:mrem	:mrad	:mrad	:Dose Rate	:Dose Rate	
:Dist (km)	:mrem	:	:	:	:mrem/year	:mrem/year	
NE	1.13E+00	5.96E-05	8.73E-05	6.27E-05	2.29E-05	4.05E-03	5.93E-03

-----  
Georgia Power Company  
Vogtle Electric Generating Plant U-1  
Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data  
-----

930099-G

-----  
Report Category : Calculated Dose Rate to Man (mrem/year) from this  
Type of Activity : Release at Site Boundary.  
Age Group & Pathway(s) : Radioiodines and Particulates  
Controlling Sector : Child . ; Inhalation  
Unit number : NE  
: 1  
-----

-----  
:Bone :Liver :Tot-body :Thyroid :Kidney :Lung :GI-LLI  
-----  
NE : 1.37E-06 : 1.80E-04 : 1.79E-04 : 6.41E-04 : 1.81E-04 : 1.78E-04 : 1.78E-04  
-----



Report Category : Cumulative Dose at Site Boundary  
 Type of Activity : Noble Gases  
 Location : NE at 1.127 km.  
 Unit number : 1

	:Tot-body :mrem	:Skin :mrem	:Gamma Air :mrad	:Beta Air :mrad
This Release	: 5.96E-05	: 8.73E-05	: 6.27E-05	: 2.29E-05
31D Prior: To Rel	: 2.83E-05	: 6.69E-05	: 3.40E-05	: 1.01E-04
31D After: Release	: 8.43E-05	: 1.49E-04	: 9.29E-05	: 1.23E-04
31 Day Limit	: 0.00E+00	: 0.00E+00	: 2.00E-01	: 4.00E-01
% 31 Day Limit	: 0.00%	: 0.00%	: 0.05%	: 0.03%
Qtr Prior: To Rel	: 3.02E-05	: 7.12E-05	: 3.62E-05	: 1.08E-04
Qtr After: Release	: 8.97E-05	: 1.59E-04	: 9.89E-05	: 1.31E-04
Quarterly: Limit	: 0.00E+00	: 0.00E+00	: 5.00E+00	: 1.00E+01
% Quarter: Limit	: 0.00%	: 0.00%	: 0.00%	: 0.00%
Ann Prior: To Rel	: 1.29E-03	: 3.03E-03	: 1.54E-03	: 4.46E-03
Ann After: Release	: 1.34E-03	: 3.12E-03	: 1.60E-03	: 4.48E-03
Annual Limit	: 0.00E+00	: 0.00E+00	: 1.00E+01	: 2.00E+01
% Annual Limit	: 0.00%	: 0.00%	: 0.02%	: 0.02%



## SCENARIO ABSTRACT

The initial conditions have Unit 2 defueled and in a refueling outage. Unit 1 is in Mode 1 at 100% power and has been on line for 222 days. All control systems are in automatic. Containment mini-purge is in service in preparation for a containment entry to repair pressurized level transmitter 461, which is out of service. Additionally, RHR train A is out of service due to scheduled bearing replacement.

The drill scenario creates conditions for an offsite release through the sequential failure of the three fission product barriers. An event is postulated which results in fuel damage and release of fission product activity to the Reactor Coolant System (RCS). In this event, control bank D control rod H-8 drops to the full "in" position in the reactor core due to a blown stationary gripper fuse. Fuel failure occurs due to localized overheating. Various radiation sensors alarm due to the fuel failure. Mini purge damper IHV-2626B inside reactor containment fails to close when operators attempt a manual closure. An alert emergency is declared due to the breach or challenge of one of the three fission product barriers. At Alert Emergency, the ERDS is initiated, the TSC and OSC are activated, and the EOF placed on standby. Accountability is initiated and completed. The mechanism for control rod H-8 ruptures, resulting in a leak in the reactor vessel head. This initiates a reactor trip and SI. RHR B pump fails to start due to faulty relays and purge supply isolation damper IHV-2626B fails to automatically close on SI. A site area emergency is declared due to the breach or challenge of two of the three fission product barriers. The EOF is activated with the declaration of a site area emergency. A bomb threat is received, with an explosion subsequently occurring in the Unit 1 HVAC containment purge equipment room. Plant personnel are dispatched to investigate and report that containment purge isolation damper IHV-2627B and associated piping is breached due to an explosion. A general emergency is declared due to the breach or challenge of three fission product barriers. Protective action recommendations are made to state agencies. The release path is isolated by closing IHV-2626B, which leads to emergency termination and recovery actions.

1993 NRC GRADED EXERCISE

August 4, 1993

SCENARIO TIME LINE

<u>CLASS</u>	<u>TIME</u>	<u>EVENT</u>
	08:00	Start Drill.
	08:05	Control Bank D control rod H-8, drops to the full "in" position in the reactor core (due to a blown stationary gripper fuse). <ul style="list-style-type: none"><li>♦ Flux distribution abnormality begins due to the dropped control rod.</li><li>♦ Control Room Operators enter Abnormal Operating Procedure 18003-C "Rod Control System Malfunction" and reduce reactor power to less than 90%.</li></ul>
	08:20	Fuel failure occurs due to localized overheating. <ul style="list-style-type: none"><li>♦ Chemical Volume Control System (CVCS) letdown radiation monitor RE-48000 alarms on the ERF computer and rapidly goes off-scale high. Radiation levels in the Reactor Coolant System (RCS) sample area start to increase (RE-007B). Chemistry is directed by the control room to sample the RCS.</li></ul>
	08:22	The Gross Failed Fuel Detector alarms.
	08:25	Control Room may isolate containment mini-purge HVAC. Damper 1HV-2626B inside reactor containment (IRC) fails to close.
<b>ALERT</b>	08:35	ALERT EMERGENCY declared due to the breach or challenge of one of three fission product barriers. <ul style="list-style-type: none"><li>♦ Unit shutdown commenced.</li></ul>
	08:50	Emergency Response Data System to NRC activated.
	09:00	TSC and OSC activated. EOF coming to standby.
	09:05	Injured person call-in to control room.
	09:05	Accountability complete.
	09:10	EOF in standby.

1993 NRC GRADED EXERCISE  
August 4, 1993

SCENARIO TIME LINE

<u>CLASS</u>	<u>TIME</u>	<u>EVENT</u>
	09:30	<p>The mechanism housing for control rod H-8 ruptures, resulting in a four inch diameter leak in the reactor vessel head.</p> <ul style="list-style-type: none"><li>• Reactor Trip (if not already actuated) and Safety Injection.</li><li>• RHR B pumps fails to start - trips due to faulty relays.</li><li>• PERMS data no longer available due to Safety Injection.</li><li>• Purge supply isolation damper 1HV-2626B fails to close.</li></ul>
<b>SITE AREA</b>	09:45	<p>SITE AREA EMERGENCY declared due to the breach or challenge of two of three fission product barriers.</p>
	10:15	<p>EOF activated.</p>
	10:45	<p>Bomb threat called in to the main control room. (Disgruntled employee)</p>
	11:00	<p>Explosion in the Unit 1 Heating Ventilation and Air Conditioning (HVAC) containment purge supply "equipment room" (Outside reactor containment (ORC) and located next to the north main steam valve room).</p> <ul style="list-style-type: none"><li>• Security alarm for door 1C108 (room 114).</li><li>• Fire alarm for fire zone 141B, local zone indicating panel (LZIP) 1S48, (rooms 114, 116, and 125).</li><li>• Containment HVAC purge supply isolation damper 1HV-2627B (ORC) QHVC light indication extinguishes.</li></ul>
	11:01	<p>Security dispatches officer to investigate door alarm.</p>
	11:01	<p>Fire protection technician dispatched to LZIP 1S48.</p>
	11:05	<p>Security officer calls in to report conditions. (Steam flowing out, scattered debris, door blown off).</p>

1993 NRC GRADED EXERCISE

August 4, 1993

SCENARIO TIME LINE

<u>CLASS</u>	<u>TIME</u>	<u>EVENT</u>
	11:06	Fire protection tech calls in to report fire alarm investigation information. <ul style="list-style-type: none"><li>• Containment HVAC purge supply isolation damper IHV-2627B and associated piping discovered breached due to bomb.</li></ul>
<b>GENERAL</b>	11:15	GENERAL EMERGENCY declared due to the breach or challenge of three of three fission product barriers. <ul style="list-style-type: none"><li>• Protective Action Recommendations (PAR's): Evacuate Zones A, C-5, D-5, E-5, F-5, SRS to 2 miles. Shelter the remainder of the plume EPZ.</li></ul>
	12:00	IHV-2626B is shut, isolating the release path.
	12:30	Emergency Terminated and Recovery Organization activated.
	13:00	Drill Terminated.

SIMULATOR SCRIPT

A. SIMULATOR SETUP

1. Reset to IC #14.
2. IC Setup:
  - a. Place containment mini-purge in service per SOP 13125-1.
  - b. Place RHR "A" handswitch, 1HS-0620 in PTL.
  - c. Fail pressurizer level channel 461 to 0%. Malf # **PR03C**.
  - d. Trip channel 461 bistables. Remote Function **ES27**.
  - e. Acknowledge annunciators.
3. Snap a temporary IC (Snapshot IC # \_\_\_\_\_).
4. Run and catalog the following programs:
  - a. (TOM) G.CHL1.AUG Seg 1
  - b. (TOM) G.CHL2.AUG Seg 1
  - c. (TOM) G.CHL3.AUG Seg 2
  - d. (TOM) G.RM.AUG Seg 10
  - e. (TOM) G.SISL.AUG Seg 11
5. Reset to temporary IC.
6. Control Board Setup:
  - a. Set control rod step counters to 228 steps on Bank D
  - b. Ensure operator aid for  $\Delta I$  target @ MOL is in place on QMCB panel 'C'.
  - c. Place hold tag on 1HS-0620, "A" RHR pump
  - d. Ensure BAST analysis on the boron meter sample board is 7200 ppm.
  - e. Ensure Accumulator sample analysis is updated.
  - f. Set the ERF computer to MODE 1
7. Insert the following malfunctions:
  - a. "RHR pump trip" (RHR pump 2), malfunction **RH01B**
  - b. "Containment mini-purge supply isolation damper 1HV-2626B fails to close",  
YP:XMFB(269)=T
8. Parameters to Monitor:
  - a. **EDCLOCK**
  - b. **RMCNTR2**
  - c. **RMCNTR3**
  - d. **CHFMLEAK**
  - e. **SIV8801A**
9. Check / Set ERF computer and simulator clocks.

1993 NRC GRADED EXERCISE  
AUGUST 4, 1993

SIMULATOR SCRIPT

**B. EXERCISE SETUP**

1. Conduct pre-drill briefing with simulator players using message #1.

**C. EXERCISE**

- 08:00 Place simulator in RUN
- 08:05 Insert malfunction RD13I, "Dropped RCCA H-8 CBD"
- 08:05 + If attempts are made to close HV-2626B by pulling the fuses to solenoid, Insert malfunction YP:XMFTB(266)=T. (NOTE: This will not close HV-2626B because of the override)
- 08:22 Insert annunciator override 464,ON, "GFFD Alarm"
- 09:30 Insert malfunction RD16, "RCCA H-8 ejected"
- 09:30 + If the operators attempt to decrease ECCS flow by throttle methods directed from EOP 19111-C, then insert remote function "HV-8801A BIT isolation valve position" as follows:
- a. SET YREMFADD(17)=1.0 ⇔ 0.0 (as desired)
  - b. SB YP:REMF(241)=T
- 11:00 Insert the following malfunctions to trip the mini-purge supply HVAC unit 1-1505-B7-002-M01, remove indicating lights from 1HS-2627B, and create a 14" diameter breach in containment:
- a. YP:XMFTB(265)=T; "Explosion"
  - b. YP:XMFTB(172)=T, and YPXSVRTY(149)=50.0; "Containment Leak to Atmosphere"
- 11:25 Insert malfunction FP02 @ 10%, "Fire Protection System Acutation (Motor Driven Fire Pump)"
- 12:00 Remove "Containment mini-purge supply isolation damper 1HV-2626B fails to close", YP:XMFB(269)=F and remove malfunction "Containment Leak to Atmosphere" by setting YP:XMFTB(172)=F
- 13:00 Terminate the Drill upon the direction of the Lead Controller.
- 13:00 + Run and catalog the following programs:
- a. (SRCE) G.CHL1 Seg 1
  - b. (SRCE) G.CHL2 Seg 1
  - c. (SRCE) G.CHL3 Seg 2
  - d. (SRCE) G.RM Seg 10
  - e. (SRCE) G.SISL Seg 11



## IN-PLANT MESSAGE

**TO:** Control Room Operations/Maintenance Manager/  
General Manager

**TIME:** 0800

**FROM:** All Onsite Lead Controllers

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

### INITIAL CONDITIONS

#### MESSAGE:

**Unit 2 is in a refueling outage.**

- The reactor is de-fueled.

**Unit 1 is in Mode 1 at MOL in Cycle 5, operating at 100% power.**

- The unit has been on line for 135 days.
- Containment mini-purge is in service (release permit # 93099-G) in preparation for a containment entry to repair the transmitter for 1LT-461.
- All control systems are in automatic.

#### Key Unit 1 Parameters:

- Reactor Power = 100%
- RCS at NOTP
- RCS boron concentration = 1003 ppm (BAST = 7100 ppm)
- Pressurizer level and Steam Generator levels at program
- Core burnup = 9000 MWD/MTU

#### Unit 1 Systems / Equipment Out Of Service

- ① Pressurizer level channel "461" due to a faulty transmitter. I&C preparing for containment entry to replace the transmitter.
- ② RHR "A" train out of service (72 hour LCO bearing replacement) scheduled to return to service 1600 August 5.

#### Meteorological Data:

- Wind Direction 90° (from)
- Wind Speed 2.3 mph
- Temperature 80°
- Stability Class B
- Precipitation 0" in the past 24 hours

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** PEO at Bank "D" control panel (Dropped Rod H-8)

**TIME:** 0810


**FROM:** PEO Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Use attached drawings to convey appropriate conditions.

**THIS IS A DRILL**



ROD CONTROL POWER CABINET

6040-2

IN-PLANT MESSAGE

**TO:** I&C Technician Team (Dropped Rod H-8),  
(Room B71 Control Building)

**TIME:** 0815

**FROM:** I&C Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Provide the following indications of a blown stationary gripper fuse.

Cabinet number 2BD; Fuse "27" pop out indicator is visible.

**CONTROLLER INFORMATION:**

Cabinet 2BD is located in Room B-71 of the Control Building.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** Chemistry Staff (Primary Lab - Control Building)

**TIME:** 0822

**FROM:** Chemistry/HP Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Personnel EDRD's are alarming and the Area Rad Monitor (ARE-0007B) is alarming.

**CONTROLLER INFORMATION:** Issue only when chemistry personnel approach sample area to collect chemistry sample.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Primary Lab Personnel (Control Building)

TIME: 0822

FROM: Chemistry Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The display reading for Sample Sink Area Radiation Monitor (ARE-0007B) is  $7.5E+2$  mr/hr.

**CONTROLLER INFORMATION:** Hang this message over the display window of monitor.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Simulator Crew

TIME: 0822

FROM: Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Gross Failed Fuel Detector (GFFD) chart is reading off-scale high. Meter is off-scale high on wide & narrow range. Low (flow) alarm light is off. High alarm light is on.

TOS Wide Range:  $1 \times 10^6$  cpm


TOS Narrow Range:  $1 \times 10^4$  cpm

**CONTROLLER INFORMATION:**

Issue to operator only when looking at GFFD meter.  
Use Attached Drawings.

**THIS IS A DRILL**

# GROSS FAIL FUEL DETECTOR



POWER	CHANNEL	LOW
ON	TEST	ALARM

## NEUTRON CHANNEL

OPERATION SELECTOR

RANGE SELECTOR

RMTE 3600  
CPM CAL

OPERATE

RESET

LEVEL CAL.

PULSE CAL.

WIDE

NARROW


HV



2A SLO BLOW



# GROSS FAIL FUEL DETECTOR



POWER ON	CHANNEL TEST	<input checked="" type="checkbox"/>	LOW ALARM
-------------	-----------------	-------------------------------------	--------------

## NEUTRON CHANNEL

OPERATION SELECTOR

RANGE SELECTOR

RMTE 3600  
CPM CAL

OPERATE

RESET


LEVEL CAL.

PULSE CAL.

WIDE

NARROW

HV



Ø 2A SLO BLOW Ø

IN-PLANT MESSAGE

TO: PEO or Maintenance Team

TIME: 0825+

FROM: HP Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

Do not allow simulated containment entry if team is ready prior to 9:30. After 9:30 containment conditions will not allow entry.

CONTINGENCY

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Primary Lab Chemistry Staff

TIME: 0835

FROM: Chemistry/HP Controller

**THIS IS A DRILL**

**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Chemistry must use PASS to obtain RCS sample.

**CONTROLLER INFORMATION:** Issue only if Operations does not request PASS sample from Chemistry.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Shift Superintendent

TIME: 0835+

FROM: Simulator Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

**MESSAGE:**

Declare an **ALERT** based on:

A breach or challenge of 1 of 3 fission product barriers.

CONTINGENCY

**CONTROLLER INFORMATION:**

Issue only on direction from Lead Controller.

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Shift Superintendent/Control Room  
Plant Page Communicator

**TIME:** 0835+

**FROM:** Simulator/Control Room Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

### MESSAGE:

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.
  - a. "ATTENTION ALL PERSONNEL - **THIS IS A DRILL** - AN ALERT HAS BEEN DECLARED FOR UNIT 1 DUE TO FUEL DAMAGE.
  - b. EMERGENCY RESPONSE PERSONNEL REPORT TO YOUR EMERGENCY RESPONSE FACILITY.
  - c. "PERSONNEL WORKING (ON/IN) \_\_\_\_\_ CALL CONTROL ROOM AT EXTENSION \_\_\_\_\_ AND CONTINUE WORK".
  - d. ALL OTHER PERSONNEL EXIT THE PROTECTED AREA AND REPORT TO THE ADMINISTRATION BUILDING. **THIS IS A DRILL**.
- II. Sound the alarm for an Alert - Warble Tone (15 seconds).
- III. Repeat the announcement from Step I.

**CONTROLLER INFORMATION:** Note that assembly and accountability will actually be performed.

Use this if ALERT is declared due to fission product barrier breach/challenge.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** Emergency Director

**TIME:** 0840+

**FROM:** Lead Controller

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

**MESSAGE:**

Use this script for **EARLY DISMISSAL** announcement:

**THIS IS A DRILL**

"ATTENTION ALL PERSONNEL. ATTENTION ALL PERSONNEL.  
THE EMERGENCY DIRECTOR HAS DIRECTED A SIMULATED  
EARLY DISMISSAL. TAKE NO EARLY DISMISSAL ACTION  
BECAUSE THIS IS A DRILL."

**(Repeat announcement)**

**CONTROLLER INFORMATION:** Early Dismissal can be ordered any time after declaration of Alert Emergency. Give this message to the ED if and when he decides Early Dismissal is appropriate.

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Shift Superintendent/Control Room  
Plant Page Communicator

**TIME:** 0845+

**FROM:** Simulator/Control Room Controller

**THIS IS A DRILL**

**DO NOT initiate actions affecting normal plant operations.**

### MESSAGE:

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.
  - a. "ATTENTION ALL PERSONNEL - **THIS IS A DRILL** - AN ALERT HAS BEEN DECLARED FOR UNIT 1 DUE TO FUEL DAMAGE.
  - b. EMERGENCY RESPONSE PERSONNEL REPORT TO YOUR EMERGENCY RESPONSE FACILITY.
  - c. "PERSONNEL WORKING (ON/IN) \_\_\_\_\_ CALL CONTROL ROOM AT EXTENSION \_\_\_\_\_ AND CONTINUE WORK".
  - d. ALL OTHER PERSONNEL EXIT THE PROTECTED AREA AND REPORT TO THE ADMINISTRATION BUILDING. **THIS IS A DRILL**.
- II. Sound the alarm for an Alert - Warble Tone (15 seconds).
- III. Repeat the announcement from Step I.

**CONTROLLER INFORMATION:** Second announcement during accountability.

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Shift Superintendent/Control Room  
Plant Page Communicator

**TIME:** 0855+

**FROM:** Simulator/Control Room Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.
  - a. "ATTENTION ALL PERSONNEL - **THIS IS A DRILL** - AN ALERT HAS BEEN DECLARED FOR UNIT 1 DUE TO FUEL DAMAGE.
  - b. EMERGENCY RESPONSE PERSONNEL REPORT TO YOUR EMERGENCY RESPONSE FACILITY.
  - c. "PERSONNEL WORKING (ON/IN) \_\_\_\_\_ CALL CONTROL ROOM AT EXTENSION \_\_\_\_\_ AND CONTINUE WORK".
  - d. ALL OTHER PERSONNEL EXIT THE PROTECTED AREA AND REPORT TO THE ADMINISTRATION BUILDING. **THIS IS A DRILL**.
- II. Sound the alarm for an Alert - Warble Tone (15 seconds).
- III. Repeat the announcement from Step I.

**CONTROLLER INFORMATION:** Third announcement during accountability.

**THIS IS A DRILL**



**IN-PLANT MESSAGE**

**TO:** OSC Repair Team (A-Train RHR Pump)

**TIME:** 0900+

**FROM:** OSC Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The new lower motor bearing was damaged during installation. The replacement should arrive by federal express today at 1600 hours.

**CONTROLLER INFORMATION:** This message should be issued to the team that was working on "A" train RHR pump motor replacement.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Simulator (Extension 4369)

TIME: 0905

FROM: Injured Individual  
(Medical Emergency Lead Controller)

**THIS IS A DRILL**

**DO NOT initiate actions affecting normal plant operations.**

**MESSAGE:**

"(This is a drill). I need help in the Administration Building Auditorium. \_\_\_\_\_ has fallen and is complaining of chest pains. (This is a drill)".

**CONTROLLER INFORMATION:** The injured individuals co-worker should telephone the above report into the Simulator (Extension 4369). Do not transmit any additional information.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Shift Superintendent

TIME: 0906+

FROM: Simulator/Control Room Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

Page 911 for first responders.

CONTINGENCY

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Control Room Page (Controller)

**TIME:** 0910

**FROM:** TSC Lead Controller

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

**MESSAGE:**

"All personnel who assembled in the Administration Building as part of the assembly/accountability return to your work stations".

**CONTROLLER INFORMATION:** Issue after assembly and accountability have been completed and not later than 1 hour after the start of assembly and accountability (declaration of Alert).

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Medical Emergency Response Team

**TIME:** 0915+

**FROM:** Medical Emergency Lead Controller

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

**MESSAGE:**

Upon arriving at the Admin. Building Auditorium you observe a man lying on the floor. He is conscious and agitated.

MEDICAL SYMPTOMS.

Conscious and complaining of chest pain, shortness of breath. Skin is pale and clammy. Patient clutching his chest. Patient has taken two nitroglycerin with no relief.

**CONTROLLER INFORMATION:** Simulator/Control Room telephone 4369

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Medical Emergency Response Team

**TIME:** 0915+

**FROM:** Observation (Medical Emergency Lead Controller)

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

	Pulse (beats per min)	Blood Pressure	Respirations (per minute)	Notes
when found	80	100/60	shallow	Labored breathing, chest pains
15 mins later	84	106/60	shallow	Irregular respirations, shortness of breath
30 mins later	84	100/60	shallow	same:

**CONTROLLER INFORMATION:** First responders should reassure the patient and keep patient calm. Other expected actions by the first responders are taking vital signs and packaging patient for transport.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** TSC Manager

**TIME:** 0915+

**FROM:** TSC Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Ambulance should simulate transport of injured person to Burke County Hospital.

**CONTROLLER INFORMATION:** Hand to TSC Manager only in the event he is unsure where ambulance should go. Ambulance will not actually arrive at the plant site nor transport patient to hospital.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: HP Supervisor in TSC

TIME: 0930

FROM: TSC Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

PERMS data no longer available on PERMS CRT.

CONTROLLER INFORMATION: Hang message over face of PERMS CRT.

**THIS IS A DRILL**



IN-PLANT MESSAGE

**TO:** HP Supervisor/HP Control Point

**TIME:** 0930

**FROM:** HP Control Point Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

PERMS data no longer available on PERMS CRT.

**CONTROLLER INFORMATION:** Hang message over face of PERMS CRT.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** PEO responder  
("B" Train RHR - Rm A-50 Control Building)

**TIME:** 0940+

**FROM:** PEO Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Describe scene to OSC repair team player.

**GREEN LIGHT ON**  
**RED LIGHT OFF**

If upper cubicle door is opened the red light resistor is charred.

**CONTROLLER INFORMATION:** Do not give upper cubicle information unless PEO opens door.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** OSC Repair Team  
("B" Train RHR - Rm A-50 Control Building)

**TIME:** 0940+

**FROM:** OSC Controller

**THIS IS A DRILL**

**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Describe scene to OSC Repair Team player.

**GREEN LIGHT ON  
RED LIGHT OFF**

If upper cubicle door is opened the red light resistor is charred.

**CONTROLLER INFORMATION:** Repair personnel could simulate pulling a resistor from any other equipment with a red indicating light which is not operating (example "A" Train RHR).

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Shift Superintendent

TIME: 0945+

FROM: Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

MESSAGE:

Declare a **SITE AREA EMERGENCY** based on:

A breach or challenge of 2 of 3 fission product barriers.

CONTINGENCY

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Shift Superintendent/Control Room  
Plant Page Communicator

**TIME:** 0945+

**FROM:** Simulator/Control Room Controller

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

### MESSAGE:

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.
  - a. "ATTENTION ALL PERSONNEL - **THIS IS A DRILL** - A SITE AREA EMERGENCY HAS BEEN DECLARED FOR UNIT 1 DUE TO A LARGE BREAK LOCA INSIDE CONTAINMENT/LOSS OF SECOND FISSION PRODUCT BARRIER."
  - b. EMERGENCY RESPONSE PERSONNEL CONTINUE TO WORK ON SIMULATED EMERGENCY DUTIES."
- II. Sound the alarm for a Site Area Emergency - Pulse Tone (15 seconds)
- III. Repeat the announcement from Step I.

**CONTROLLER INFORMATION:** Use this if a Site Area Emergency is declared due to product barriers breach/challenge.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Simulator Control Room (Ext. 4369)

**TIME:** 1045

**FROM:** Disgruntled Employee (Controller)

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

**"THIS IS A DRILL. THIS IS A DRILL.**

I have placed a bomb in the protected area and it will go off at about 1100 this morning and you can't do a thing about it. I'll teach you people not to treat me the way you do. **THIS IS A DRILL."**

**CONTROLLER INFORMATION:** Read this message and give **No** additional information.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Simulated Control Room

TIME: 1100

FROM: TSC/OSC CONTROLLERS

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

Make announcement to ALL players

"You have just now heard a loud thump.

**THIS IS A DRILL"**

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Control Room Fire Technician

**TIME:** 1100

**FROM:** Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The Fire Computer has reported: Fire Alarm Zone 141B

Fire Alarm LZIP 1S48

**THIS IS A DRILL**



IN-PLANT MESSAGE

**TO:** Simulator Control Room Operators  
that respond to Seismic Panel

**TIME:** 1100

**FROM:** Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The "EVENT INDICATOR" located at SM-3 Control Rack of Seismic Control Panel (ANCQSIP) is "ON" and alarming. (white flag is showing)

**CONTROLLER INFORMATION:**

Issue only after simulator personnel arrive at SMA-3 control rack of the seismic control panel.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: SAS/CAS Operators

TIME: 1100

FROM: Security Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

Door 1C108 has an Alarm.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Simulator Shift Superintendent

**TIME:** 1100

**FROM:** Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

ALL Seismic Equipment is working properly.

**CONTROLLER INFORMATION:** Issue if I&C is requested to inspect seismic equipment.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Security Officers at Unit 1 HVAC Containment  
Purge Supply Equipment Room

**TIME:** 1105+

**FROM:** Security Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Upon arriving at the scene you observe that there is steam filling the room from a broken pipe. (Rooms 114, 116, 125). The door has been torn from its hinges and there is **NO** fire or smoke present, only steam.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** Fire Protection Tech/PEO

**TIME:** 1110+

**FROM:** Security Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The door to rooms 114, 116, and 125 has been torn from its hinges. The HVAC outside air intake louvers have also been blown out and are damaged.

The containment HVAC piping before and up to HV-2627B is flared with jagged edges and is open to the environment and steam is coming out the pipe.

There are blast marks around the room.

**CONTROLLER INFORMATION:** If personnel go into containment HVAC equipment room they will be contaminated.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** OSC Repair Teams

**TIME:** 1110+

**FROM:** OSC Controller

**THIS IS A DRILL**  
**DO NOT initiate actions affecting normal plant operations.**

**MESSAGE:**

After completing inspection of Rooms 114, 116, and 125 you observed the following:

- Panel INB1702N door is open with charring inside.
- TV-12432C equipment bldg. HVAC outside air intake louvers are blown out.
- Some sections of the expand -o- flash around the outside of room is blown away.
- The containment HVAC piping coming out of PEN 83 up to valve HV-2627B is blown away. The end of the containment side of pipe is flared with jagged edges.

**CONTROLLER INFORMATION:** These team members should be decontaminated upon exit of rooms if not properly dressed out.

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Shift Superintendent

TIME: 1123+

FROM: Simulator Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

**MESSAGE:**

Upgrade to **GENERAL EMERGENCY** based on:

A breach or challenge of 3 of 3 fission product barriers.

CONTINGENCY

**THIS IS A DRILL**

## IN-PLANT MESSAGE

**TO:** Shift Superintendent/Control Room  
Plant Page Communicator

**TIME:** 1123+

**FROM:** Simulator/Control Room Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

### MESSAGE:

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.
  - a. "ATTENTION ALL PERSONNEL - **THIS IS A DRILL** - A GENERAL EMERGENCY HAS BEEN DECLARED FOR UNIT 1 DUE TO A BREACH OR CHALLENGE OF 3 OF 3 FISSION PRODUCT BARRIERS."
  - b. EMERGENCY RESPONSE PERSONNEL CONTINUE TO WORK ON SIMULATED EMERGENCY DUTIES."
- II. Sound the alarm for a General Emergency - Yelp Tone (15 seconds).
- III. Repeat the announcement from Step I.

**THIS IS A DRILL**



IN-PLANT MESSAGE

**TO:** Control Room Fire Technician

**TIME:** 1125+

**FROM:** Simulator Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

The fire computer has reported:

Electric fire Pump is running

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** PEO/OSC Teams

**TIME:** 1125+

**FROM:** Operations/OSC Controller

**THIS IS A DRILL**

**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Post Indicating Valve 1-2301-U4-391 (fire water to unit 1 turbine building) is leaking water at the point where the valve enters the ground. (approximately 25 gallons per minute)

**THIS IS A DRILL**

IN-PLANT MESSAGE

TO: Health Physics Decon Team

TIME: 1130+

FROM: Health Physics Controller

**THIS IS A DRILL**  
DO NOT initiate actions affecting normal plant operations.

MESSAGE:

Initial Contamination Survey Data:

Overall body - 50k cpm  
Face - Chin - 30k cpm

Decontamination Survey Data:

After 1st decontamination efforts:

Overall body - 10k cpm  
Face - 5k cpm

After 2nd decontamination efforts:

Overall body 2k cpm  
Face - <100 cpm

After 3rd decontamination efforts:

Overall body - <100 cpm

CONTROLLER INFORMATION:

These contamination levels are for all personnel that initially enter Rooms 114, 116 and 125 of the control building.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** Emergency Director, TSC Manager, OSC Manager

**TIME:** 1215+

**FROM:** EOF Controller, TSC Lead Controller, OSC Lead Controller

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

Time is advanced 48 hours.

Plant conditions have stabilized.

A RCS leak still exists but the core is covered and decay heat is being removed with RHR in hot leg recirc mode. Both trains of RHR are operational.

Plant Temperatures is 112°F.

The release of radioactivity from containment has stopped.

Containment is full of radioactive gas. RE-002/003 read 100 mrem/hr.

Make plans to enter Recovery and establish an Initial Recovery Organization.

**THIS IS A DRILL**

IN-PLANT MESSAGE

**TO:** All Players

**TIME:** 1300+

**FROM:** All Controllers

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

DRILL TERMINATED

All Players please complete critique forms and participate in critique process.

**CONTROLLER INFORMATION:** Issue only after approval of Lead Exercise Controller.

**THIS IS A DRILL**

**IN-PLANT MESSAGE**

**TO:** All Participants

**TIME:** 1300+

**FROM:** Control Room Plant Page Communicator

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

**MESSAGE:**

- I. Make this announcement after you receive call from Simulator Plant Page Communicator.

**"ATTENTION ALL PERSONNEL "**

**ALL DRILL ACTIVITIES ARE TERMINATED.**  
**ALL DRILL ACTIVITIES ARE TERMINATED"**

**CONTROLLER INFORMATION:** Simulated Control Room telephone 4369 or 4370.

**THIS IS A DRILL**

VOGTLE ELECTRIC GENERATING PLANT  
 RADIOCHEMISTRY ANALYSIS SYSTEM

NID QUALITY CONTROL REPORT

TITLE : Unit 1 RCS HOT LEG - LOOP 3 - DEGASSED LIQ  
 SAMPLE # : 2650-93 SAMPLE GEOMETRY : SCIN S0  
 SAMPLE TYPE : DEGASSED LIQ SAMPLE QUANTITY : 8.00000E+00  
 COUNT TIME : 04-Aug-1993 02:44:08.00 REACTOR UNIT # : 1  
 SAMPLE TIME : 04-Aug-1993 01:05:00.00 OPERATOR NAME : AROBERSON

ISOTOPE	PEAK ENERGY	ENERGY DIFF (KEV)	DECAY CORR UCI/ML	COMMENTS
F-18	511.00	-0.14	1.022E-01	* Peak FWHM Suspect
NA-24	1368.53	-0.15	3.347E-03	Nuclide QA Results OK
CL-38	1642.42	0.25	8.852E-04	* Count Rate Error >50%
CR-51	320.08	-0.27	2.438E-02	Nuclide QA Results OK
MN-54	834.83	-0.05	1.189E-02	Nuclide QA Results OK
MN-56	1810.69	-0.28	1.186E-03	Nuclide QA Results OK
CO-57	122.06	0.02	2.565E-04	Nuclide QA Results OK
CO-58	810.76	-0.05	8.562E-02	Nuclide QA Results OK
FE-59	1099.22	-0.11	3.775E-03	Nuclide QA Results OK
CO-60	1332.47	-0.09	5.775E-03	Nuclide QA Results OK
NB-95	765.79	-0.07	4.730E-03	Nuclide QA Results OK
ZR-95	756.72	-0.07	3.045E-03	Nuclide QA Results OK
NB-97	657.90	-0.36	1.198E-03	Nuclide QA Results OK
ZR-97	743.36	-0.12	3.844E-04	Nuclide QA Results OK
SN-113	391.69	-0.26	3.968E-04	Nuclide QA Results OK
I-133	529.87	-0.32	3.436E-04	Nuclide QA Results OK
CS-134	795.85	-0.07	1.080E-03	Nuclide QA Results OK
I-134	847.03	0.14	5.350E-03	Nuclide QA Results OK
I-135	1260.41	-0.03	8.149E-04	Nuclide QA Results OK
XE-135	249.79	-0.41	7.680E-05	* Peak FWHM Suspect
CS-137	661.65	-0.11	1.263E-03	* Count Rate Error >30%
CE-144	133.20	-0.37	1.814E-03	Nuclide QA Results OK
W-187	479.53	-0.21	5.167E-04	* Peak FWHM Suspect
				* Count Rate Error >30%
AVG ENERGY DIFF = -0.14				2.603E-01 = TOTAL GAMMA ACTIVITY

Dose Equivalent Iodine-131 = 1.060E-04

133.57 KeV Peak was used in identifying 2 isotopes  
 846.89 KeV Peak was used in identifying 2 isotopes  
 1038.70 KeV Peak was used in identifying 2 isotopes

UNIDENTIFIED PEAKS

ENERGY	NET AREA	FWHM	CTS/SEC	ERROR
61.10	612.	0.88	5.097E-01	45.84
172.23	795.	1.84	6.622E-01	34.64

REPORT NAME : QA CHECK  
REPORT DATE : 04-Aug-1993 01:41:51.94

PAGE : 1

VOGTLE ELECTRIC GENERATING PLANT  
RADIOCHEMISTRY ANALYSIS SYSTEM

NID QUALITY CONTROL REPORT

TITLE : Unit 1 RCS HOT LEG - LOOP 3 - DISSOLVED GAS  
SAMPLE # : 2648-93 SAMPLE GEOMETRY : 14GAS\_S0  
SAMPLE TYPE : DISSOLVED GAS SAMPLE QUANTITY : 2.00000E+00  
COUNT TIME : 04-Aug-1993 01:23:16.00 REACTOR UNIT # : 1  
SAMPLE TIME : 04-Aug-1993 01:05:00.00 OPERATOR NAME : AROBERSON

ISOTOPE	PEAK ENERGY	ENERGY DIFF (KEV)	DECAY CORR UCI/CC	COMMENTS
AR-41	1293.64	0.09	1.550E-02	Nuclide QA Results OK
KR-85M	151.18	0.01	1.141E-04	Nuclide QA Results OK
KR-87	402.58	0.26	2.883E-04	* Count Rate Error >30%
XE-135	249.79	-0.17	5.153E-04	Nuclide QA Results OK
XE-135M	526.56	-0.13	4.855E-04	Nuclide QA Results OK
XE-138	434.49	-0.17	1.856E-03	* Count Rate Error >30%
AVG ENERGY DIFF = -0.02				1.876E-02 = TOTAL GAMMA ACTIVITY

UNIDENTIFIED PEAKS

ENERGY	NET AREA	FWHM	CTS/SEC	ERROR
196.40	297.	1.52	2.966E-01	25.41
462.25	77.	1.77	7.727E-02	39.08
511.06	26825.	2.37	2.683E+01	0.70
810.93	39.	1.28	3.911E-02	51.15
889.67	28.	1.39	2.827E-02	50.58
1436.24	23.	2.08	2.283E-02	39.18

Total Unidentified Peaks = 6  
% Unidentified Peaks = 42.86

REVIEWED BY :

*[Signature]*

DATE :

8/4/93

APPROVED BY :

*[Signature]*

DATE :

8-4-93



REPORT NAME: QA CHECK  
REPORT DATE: 4-AUG-1993 10:20:57

VOGTLE ELECTRIC GENERATING PLANT  
RADIOCHEMISTRY ANALYSIS SYSTEM  
NID QUALITY REPORT

TITLE: UNIT # 1 PASS  
SAMPLE #: 2649-93  
SAMPLE TYPE: LIQUID  
OPERATOR: MARVIN MUDDLE

ISOTOPE	PEAK ENERGY	DECAY CORR UCI/CC
Kr-85m	151.18	2.28E0
Kr-87	402.58	2.42E+1
Kr-88	196.32	1.60E+2
Xe-131m	164.01	1.31E+1
Xe-133	81.00	2.3E+2
Xe-133m	233.14	8.5E+1
I-131	364.48	9.6E+1
I-132	667.69	1.4E+2
I-133	529.87	1.4E+2
I-135	1280.4	2.1E+2
Cs-134	795.85	1.15E-2
Te-132	230.0	1.17E-1
Ba-140	537.0	1.90E-1
Pr-144	695.1	1.5E-1

---

TOTAL GAMMA ACTIVITY 1.10E+3 uCi/cc

REVIEWED BY: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_

REPORT NAME: QA CHECK  
REPORT DATE: 4-AUG-1993 10:30:37

VOGTLE ELECTRIC GENERATING PLANT  
RADIOCHEMISTRY ANALYSIS SYSTEM  
NID QUALITY REPORT

TITLE: UNIT # 1 PASS  
SAMPLE #: 2650-93  
SAMPLE TYPE: CONTAINMENT ATMOSPHERE  
OPERATOR: MARVIN MUDDLE

ISOTOPE	PEAK ENERGY	DECAY CORR UCI/CC
Kr-85m	151.18	3.09E-4
Kr-87	402.58	8.80E-6
Kr-88	196.32	5.89E-5
Xe-131m	164.01	4.72E-6
Xe-135	81.00	8.40E-5
Xe-133m	233.14	3.09E-5
I-131	364.48	3.49E-5
I-132	667.69	5.16E-5
I-133	529.87	5.01E-5
I-135	1280.4	7.6E-5

---

TOTAL GAMMA ACTIVITY 7.08E-4 uCi/cc

REVIEWED BY: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_

## IN-PLANT HP SURVEY DATA

TABLE FHB A-1

TIME	0930	FOX
------	------	-----

AMBIENT RADIATION LEVELS mR/hr

AREA		
A-1	150	150
A-2	5	5
A-3	2.5	2.5
A-4	As Read	As Read

\* NOTE: 200 mR/hr VALUE IS AT THREE FT WITH LID OFF OF SAMPLE TRANSPORT PIG AS PASS PANEL. CONTACT DOSE ON SIDE OF SAMPLE TRANSPORT PIG IS 20 mR/hr. There is a reading of 2R/hr on contact.

AIRBORNE RADIOACTIVITY LEVELS

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"

LOOSE SURFACE CONTAMINATION LEVELS

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"




FIGURE FHB A-1

1993 NRC GRADED EXERCISE

August 4, 1993

**IN-PLANT HP SURVEY DATA**

<b>TIME</b>	0800	0931	1001	1031	1101	1201
	0930	1000	1030	1100	1200	FOX

**AMBIENT RADIATION LEVEL POINT OF RELEASE mR/hr**

**AREA**

A1	AS READ	150	150	150	1,500	150
A2	AS READ	20	20	20	1000	20
A3	AS READ	5	5	5	700	5
A4	AS READ	150	150	150	750	150
A5	AS READ	20	20	20	750	20
A6	AS READ	150	150	150	2000	150
A7	AS READ	150	150	150	150	150
A8	AS READ	AS READ	AS READ	AS READ	10	AS READ
A9	AS READ	AS READ	AS READ	AS READ	200	AS READ
A10	AS READ	AS READ	AS READ	AS READ	350	AS READ
A11	AS READ	AS READ	AS READ	AS READ	200	AS READ
A12	AS READ	AS READ	AS READ	AS READ	40	AS READ

August 4, 1993

## IN-PLANT HP SURVEY DATA

AIRBORNE RADIOACTIVITY LEVELS

## NOTE

LEVELS "AS READ" UNTIL 1100 HOURS

1100 - FOX

ISOTOPE	ACTIVITY
	$\mu\text{Ci/cc}$
Kr-85m	3.09E-3
Kr-87	8.8E-5
Kr-88	5.89E-4
Xe-131m	4.72E-4
Xe-133	8.4E-4
Xe-133m	3.1E-4
I-131	4.59E-7
I-132	5.16E-7
I-133	5.01E-8
I-135	7.6E-6
Co-58	6.2E-8
Cs-134	3.1E-7
Cs-137	4.7E-8

IN-PLANT HP SURVEY DATA

LOOSE SURFACE CONTAMINATION LEVELS

NOTE


LEVELS "AS READ" UNTIL 1100 HOURS

1100 - FOX

AREA

Rooms 114, 116, 125	200 mRAD/hr smearable
A10	5 mRAD/hr smearable
A9 & A11	AS READ
A8 & A12	AS READ

NORTH MAIN  
STEAM VALVE  
Room



A-8

A-9

A-10

A-11

A-12

LEVEL 1  
Unit 1



**IN-PLANT HP SURVEY DATA**

**LEVEL "A" UNIT 1**

<b>TIME</b>	<b>0800</b>	<b>0930</b>
		<b>FOX</b>

**AMBIENT RADIATION LEVELS mR/hr**

<b>AREA</b>		
A-1	AS READ	100
A-2	AS READ	5

---

**AIRBORNE RADIOACTIVITY LEVELS**

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"


**LOOSE SURFACE CONTAMINATION LEVELS**

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"

A<sub>1</sub> → 100 mR/h

A<sub>2</sub> → 5 mR/h


Dose increases as you  
get closer to ~~the~~ containment.  
Assume Inverse Square Law  
relationship.






A1 - 150 MR/L

A2 - 10 MR/L





~~A1~~  
A1 = 175 m<sup>2</sup>/h  
A2 = 10 m<sup>2</sup>/h



IN-PLANT HP SURVEY DATA

LEVEL "D" UNIT 1

TIME 0800 0930  
FOX

AMBIENT RADIATION LEVELS mR/hr

AREA	AS READ	
A-1	AS READ	175
A-2	AS READ	10

---

AIRBORNE RADIOACTIVITY LEVELS

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"

LOOSE SURFACE CONTAMINATION LEVELS

GENERAL AREAS "AS READ FOR THE DURATION OF THE EXERCISE"





1993 NRC GRADED EXERCISE

August 4, 1993

RADIATION MONITORS (STEAM GENERATORS)

$\mu\text{Ci}/\text{cm}^3$

RANGE    ALERT    ALARM    NORMAL    0800  
FOX

RE-019	STM GEN SAMPLE LIQ	7.2E-8	1.4E-2	9.0E-6	3.0E-5	9.0E-8	1.8E-7
RE-021	STM GEN BLOWDOWN LIQ	7.1E-9	7.1E-3	9.0E-6	1.8E-5	0.0E0	9.5E-7
RE-13120	STEM GEN 1 MAIN STM LINE	3.6E-3	1.1E+3	2.0E-1	3.0E-1	1.0E-1	7.2E-2
RE-13121	STEM GEN 2 MAIN STM LINE	3.6E-3	1.1E+3	2.0E-1	3.0E-1	1.0E-1	7.4E-2
RE-13122	STEM GEN 3 MAIN STM LINE	3.6E-3	1.1E+3	2.0E-1	3.0E-1	1.0E-1	9.5E-2
RE-13119	STEM GEN 4 MAIN STM LINE	3.6E-3	1.1E+3	2.0E-1	3.0E-1	1.0E-1	8.7E-2
RE-12839C	CNDSR AIR EJCTR/STM (L)	1.2E-8	3.5E-3	6.3E-4	7.9E-4	8.0E-8	4.5E-7
RE-12839D	CNDSR AIR EJCTR/STM (M)	1.4E-4	4.2E+1	1.0E0	3.0E0	8.0E-8	0.0
RE-12839E	CNDSR AIR EJCTR/STM (H)	3.2E-1	1.9E+4	5.0E+2	5.0E+2	8.0E-8	0.0

RANGE    ALERT    ALARM    NORMAL    0800    0820    0821  
0820    0821    FOX

RE-48000	CVCS LETDOWN	2.0E-4	4.0E+1	8.0E0	1.1E+1	4.0E0	4.0E0	TOS	TOS
----------	--------------	--------	--------	-------	--------	-------	-------	-----	-----

RCS

NC - NO CHANGE  
TOS - TOP OF SCALE

RADIATION MONITORS (AREA)

mR/hr

RANGE    ALERT    ALARM    NORMAL    0800    0820    0822    0930  
0820    0822    0930    FOX

RE-001	CONTROL ROOM	1.2E-2	1.2E+3	1.0E-1	2.5E-1	5.0E-2	5.0E-2	NC	NC	NC
RE-007B	SAMPLING ROOM	7.5E-3	7.5E+2	2.0E+1	4.0E+1	6.0E0	6.0E0	7.5E+2	1.0E+1	NC
RE-008	FUEL HANDLING BLDG	9.7E-3	9.7E+2	1.0E0	2.5E0	8.0E-2	2.3E-1	2.3E-1	NC	NC

NC - NO CHANGE

1993 NRC GRADED EXERCISE

August 4, 1993

RADIATION MONITORS (CONTAINMENT)

		RANGE		ALERT	ALARM	NORMAL	SOX	0930	1000	1100	1200
$\mu\text{Ci}/\text{cm}^3$								0930	1000	1100	1200
								FOX			
RE-2565A	CNMT VENT EFFL PART	2.1E-11	4.2E-6	2.4E-7	3.0E-7	0.0E0	1.9E-10	NC	NC	NC	NC
RE-2565B	CNMT VENT EFFL IODINE	1.7E-11	3.4E-6	1.0E-7	1.3E-7	0.0E0	2.9E-11	NC	NC	NC	NC
RE-2565C	CNMT VENT EFFL GAS	5.6E-8	1.1E-2	1.9E-4	2.4E-4	2.0E-7	2.2E-7	NC	NC	NC	NC
RE-2562A	CNMT ATM PART	9.1E-11	1.8E-5	2.1E-8	2.6E-8	2.0E-9	2.0E-9	NC	NC	NC	NC
RE-2562C	CNMT ATM GAS	6.2E-8	1.2E-2	8.8E-6	9.7E-6	4.0E-6	7.8E-7	NC	NC	NC	NC
		mR/hr									
RE-002	CNMT BLDG LOW RANGE	1.0E-2	1.0E+3	1.0E+2	7.6E+2	1.3E+1	1.3E+1	TOS	TOS	TOS	TOS
RE-003	CMNT BLDG LOW RANGE	1.0E-2	1.0E+3	1.0E+2	7.6E+2	1.3E+1	1.3E+1	TOS	TOS	TOS	TOS
RE-004	CNMT BLDG ACCESS HATCH	1.7E-2	1.7E+3	1.0E+1	1.5E+1	2.0E-1	2.0E	TOS	TOS	TOS	TOS
RE-005	CNMT BLDG HIGH RANGE	1.0E+3	1.6E+11	3.0E+3	1.0E+5	5.0E+1	5.0E+1	3.1E+6	3.8E+6	4.5E+6	2.0E+6
RE-006	CNMT BLDG HIGH RANGE	1.0E+3	1.8E+11	3.0E+3	1.0E+5	5.0E+1	5.0E+1	2.9E+6	3.3E+6	4.0E+6	2.1E+6
RE-011	CNMT BLDG INCORE INSTR	1.0E-1	1.0E+4	5.0E+1	1.0E+2	5.0E0	5.0E+0	TOS	TOS	TOS	TOS

TOS - TOP OF SCALE

1993 NRC GRADED EXERCISE

August 4, 1993

RADIATION MONITORS (GASEOUS)

$\mu\text{Ci}/\text{cm}^3$

RANGE ALERT ALARM NORMAL 0800  
FOX

RE-013	WASTE GAS PROC SYS	1.9E-1	3.7E+3	2.4E+2	2.4E+3	6.0E-1	BAD
RE-12442A	PLANT VENT PART	6.5E-11	1.3E-5	1.5E-6	1.9E-6	7.0E-10	4.6E-10
RE-12442B	PLANT VENT IODINE	1.7E-11	3.4E-6	6.7E-7	8.4E-7		1.8E-11
RE-12442C	PLANT VENT GAS	2.1E-7	4.1E-2	2.5E-4	3.1E-4	1.2E-7	5.8E-7
RE-12444C	PLANT VENT GAS	1.5E-7	9.2E-3	2.5E-4	3.1E-4	1.2E-7	2.4E-7
RE-12444D	PLANT VENT GAS	1.4E-4	4.2E+1	1.0E0	3.0E0	0.0E0	0.0E0
RE-12444E	PLANT VENT GAS	3.2E-1	1.9E+4	5.0E+2	5.0E+2	0.0E0	0.0E0
ARE-014	WASTE GAS PROC EFFL	3.7E-2	3.7E+3	1.1E0	1.4E0	1.0E-1	2.0E-2
RE-039A	WASTE GAS DECAY TK EFFL	2.7E-8	5.4E-3	1.0E-5	1.0E-4	6.0E-8	1.8E-7
RE-039B	WASTE GAS DECAY TK CMPSR VENT	1.8E-8	3.6E-3	1.0E-5	1.0E-4	1.0E-7	2.9E-8
RE-AUCT	FUEL HAND BLDG EFFL GAS	2.5E-9	2.5E-3	4.0E-7	6.0E-7	4.4E-8	4.8E-8
RE-024A	SELECTIVE CUBICLE PART	1.3E-11	1.3E-5	2.0E-8	3.0E-8	9.0E0	BAD
RE-024B	SELECTIVE CUBICLE GAS	5.9E-8	5.9E-2	1.9E-5	2.8E-5	0.0E0	BAD
RE-12116	CR AIR INTAKE GAS	4.8E-9	4.8E-3	7.2E-7	1.0E-6	0.0E0	0.0E0
RE-12117	CR AIR INTAKE GAS	4.8E-9	4.8E-3	8.0E-7	1.2E-6	0.0E0	0.0E0

NC - NO CHANGE  
TOS - TOP OF SCALE  
SOX - START OF EXERCISE  
FOX - FINISH OF EXERCISE

1993 NRC GRADED EXERCISE  
August 4, 1993

WEATHER FORECAST

TO: EOF Dose Assessment Staff

TIME: 1015+

FROM: EOF Controllers

**THIS IS A DRILL**  
**DO NOT** initiate actions affecting normal plant operations.

MESSAGE:

Bush Field Weather Report (forecast)

No rain forecasted. Temperatures ranging from middle 80's to middle 90's.

Partly cloudy. Winds from southeast up to 5 miles per hour.

CONTROLLER INFORMATION: Provide forecast only if players request information.

**1993 NRC GRADED EXERCISE**

August 4, 1993

**METEOROLOGICAL DATA (15 Minute Ave)**

	0800	0815	0830	0845	0900	0915	0930	0945	1000
PRI MET TWR 10M Wind Speed - mph	2.5	5.2	6.1	3.4	3.7	5.1	4.2	3.7	4.2
PRI MET TWR 10M Wind Dir.	90	81	85	96	76	91	70	78	90
PRI MET TWR 10M Ambient Temp - Deg. F	80°	81°	81°	82°	82°	84°	85°	85°	85°
PRI MET TWR 10M DEW PT Temp	74°	75°	75°	74°	75°	75°	76°	76°	76°
PRI MET TWR 10M Sigma Theta	22.0	20.6	21.2	19.3	17.5	16.9	19.0	20.1	20.8
PRI MET TWR 60M Wind Speed - mph	3.0	4.2	5.1	3.6	3.5	4.2	3.3	5.1	3.9
PRI MET TWR 60M Wind Dir.	110	101	105	116	64	67	79	70	80
PRI MET TWR 60M Precipitation	.4	.4	.4	.4	.4	.4	.4	.4	.4
PRI MET TWR 60-10M Delta Temp - Deg F	-1.6	-1.7	-1.6	-1.6	-1.4	-1.4	-1.5	-1.6	-1.6
SEC MET TWR 10M Wind Speed - mph	BAD								
SEC MET TWR 10M Wind Dir. - Deg.	BAD								
SEC MET TWR Ambient Temp - Deg F	BAD								
SEC MET TWR 10M Sigma Theta	BAD								
Stability Class	B	B	B	B	C	C	B	B	B

**1993 NRC GRADED EXERCISE**  
**August 4, 1993**

**METEOROLOGICAL DATA (15 Minute Ave)**

	1015	1030	1045	1100	1115	1130	1145	1200	1215
PRI MET TWR 10M Wind Speed - mph	3.5	3.0	4.1	4.3	3.1	2.9	3.4	3.6	3.3
PRI MET TWR 10M Wind Dir.	80	85	95	90	100	130	125	135	90
PRI MET TWR 10M Ambient Temp - Deg. F	86°	86°	86°	86°	87°	87°	87°	88°	88°
PRI MET TWR 10M DEW PT Temp	76°	76°	76°	76°	76°	76°	76°	76°	76°
PRI MET TWR 10M Sigma Theta	16.4	17.0	20.1	21	19.1	19.1	19.0	16.9	17.0
PRI MET TWR 60M Wind Speed - mph	3.0	2.7	3.1	4.2	4.0	3.5	4.2	4.5	4.0
PRI MET TWR 60M Wind Dir.	100	105	95	75	110	120	135	130	110
PRI MET TWR 60M Precipitation	.4	.4	.4	.4	.4	.4	.4	.4	.4
PRI MET TWR 60-10M Delta Temp - Deg F	-1.4	-1.5	-1.6	-1.6	-1.6	-1.6	-1.6	-1.4	-1.4
SEC MET TWR 10M Wind Speed - mph	BAD								
SEC MET TWR 10M Wind Dir. - Deg.	BAD								
SEC MET TWR Ambient Temp - Deg F	BAD								
SEC MET TWR 10M Sigma Theta	BAD								
Stability Class	C	C	B	B	B	B	B	C	C

**1993 NRC GRADED EXERCISE**

August 4, 1993

**METEOROLOGICAL DATA (15 Minute Ave)**

	1230	1245	1300	1315
PRI MET TWR 10M Wind Speed - mph	5.1	4.2	3.9	4.0
PRI MET TWR 10M Wind Dir.	79	80	92	90
PRI MET TWR 10M Ambient Temp - Deg. F	88°	88°	89°	89°
PRI MET TWR 10M DEW PT Temp	75°	75°	76°	76°
PRI MET TWR 10M Sigma Theta	18.3	18.4	18	18
PRI MET TWR 60M Wind Speed - mph	4.6	5.0	4.9	5.1
PRI MET TWR 60M Wind Dir.	90	100	101	100
PRI MET TWR 60M Precipitation	.4	.4	.4	.4
PRI MET TWR 60-10M Delta Temp - Deg F	-1.6	-1.6	-1.6	-1.6
SEC MET TWR 10M Wind Speed - mph	BAD			
SEC MET TWR 10M Wind Dir. - Deg.	BAD			
SEC MET TWR Ambient Temp - Deg F	BAD			
SEC MET TWR 10M Sigma Theta	BAD			
Stability Class	B	B	B	B

# DOWNWIND PLUME DATA

## WHOLE BODY DATA ALONG PLUME CENTERLINE

General Area Count Rate - cpm  
(Whole Body Dose Rate - mRem/hr)  
DOWNWIND DISTANCE (Miles)

	0.6	1	2	3	4	5	6	7	8	9	10
ETA	1110	1117	1134	1151	1208	1226	1243	1300	1317	1334	1351
cpm	340,000	340,000	23,800	17,000	6,800	13,600	10,200	10,200	6,800	3,400	3,400
mRem/hr	100	100	7	5	2	4	3	3	2	1	1
ETA	1125	1132	1149	1206	1224	1241	1258	1315	1332	1349	
cpm	408,000	374,000	34,000	17,000	10,200	10,200	10,200	13,600	6,800	3,400	
mRem/hr	120	110	10	5	3	3	3	4	2	1	
ETA	1140	1147	1204	1221	1239	1256	1313	1330	1347		
cpm	340,000	408,000	27,200	20,400	6,800	6,800	10,200	6,800	3,400		
mRem/hr	100	120	8	6	2	2	3	2	1		
ETA	1155	1204	1221	1238	1255	1312	1329	1346	1403		
cpm	374,000	374,000	34,000	17,000	10,200	10,200	6,800	6,800	3,400		
mRem/hr	110	110	10	5	3	3	2	2	1		
ETA	1210	1227	1234	1251	1308	1325	1342	1359	1416		
cpm	306,000	340,000	30,600	20,400	10,200	6,800	10,200	6,800	3,400		
mRem/hr	90	100	9	6	3	2	3	2	1		
ETA	1225	1242	1259	1316	1333	1350	1406				
cpm	0	0	0	0	0	0	0				
mRem/hr	0	0	0	0	0	0	0				

NOTES: background reading  
Use table values for map areas shaded BLUE.  
Use 0.10 times table values for map areas shaded YELLOW.  
Use 0.01 times table values for map areas shaded GREEN.  
Use 3,400 cpm/1mR to determine cpm's.  
Use the sample readings for waist and 2-inch readings.

For "closed window" readings use the above values.  
For "open window" readings use 3.00 times the table values.



# DOWNWIND PLUME DATA

## PARTICULATE & SILVER ZEOLITE DATA ALONG PLUME CENTERLINE

DOWNWIND DISTANCE (Miles)


	0.6	1	2	3	4	5	6	7	8	9	10
ETA	1110	1117	1134	1151	1208	1226	1243	1300	1317	1334	1351
part.	0	0	0	0	0	0	0	0	0	0	0
AgZ ncpm	950	100	50	30	10	35	30	20	10	5	5
ETA	1125	1132	1149	1206	1224	1241	1258	1315	1332	1349	
part.	0	0	0	0	0	0	0	0	0	0	
AgZ ncpm	1045	980	95	30	20	20	20	35	10	5	
ETA	1140	1147	1204	1221	1239	1256	1313	1330	1347		
part.	0	0	0	0	0	0	0	0	0		
AgZ ncpm	950	1045	63	40	10	10	20	10	5		
ETA	1155	1204	1221	1238	1255	1312	1329	1346	1403		
part.	0	0	0	0	0	0	0	0	0		
AgZ ncpm	980	980	95	30	20	20	10	10	5		
ETA	1210	1227	1234	1251	1308	1325	1342	1359	1416		
part.	0	0	0	0	0	0	0	0	0		
AgZ ncpm	825	940	84	40	20	10	20	10	5		
ETA	1225	1242	1259	1316	1333	1350	1406				
part.	0	0	0	0	0	0	0				
AgZ ncpm	0	0	0	0	0	0	0				

NOTES: Use 0.10 times table values for map areas shaded YELLOW.  
Use 0.01 times table values for map areas shaded GREEN.



RECREATION AREA  
RELOCATION CENTER

TO RECREATION  
RELOCATION CENTER  
(SEE DETAIL I)




ANSTEC  
 APERTURE  
 CARD

Also Available on  
 Aperture Card

9406060042.01







23

56

F-10

56

80

E-5

G-10

9406060042-02