LICENSEE EVENT REPORT

LICENSEE EVENT REPORT
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 N C B E P 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 6 15 CAT 58
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 O 2 During plant operation, performance of the suppression pool level indicators operabil—
[0]3 lity test, PT-08.1.6, revealed that indicator/recorder, 2-CAC-LR-2602, showed a level
o[4] of -26.4" while redundant indicators, 2-CAC-LI-2602-1 and 3, along with the local
[0]5 [level indicator, showed a level of -28.3". This event did not affect the health and
0 6 safety of the public.
07
Technical Specifications 3.3.5.3, 6.9.1.9b
SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
LER/RO REPORT 8 3 3 1 24 26 27 28 29 30 31 32 31 31
A loss of trickle flow to the wet reference leg of the LR-2602 instrument transmitter,
LT-2602, Model No. BQ15521, caused an incorrect input signal to the LR-2602 instrument
Trickle flow to the LR-2602 was reestablished, properly adjusted, LR-2602 was returned
1 3 to service, and the PT was satisfactorily completed. Plant modifications will be
installed on both units to eliminate the reference leg trickle flow requirement of The second of these instruments. The second of these instruments.
FACILITY STATUS SPOWER OTHER STATUS (30) METHOD OF DISCOVERY DESCRIPTION (32) NA B (31) Periodic Test
7 8 9 10 12 13 44 45 46 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA NA LOCATION OF RELEASE (36)
7 8 9 10 11 44 45 80 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7 0 0 0 37 Z 38 NA
PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA NA 80
LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA NA
7 8 9 10 PUBLICITY ISSUED DESCRIPTION (45) PDR ADDCK 05000324 S PDR NAME OF PREPARED M. J. Pastva, Jr. PHONE: 919-457-9521