	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	N J S G S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 CAT 58
CON'T 0 1 7 8	REPORT LG 0 5 0 0 0 2 7 2 7 0 2 1 0 8 3 8 0 3 1 0 8 3 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  On February 10, 1983, during routine surveillance testing of No. 1A Diesel Generator
0 3	a Jacket Water High Temperature alarm was received. The diesel was immediately tripped;
0 4	it was noted that the jacket water cooler service water outlet valve was not sufficiently
05	open. The diesel was declared inoperable and Action Statement 3.8.1.1a was entered.
0 [6]	Investigation revealed no apparent problem; the diesel was satisfactorily tested and the
0 7	action statement was terminated. Later investigation showed an isolated malfunction of
0 8	the outlet valve may have occurred. Redundant A.C. sources were demonstrated operable.
0 9 7 8	SYSTEM CAUSE SUBCODE S
	LEH RO EVENT YEAR REPORT NO.  O 1 5 27 26 29 30 31 32 32 32 34 26 27 28 29 30 31 32 32 32 34 34 34 39 2 20 20 20 36 37 37 40 40 41 23 42 43 42 43 43 44 47 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0	The valve malfunction evidently resulted from a missing handwheel on the flow trans-
11	mitter high side isolation valve. The valve is a diaphragm type; the missing
1 2	handwheel apparently resulted in the valve being in an intermediate, unrestrained
1 3	position and causing sensing line pressure fluctuations. The handwheel was replaced
1 4	and the valve was opened. (82-053, 82-012, 82-003, 81-053, 81-018)
1 5 7 8	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  C 28 0 0 0 0 29 N/A B 31 Surveillance Testing
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35  Z 33 Z 34 N/A  PERSONNEL EXPOSURES  AMOUNT OF ACTIVITY 35  N/A  44  45
1 7 7 8	NUMBER TYPE DESCRIPTION 39  O O O O O O O O O O O O O O O O O O O
1 8 7 8	NUMBER DESCRIPTION (41)  N/A  9 LOSS OF OR DAMAGE TO FACILITY (43)
1 9 7 8	Z   42   N/A   8303180420 830311   80   80   80   80   80   80   80
2 0	SSUED DESCRIPTION (45)  N/A  PDR  NHC USE ONLY  NA  NHC USE ONLY
	R. Frahm PHONE: 909/935-6000 Ext. 3078 0