LICENSEE EVENT REPORT

7	CONTROL BLOCK: [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N J S G S 2 2 0 0 - 0 0 0 0 0 0 0 0 4 1 1 1 1 1 1 0 0 57 CAT 58 5.
0 1 7 8	REPORT L 6 0 5 0 0 0 3 1 1 0 0 8 1 6 8 2 8 0 9 0 3 8 2 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
0 2	On August 16, 1982, two occurrences of malfunction of No. 24 Reactor Coolant Channel
0 3	Flow Indication were experienced. The first was at 1240 hours. The channel was
0 4	declared inoperable and Action Statement 3.3.1 Action 7 was entered at 1245 hours.
0 5	The isolation amplifier was replaced and tested satisfactorily. The channel was de-
0 6	clared operable and Action Statement 3.3.1 Action 7 was terminated at 1407 hours.
37	The second occurrence was at 2330 hours. Action Statement 3.3.1 Action 7 was entered
0 8	at 2330 hours. The isolation amplifier was replaced and tested satisfactorily, and 9 Action Statement 3.3.1 Action 7 was terminated at 0005 hours. August 17, 1982. SYSTEM CAUSE CAUSE CAUSE VALVE 80
0 9	CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
	TO REPORT NUMBER 21 22 23 24 25 21 20 20 20 20 20 20 20 20 20 20 20 20 20
	ACTION FUTURE OF FECT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. SUPPLIER H O 2 1 26 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
1 0	Both occurrences were attributed to failure of the signal isolation amplifiers. This
11	caused inaccurate signals to be sent to the channel flow meter. The amplifiers were
1 2	replaced and tested satisfactorily. No common cause for signal isolation amplifier
1 3	failure could be determined.
1 4	
1 5	ACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 0 8 2 29 NA A 31 Operational Event
	LEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
1 6	Z (33) Z (34) NA NA NA
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 O O O O O O NA
8	PERSONNEL INJURIES NUMBER DESCRIPTION 41
1 8	0 0 0 0 0 NA 9 11 12 80
1 9	LOSS OF OR DAMAGE TO FACILITY 43
8	PUBLICITY PUBLICITY PDR ADOCK 05000311
2 0	SSUED DESCRIPTION 45 PDR NRC USE ONLY
	NAME OF PREPARER R. Heller PHONE: 609/935-6000 Ext. 3078
	THUNE .