

DMB



**INDIANA & MICHIGAN ELECTRIC COMPANY**

DONALD C. COOK NUCLEAR PLANT  
P.O. Box 458, Bridgman, Michigan 49106  
(616) 465-5901

September 13, 1982

Mr. J.G. Keppler, Regional Administrator  
United States Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Operating License DPR-58  
Docket No. 50-315

Dear Mr. Keppler:

This is to confirm our telephone report utilizing the Emergency Notification System at 1954 hours on September 10, 1982, and subsequent notification made at 2010 hours to your onsite inspector, Mr. N.E. DuBry. At 2003 hours a followup call was made informing the Duty Officer that the event previously reported should have been classified an unusual event during the time period of 1900 to 1946 hours. The purpose of this call was to inform the Nuclear Regulatory Commission that the required surveillance testing following the installation of a Design Change on the 2 Control Room pressurization fans for Unit 1 of the Donald C. Cook Nuclear Plant had not been performed. This made the fans inoperable per the requirements of Technical Specification Section 3/4.7.5.1.

Discovery of this situation was made at 1900 hours on September 10, 1982. The Reactor Coolant System had entered Mode 4 at 0516 on September 10, 1982. The Control Room Pressurization System was available for service with the fan control switches in automatic. Upon discovery, the pressurization fans were immediately retested utilizing approved plant procedures. The first fan was declared operable at 1946 hours and the second fan was declared operable at 2008 hours. During the conduct of this test no problems were encountered.

As required by Technical Specification Section 6.9.1.8, a followup report providing a complete explanation of the


8209220326 820913  
PDR ADOCK 05000315  
S PDR

SEP 16 1982 1E22

Mr. J.G. Keppler  
September 13, 1982  
Page 2 of 2

circumstances surrounding this event and the corrective action taken to prevent recurrence, will be submitted no later than September 24, 1982.

Sincerely,

  
W.G. Smith, Jr.  
Plant Manager

/bab

cc: John E. Dolan  
R.S. Hunter  
M.P. Alexich  
R.F. Kroeger  
K.J. Vehstedt  
E.R. Swanson/N.E. DuBry RO:III  
R.C. Callen MPSC  
G. Charnoff, Esq.  
J.M. Hennigan  
R.O. Bruggee  
INPO  
PNSRC  
J.F. Stietzel  
E.L. Townley  
Dir., IE (40 copies)  
Dir., MIPC (4 copies)