



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 16, 1983

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
79th Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

Reportable Occurrence Report #83-014/03L-0 Docket #050-373 is being submitted to your office in accordance with LaSalle County Nuclear Power Station Technical Specification 6.6.B.2.(a). Reactor protection system or engineered safety feature instrument settings which are found to be less conservative than those established by the technical specifications but which do not prevent the fulfillment of the functional requirements of affected systems.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/GW/rg

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC Document Management Branch
Inpo-Records Center
File/NRC

8303220107 830316
PDR ADOCK 05000373
S PDR

MAR 17 1983

LE 22