PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-V-83-14

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

Date: 3/17/83

- it would

	Licensee Emergency Classification:		
San Unofre Nuclear Generating Station Unit 1	Notification of Unusual Event		
Docket No. 50-206 -	Alert		
NOTIFICATION OF SIGNIFICANT EVENT - INADVERTED LOSS OF INSTRUMENT AIR TO THE SALTWATER COOLING SYSTEM	Site Area Emergency		
	General Emergency		
	<u>x</u> Not Applicable		
	Southern California Edison Company San Onofre Nuclear Generating Station Unit 1 San Clemente, California Docket No. 50-206 NOTIFICATION OF SIGNIFICANT EVENT - INADVERTEN LOSS OF INSTRUMENT AIR TO THE SALTWATER		

At about 4:10 p.m. on 3/16/83, the licensee notified the IE:HQ Duty Officer, by the ENS, and the Senior Resident Inspector of the following event, pursuant to 10CFR50.72.

At 2:30 p.m. PDT on 3/16/83 a construction worker drilling holes in the circulating water intake structure accidently drilled through an instrument air line which supplied instrument air to operate the two sale water cooling pumps discharge valves. The rupture of this line made it impossible to open the closed north salt water cooling pump discharge valve. The south salt water cooling pump was running at the time and it's discharge valve remained open following loss of instrument air. The ability to operate this valve was considered to be uncertain. Since the salt water cooling system is the ultimate heat sink for the plant, the licensee declared a significant event at 4 p.m. because of the apparent potential for the total loss of this system if the running south pump failed. At 11:15 p.m. temporary repairs to the ruptured line were made and at 11:45 p.m. the north pump discharge valve was opened and the north pump started. The licensee intends to maintain both pumps operating until permanent repair of the lines is completed. The plant has been in mode 5 since February 1982.

This preliminary notification is for information only.

Media interest is not expected. Neither the licensee nor the NRC plans to issue a news release. Region V (San Francisco) received notification of this occurrence from the Senior Resident Inspector at about 4:30 p.m. on 3/16/83. This information is current as of 8:45 a.m. on 3/17/83.

CONTACT: D. F. Kirsch 463-3723

8303220111 830317 PDR I&E PND-V-83-014 PDR

DISTRIBUTION:

UISTRIBUIZON.	1	/	1	./	V	
H St. 11:03	MNBB 10.50	Phillips noo	E/W 11:01	Willste 11:02Air	Rights 11:04	Mail:
Chairman Palladino	EDO (m)		IE	NMSS		ADM: DMB
Comm. Gilinsky	PA		OIA	RES		DOT: Trans
Comm. Ahearne	MPA		AEOD			Only
Comm. Roberts	ELD	11	11		TE34	
Comm. Asselstine		Regions: エロ			2001	
SECY		INPO 11:02 NSA	C 11:01			
ACRS		Licensee: 11:	.00 V			
CA		(Reactor Lice	nsees)			V: FORM 211
PDR		Resident Insp	ector 11:10		(revis	ed 3/14/83)
						and the second se