

SEP 9 1982

Docket No.: 50-322

Mr. M. S. Pollock
Vice President - Nuclear
Long Island Lighting Company
175 East Old Country Road
Hicksville, New York 11807

Dear Mr. Pollock:

Subject: NRC Staff Position on Procedures for Suppression Pool Pumpback System (SER Open Item No. 39) - Shoreham Nuclear Power Station

The Shoreham design does not use watertight rooms to provide flood protection for the ECCS pumps as do other BWRs. In the Shoreham design, the ECCS pumps are located in one large annular area surrounding the suppression pool enclosure in the reactor building basement (elevation 8-0). Your position is that this annular area has sufficient volume to prevent flooding of ECCS equipment prior to detection and isolation of the source of leakage. The method of locating the leak (inside the Reactor Building) in the long-term post-LOCA period involves isolating ECC systems (trial-and-error basis) and monitoring the level change in the suppression pool or reactor building flood drain sump.

In response to staff comments on this method, you installed a manually actuated "pumpback" system which can pump water from the reactor building basement floor drain sump to the suppression pool. The system is to minimize the possibility of flooding and reduce loss of inventory from the suppression pool.

By letter SNRC-473 dated May 2, 1980, you submitted a detailed design and operating philosophy of the suppression pool leakage return system. In your response (212.107) identification and isolation procedures of ECCS were given for the long-term post-LOCA period. Based on the above information submitted by you, the staff approved the system design and operating philosophy. We perceived that LILCO would incorporate the detailed identification and isolation procedures into plant operating procedures for use by the operator. Neither the operating procedure SP.23.702.04 Rev. 0 nor the alarm response procedures submitted on letter SNRC-696 dated April 30, 1982 includes the identification and isolation procedures given earlier to the staff.

The detailed operating procedures are also a useful tool in the operator training program. During the long-term post-LOCA period, the reactor conditions are stabilized and the operator will have the flexibility of initiating the selective identification and isolation of ECCS procedures to detect and isolate the leak.

B209240444 B20909
PDR ADOCK 05000322
E PDR

OFFICE
SURNAME
DATE

It is the staff's position that you include the identification and isolation of ECCS procedures given in your May 2, 1980 response (212.107) into plant procedures so that the operator will know the actions to be taken during the post-LOCA period.

Additionally, with regard to internal flooding in the elevation 8-0 areas as a result of the limiting moderate energy pipe break (Residual Heat Removal System), plant procedures should address leak detection and isolation methodology to ensure that operator action can be successfully completed within the 30 minute period described in FSAR Appendix 3C Section 3C.5.4.4. You should demonstrate that these procedures will also be adequate to detect and isolate leaks of lesser magnitude than the limiting moderate energy pipe leak. You also should demonstrate that access to equipment on elevation 8-0 will be available as necessary to detect and isolate leaks considering the accumulation of potentially radioactive and/or thermally hot water on this elevation and that the accumulation of water could submerge the leak.

As a result of water migration to elevation 8-0 due to moderate energy line breaks from elevations 175-0 through 40-0, it is requested that you address indirect equipment wetting and equipment qualification resulting from water flow and impingement through the staircase or other floor penetrations. Leak detection and isolation procedures should be verified effective within the time frame assumed in Appendix 3C of the FSAR as a part of the preoperational program.

Please inform the staff within seven days of receipt of this letter as to the schedule of your response to these items.

If you have any questions on this matter, please contact Mr. Ed Weinkam at (301) 492-8430 or myself.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page

DISTRIBUTION:

Document Control	EWeinkam/RGilbert	JKennedy
NRC PDR	BBordenick/DRepka, OELD	
L PDR	I&E	
NSIC	ACRS (16)	
PRC	Region I	
LB#2 R/F	ESylvester	
EHylton	GThomas	

OFFICE	LB#2:DL	LB#2:DL				
SURNAME	EWeinkam:kab	ASchwencer				
DATE	9/9/82	9/8/82				

Shoreham

Mr. M. S. Pollock
Vice President - Nuclear
Long Island Lighting Company
175 East Old Country Road
Hicksville, New York 11801

cc: Howard L. Blau, Esquire
Blau and Cohn, PC.
217 Newbridge Road
Hicksville, New York 11801

Mr. Jay Dunkleberger
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Energy Research Group, Inc.
400-1 Totten Pond Road
Waltham, Massachusetts 02154

Mr. Jeff Smith
Shoreham Nuclear Power Station
Post Office Box 618
Wading River, New York 11792

W. Taylor Reveley, III, Esquire
Hunton & Williams
Post Office Box 1535
Richmond, Virginia 23212

Ralph Shapiro, Esquire
Cammer & Shapiro
9 East 40th Street
New York, New York 10016

Mr. Brian McCaffrey
Long Island Lighting Company
175 E. Old Country Road
Hicksville, New York 11801

Honorable Peter Cohalan
Suffolk County Executive
County Executive/Legislative Bldg.
Veteran's Memorial Highway
Hauppauge, New York 11788

David Gilmartin, Esquire
Suffolk County Attorney
County Executive/Legislative Bldg.
Veteran's Memorial Highway
Hauppauge, New York 11788

MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, California 95125

Stephen Latham, Esquire
Twomey, Latham & Shea
Post Office Box 398
33 West Second Street
Riverhead, New York 11901

Matthew J. Kelly, Esquire
Staff Counsel
New York State Public Service Commission
Three Rockefeller Plaza
Albany, New York 12223

Ezra I. Bialik, Esquire
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Shoreham NPS, U.S. NRC
Post Office Box B
Rocky Point, New York 11778

Herbert H. Brown, Esquire
Kirkpatrick, Lockhart, Hill,
Christopher & Phillips
1900 M Street, N.W.
Washington, D.C. 20036

Lawrence Coe Lanpher, Esquire
Kirkpatrick, Lockhart, Hill,
Christopher & Phillips
1900 M Street, N.W.
Washington, D.C. 20036

Karla J. Letsche, Esquire
Kirkpatrick, Lockhart, Hill,
Christopher & Phillips
1900 M Street, N.W.
Washington, D.C. 20036