

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

March 18, 1983

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

On March 7, 1983, we had a telephone conversation with Carl Stahle of your staff and Don Brinkman, NRC, to discuss the acceptance criteria for the surveillance requirement for the Emergency Gas Treatment System (EGTS) charcoal filters. The NRC agreed that for our Sequoyah Nuclear Plant units 1 and 2, the acceptance criteria for surveillance requirement for the charcoal filters (TS 4.6.1.8) defined by Table 2 of Regulatory Guide 1.52, Revision 2, is less than 1-percent methyl iodine penetration at a relative humidity of 70 percent per test 5.b.

If you have any questions, please get in touch with Jerry Wills at FTS 858-2685.

Very truly yours

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 18th day of Mar 1983

Raymond M. Lowery
Notary Public

My Commission Expires 4/8/86

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Boal

8303220156 830318
PDR ADOCK 05000327
P PDR