

TABLE 4.3-1 (Continued)

## REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
13. Steam Generator Water Level--Low-Low	S	R	Q	1, 2
14. Deleted	_____	_____	_____	_____
15. Undervoltage - Reactor Coolant Pumps	N.A.	R	Q	1
16. Underfrequency - Reactor Coolant Pumps	N.A.	R	Q	1
17. Turbine Trip				
A. Low Auto Stop Oil Pressure	N.A.	R	S/U(9) (10)	N.A.
B. Turbine Throttle Valve Closure	N.A.	R	S/U(9) (10)	N.A.
18. Safety Injection Input from ESF	N.A.	N.A.	R(4)	1, 2
19. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.	R	1
20. Reactor Trip System Interlocks	N.A.	R	S/U(8)	1
21. Reactor Trip Breaker	N.A.	N.A.	M(5) (14) (15), S/U(1) (14) (15)	1, 2, 3*, 4*, 5*
22. Automatic Trip Logic	N.A.	N.A.	M(5)	1, 2, 3*, 4*, 5*
23. Reactor Trip Bypass Breaker	N.A.	N.A.	(13), R(11)	1, 2, 3*, 4*, 5*

FARLEY-UNIT 1

9406080021 940603  
PDR ADDCK 05000348  
PDR

3/4 3-13

AMENDMENT NO.