



Donald A. Wells
Manager-Quality Assurance
(313) 237-9657

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

February 22, 1983
EF2 - 61,961

Mr. J. A. Hind
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Hind:

Reference: Enrico Fermi Atomic Power Plant, Unit 2
NRC Docket No. 50-341

Subject: Region III Inspection Report No. 50-341
(82-21) (DEPOS), January 21, 1983

The response to each item in the referenced Inspection Report is delineated below:

2. Licensee Actions

- a. Open Item (50-341/78-06-01 - Terrestrial Monitoring Program

All reports associated with this program will be available in final form within three months of the date of this letter.

- b. Open Item (50-341/80-07-01; 82-04-01) - QA Audits

Attached is a copy of a letter, EF2-61,237, December 29, 1982 closing the June 1979 audit and a copy of the QA audit of the NUS facilities in December 20-22, 1982.

- e. Open Item (50-341/82-04-02) - REMP procedures, NUS Laboratory

Controlled copies of the NUS work instructions used in their Pittsburgh laboratory were received in November, 1982. These work instructions will be entered into the Edison approval schedule according to draft Technical Specification, Section 6, Administrative Controls.

FEB 28 1983

f. Open Item (50-341/82-04-04) - FSAR Section 11.6

Since the information contained in FSAR Section 11.6 is covered in the appropriate Standard Technical Specifications in Chapter 16 and the ODCM, both of which are in draft form and submitted to the NRC Staff, it is no longer appropriate to incorporate it in Section 11.6. Therefore, it is Detroit Edison's intention to delete Section 11.6 in its entirety.

The exact sample locations for the program are in Tables 3.0-1 and 3.0-2 of the draft Offsite Dose Calculational Manual (ODCM) as stated in the draft Technical Specifications. The draft ODCM was submitted to the NRC Staff late December 1982. Tables 3.0-1 and 3.0-2 of the ODCM are attached for your information.

g. Open Item 50-341/82-04-05) - Quarterly REMP reports

Under the preoperational REMP there is no requirement for quarterly reports. These are presently generated as contract requirements between Edison and NUS. As of 1983, the reporting requirements for the contractor will be those listed in the draft Technical Specifications under Section 6.9.1.10, and will no longer include quarterly reports.

A copy of the 1982 Annual Report will be forwarded to Region III when it is received from NUS.

h. Open Item (50-341/82-04-06) - Management Controls

Management controls and procedures are being initiated and will be in place by April 1, 1983.


j. Open Item (50-341/82-04-09) - Field Sample Collection Forms

A new multipart form and procedure has been developed by NUS for field sample collection data. This procedure and form becomes effective March 1, 1983. One part of the form is mailed to the Environmental Engineer at the Fermi 2 site subsequent to collection.

Mr. J. A. Hind
February 22, 1983
EF2 - 61961
Page 3

Should you have any questions regarding the above,
please contact Mr. George Trahey, (313) 586-5036.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'DAW', written in a cursive style.

DAW/EFM/jl

cc: Mr. Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Bruce Little, Senior Resident Inspector
U. S. Nuclear Regulatory Commission
7450 North Dixie Highway
Newport, Michigan 48166