

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company

San Onofre Units 2 and 3

Dockets No: 50-361
50-362

Licenses No: NPF-10
NPF-15

During an NRC inspection conducted on March 8 through April 18, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

- A. 10 CFR Part 50, Appendix B, Criterion XVI, "Corrective Actions," states that: "Measures shall be established to assure that conditions adverse to quality . . . are promptly identified and corrected. In the case of significant conditions adverse to quality, the measures shall assure that the cause of the condition is determined and corrective action taken to preclude repetition"
1. Contrary to the above, the licensee failed to implement the corrective actions identified in Operations Division Evaluation Report 3-92-07A which were intended to preclude repetition of a February 8, 1992, event. Specifically, the licensee failed to revise Station Procedure 5023-1-4.2 to incorporate guidance to prevent pressurizing the containment building in the event that the containment purge system could not be started. The failure to effectively implement this corrective action resulted in a similar event on October 22, 1993, in which a containment pressure increase caused the refueling cavity water level to decrease below the Technical Specification limit.
 2. Contrary to the above, in March 1992, the licensee failed to determine the cause of an abnormal motor-operated valve diagnostic test result for Valve 3HV6371, a significant condition adverse to quality, and failed to take timely corrective action. The abnormal test was later shown to be indicative of a misassembled valve. Subsequently, the valve failed to stroke in January 1993 due to having been misassembled prior to 1992.

This is a Severity Level IV violation (Supplement I) (362/9408-1).

Dated at Arlington, Texas,
this *1st* day of *June* 1994

9406080071 940601
PDR ADOCK 05000361
Q PDR