



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 57
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated June 11, 1982, as supplemented June 16 and August 18, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 57, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 7, 1982

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 57 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Page

3/4 1-21

Insert Page

3/4 1-21

REACTIVITY CONTROL SYSTEM

POSITION INDICATION SYSTEM-SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.3.3 One analog rod position indication channel per rod and the associated group step demand counter shall be OPERABLE* for each shutdown or control rod not fully inserted.

APPLICABILITY: MODES 3**, 4**, and 5**

ACTION:

With less than the above required position indicator(s) OPERABLE, immediately insert all rods or, immediately open the reactor trip system breakers.

SURVEILLANCE REQUIREMENTS

4.1.3.3 Each of the above required position indicator(s) shall be determined to be OPERABLE by performance of Specifications 4.1.3.2.1 and 4.1.3.2.2*.

*During maintenance or surveillance actions on the analog indicators in Modes 3,4, or 5, it may not be feasible to have an OPERABLE analog position indicator for each rod not fully inserted. In addition, due to known temperature affects below 547°F, the analog position indicators may not be able to perform within 12-step accuracy required above 547°F. These two situations are acceptable provided that each affected rod is assumed to be fully withdrawn, for the purposes of k_{eff} calculations and minimum boron concentration calculations.

**With the reactor trip system breakers in the closed position.