

June 2, 1994

Mr. Patrick M. Donnelly, Plant Manager
Big Rock Point Plant
Consumers Power Company
10269 U.S. 31 North
Charlevoix, Michigan 49201

Dear Mr. Donnelly:

SUBJECT: BIG ROCK POINT - RESPONSE TO NRC BULLETIN 93-02, SUPPLEMENT 1,
"DEBRIS PLUGGING OF EMERGENCY CORE COOLING SUCTION STRAINERS"
(TAC NO. M89276)

This letter acknowledges receipt of your response dated April 15, 1994, to NRC Bulletin 93-02, Supplement 1 (Bulletin). The Bulletin was issued February 18, 1994, for action to all Boiling Water Reactor (BWR) licensees and for information to all Pressurized Water Reactor (PWR) licensees. The purpose of the Bulletin was to inform BWR and PWR licensees about the vulnerability of ECCS suction strainers in BWRs and containment sumps in PWRs to clogging during the recirculation phase of a loss-of-coolant accident (LOCA), to request that BWR licensees take the appropriate actions to ensure reliability of the ECCS in view of the information discussed in this bulletin supplement, and to require that BWR licensees report to the NRC on the requested actions taken. Your response adequately addressed the actions you will take to assure the operability of ECCS recirculation. We await your report confirming completion of the requested actions. Please retain any records of your actions in response to this Bulletin, as subsequent inspection activities may be conducted in regard to this issue.

Should you have any questions, please contact me at (301) 504-3018 or the lead Project Manager for this issue, John B. Hickman, at (301) 504-3017.

Sincerely,

Original signed by

Leonard N. Olshan, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9406080154 940602
PDR ADOCK 05000155
Q PDR

cc: see next page

DISTRIBUTION:

Docket File LOlshan
NRC & Local PDRs JHickman
PD31 Reading File RElliott, 8H7
JRoe CJamerson
JZwolinski OGC
LBMarsh ACRS (10)

M. Phillips, RIII

NRC FILE CENTER COPY

cc: Plant Service list

OFFICE	LA:PD31	PM:PD31	D:PD31
NAME	CJamerson	LOlshan:g11	LBMarsh
DATE	06/2/94	06/2/94	06/02/94

LF 01/10

Mr. Patrick M. Donnelly, Plant Manager
cc:

Big Rock Point Nuclear Plant

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Jane E. Brannon, County Clerk
County Building Annex
203 Antrim Street
Charlevoix, Michigan 49720

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Big Rock Point Plant
10253 U.S. 31 North
Charlevoix, Michigan 49720

Mr. Robert A. Fenech, Vice President
Nuclear Operations
Consumers Power Company
Palisades Plant
27780 Blue Star Memorial Hwy.
Covert, Michigan 49043