NRC FORM 366 (7-77) Update Report-Original submitted 1/21/83

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

Attachment to AECM-83/0168
Page 1 of 1

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MSGGS1 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000416 (7) | 121582 (8) | 031483 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On December 15 and 17, 1982, fire barriers were broken to route cables for
03 modifications to the transient test system. The penetrations were AE-290 (Auxiliary
04 Building floor penetration; elevation 166 feet) and 1H13-J732 (Control Room). An
05 hourly fire watch was established in accordance with T.S.3.7.7. The event had no
06 effect on the health and safety of the public and did not constitute a threat to
07 plant safety. The original report was submitted as a Special Report pursuant to
08 T.S.3.7.7.b.

09 SYSTEM CODE AB (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 176 | / | OCCURRENCE CODE 99 | REPORT TYPE X | — | REVISION NO. 1

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The fire barriers were broken in order to pull cables through them. Work was
11 completed by January 24, 1983, and the LCO was closed out. An hourly fire watch
12 was conducted for the duration of the event in accordance with T.S.3.7.7.
13 This is being submitted as a final report.
14

15 FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Planned Action

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8303220352 830314
PDR ADOCK 05000416
S PDR

NAME OF PREPARER Matthew V. Rohrer PHONE:

GPO 917-926